



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Bid Receiving - PWGSC / Réception des soumissions -
TPSGC**

**11 Laurier St. / 11, rue Laurier
Place du Portage, Phase III
Core 0B2 / Noyau 0B2
Gatineau, Québec K1A 0S5
Bid Fax: (819) 997-9776**

Revision to a Request for a Standing Offer

Révision à une demande d'offre à commandes

Regional Individual Standing Offer (RISO)

Offre à commandes individuelle régionale (OCIR)

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution

Electrical & Electronics Products Division
11 Laurier St./11, rue Laurier
7B3, Place du Portage, Phase III
Gatineau, Québec K1A 0S5

| | |
|--|---|
| Title - Sujet Key machine, software & supplies | |
| Solicitation No. - N° de l'invitation B8107-180074/A | Date 2017-12-19 |
| Client Reference No. - N° de référence du client B8107-180074 | Amendment No. - N° modif. 002 |
| File No. - N° de dossier hn460.B8107-180074 | CCC No./N° CCC - FMS No./N° VME |
| GETS Reference No. - N° de référence de SEAG PW-\$SHN-460-73772 | |
| Date of Original Request for Standing Offer 2017-11-20 | |
| Date de la demande de l'offre à commandes originale | |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-01-08 | |
| Time Zone Fuseau horaire Eastern Standard Time EST | |
| Address Enquiries to: - Adresser toutes questions à: Guertin, Benoit | Buyer Id - Id de l'acheteur hn460 |
| Telephone No. - N° de téléphone (819) 420-0331 () | FAX No. - N° de FAX () - |
| Delivery Required - Livraison exigée | |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: National Capital Region Région de la capitale nationale | |
| Security - Sécurité This revision does not change the security requirements of the Offer. Cette révision ne change pas les besoins en matière de sécurité de la présente offre. | |

Instructions: See Herein

Instructions: Voir aux présentes

| | | |
|--|--|---|
| Acknowledgement copy required Accusé de réception requis | Yes - Oui <input type="checkbox"/> | No - Non <input type="checkbox"/> |
| The Offeror hereby acknowledges this revision to its Offer. Le proposant constate, par la présente, cette révision à son offre. | | |
| Signature | Date | |
| Name and title of person authorized to sign on behalf of offeror. (type or print) Nom et titre de la personne autorisée à signer au nom du proposant. (taper ou écrire en caractères d'imprimerie) | | |
| For the Minister - Pour le Ministre | | |

This amendment (2) seeks to make the following changes and answer questions from vendors.

1) Questions and answers

Q7: On page 20 section 3.2 d) the requirement on the key is to have a blocking system. To our knowledge the blocking system is only available, and only relates to disc type of locks. The blocking system is to prevent manipulation or picking of the cylinder so as long as the product is ULC 437 rated it would meet the requirements. Please confirm...

A7: Yes, ULC 437 rated or with a blocking system

Q8: Please elaborate on the MACS restriction..... if the product can provide the 1 million plus usable codes what is the reason behind this requirement?

A8: National Approach Keying requires a large amount of usable codes

Q9: You mention control duplication through an additional security measure. Please elaborate.

A9: CIC wishes to control the duplication of the keys. We wish to avoid the possibility of product duplication outside of our shop.

Q10: Should the key blank be a specific dedicated keyway only?

A10: We will need key blanks to match the machine. The cylinders might have a different requirement depending on the product that we are servicing. If those cylinders have different requirements for keys, then those would also need to be provided.

Q11: Should the product not be manufacture in North American only to meet the 2 week turnaround on product?

A11: Not a requirement as long as the contractor meets the delivery deadlines. Deliverables can be expedited quickly even if not in Canada but these shipping costs must be included as part of the unit costing.

Q12: What are the current cylinder and keys being utilize at this facility?

A12: N/A, the new products would replace the current models. As specified before, the cylinders must be able to be implemented in Corbin-Ross and Schlage locksets

Q13: Page 20 section 3.1 a) when referring to the same MK system are you referring to an existing system?

A13: No

Q14: Is there a requirement for ULC 437 rating?

A14: Yes, if they do not have a blocking system

Q15: Does the key machine have to integrate with the software

A15: No but the software must meet the requirements stated and be under the same service contract as the key machine

Q16 Line item #1: Does not specify if you need cylinders (mortise cylinders or key-in-knobs) for these locksets or if you actually need the locksets.

A16 Both are needed, our offices have multiple locksets/devices that fall under both categories.

Solicitation No. - N° de l'invitation
B8107-180074/A
Client Ref. No. - N° de réf. du client
B8107-180074/A

Amd. No. - N° de la modif.
002
File No. - N° du dossier
hn460.B8107-180074

Buyer ID - Id de l'acheteur
hn460
CCC No./N° CCC - FMS No/ N° VME

Q17 Line item #2: Same as line #1.

A17 Both

Q18 Line item #7: We need to know what make of hardware you need the key-in-knobs for ie. Schlage, Corbin, Sargent, etc.

A18 All of the above, we tender for keys to be used in locksets and devices from Corbin-Russ, Schlage, etc

Q19 Line item #8: Again we need to know what type of unpinned cylinders you require ie. Mortise, key-in-knob, pênes deadbolts, etc.

A19 All

All other terms and conditions remain unchanged