



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
PWGSC/TPSGC Acquisitions
1045 Main Street
1st Floor, Lobby C
Unit 108
Moncton, NB E1C 1H1
Bid Fax: (506) 851-6759

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
NB / PEI Division - Moncton Acquisitions Office
1045 Main Street
1st Floor, Lobby C
Unit 108
Moncton, NB E1C 1H1

Title - Sujet Overhead Crane and Runway	
Solicitation No. - N° de l'invitation WB105-180037/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client WB105-180037	Date 2017-12-19
GETS Reference No. - N° de référence de SEAG PW-\$MCT-014-5337	
File No. - N° de dossier MCT-7-40032 (014)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-01-15	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: MacDonald, Charline	Buyer Id - Id de l'acheteur mct014
Telephone No. - N° de téléphone (506) 851-6067 ()	FAX No. - N° de FAX (506) 851-6759
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Title: Overhead Crane and Runway

Solicitation Amendment No. 004

This solicitation is hereby amended to provide the following questions and answers:

Q2. What is the grade of the flooring as well as the slope?

A2. Floor has a minimum 1% slope. Top of slab elevation is 47.898m.

Q3. Could you please confirm that the Department of National Defense (DND) will be supplying & installing the disconnect junction box and wiring to the power the crane system?

A3. The winning vendor of the contract will be responsible for all electrical requirements including installing the disconnect junction box, breakers, conduits, wiring etc. 600V and 208V are available.

Q4. What is the exact span required (measurements to the back of the air vent system)?

A4. 12.35m W (width of the two bays) 8.84m L (Depth of the Bay to air vent system)

Q5. Can DND please provide the following information:

5.1 - Length of runway

A5.1 - 8.84m

5.2 – Voltage

A5.2 - 600V and 208V available – contract will be responsible for all electrical requirements including breakers, conduits, wiring etc.

5.3 - Confirm floor thickness –

A5.3 - Floor is 200mm reinforced concrete

5.4 – Confirm dimension floor to underside of truss

A5.4 - 4.27m H (distance between floor and underside of truss) x 12.35m W x 8.84m L

Q6. Can we tie back to building column if required?

A6. If this is a requirement, the winning vendor will have to provide a structural engineer to verify applicable changes.

Solicitation No. - N° de l'invitation à soumissionner

WB105-180037/A

Client Ref. No. - N° de réf. du client

WB105-180037

Amd. No. - N° de la modif.

004

File No. - N° du dossier

MCT-7-40032

Buyer ID - Id de l'acheteur

mct014

CCC No./N° CCC - FMS No./N° VME

Q7. Can DND clarify what is meant by 3.1.4 height of lift 15 (4.58m) ft. usable height 13ft (3.97m).

A7. The usable height is the required height from the lifting point on the crane (hook) to the floor. The height of the lift is the overall height of the crane.

If your bid has already been forwarded and you wish to revise same, this revision should be sent either in a sealed envelope and mailed to the above address or by facsimile (506) 851-6759 and reach the undersigned before the appropriate closing date. The solicitation number and the closing date are to be shown on the outside of the sealed envelope or on the facsimile transmission.

All other terms and conditions of the solicitation document remain unchanged.

All enquiries concerning this amendment are to be forwarded to:

Name: Charline MacDonald

Telephone No: (506) 871-2953

Facsimile No: (506) 851-6759