



QUESTION & ANSWER #1

Date: December 19, 2017

Project: Replacement of 40 Ton Chiller in Penthouse – Building 22

Bidders must make sure that their bids are based on the latest version of the tender documents published and take into consideration the following amendments and information, including any information provided on amendments or Q&As previously published for this project.

Bidders that do not comply with this requirement will be discarded.

1. Question: What kind of refrigerant is being used in the current system?

Answer: The current system has R22 refrigerant.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED