

REVISIONS	DESCRIPTION	DATE
0	ISSUED FOR TENDER	17/07/04

A	A detail number number du detail	A
B	B source drawing no. de dessin no.	B
C	C detail on drawing no. detail sur dessin no.	C

project title  
**SALLYPORT GATE  
AND  
FENCE REPAIRS**  
titre du projet

drawing title  
**ELECTRICAL:  
SITE PLANS  
LEGEND  
DETAILS**  
titre du dessin

designed by  
HJ  
conçu par

drawn by  
BS  
dessiné par

approved by  
GR  
approuvé par

PWSC Project Manager  
LINDA KAMINSKI  
Administrateur de Projets TPSGC

scale  
AS NOTED  
échelle  
sheet  
feuille

project no.  
R.058018.001  
projet no.

date  
2017/07/04  
date

**E-1**  
OF 3

LEGEND

- MOTOR
- KEYED OPERATED CONTROL STATION - SUPPLIED BY GATE SUPPLIER
- DISCONNECT SWITCH - SUPPLIED WITH GATE MOTOR BOX
- POWER PANEL
- JUNCTION BOX
- DE-ICING SENSOR - RAYCHEM #SIT-GE OR APPROVED EQUAL
- DE-ICING CONTROLLER - RAYCHEM #ETI-PD-PRO OR APPROVED EQUAL
- HEAT TRACE POWER/END KIT - RAYCHEM #EMK-XP OR APPROVED EQUAL

ELECTRICAL DEMOLITION AND SALVAGE

- UNLESS OTHERWISE NOTED ALL EXISTING ELECTRICAL SYSTEMS WHICH BECOME REDUNDANT SHALL BE REMOVED BY THE CONTRACTOR.
- REMOVE ALL REDUNDANT EXISTING CONDUIT WHERE ACCESSIBLE.
- REMOVE ALL REDUNDANT EXISTING CONDUCTORS TO POINT OF SOURCE.
- CUT AND PATCH EXISTING WALLS WHERE REQUIRED TO ACCOMMODATE NEW EQUIPMENT OR CONDUIT. LEAVE FINISHED SURFACE OF WALL IN "READY TO PAINT" CONDITION.
- REMOVE ALL EXISTING REDUNDANT MATERIAL FROM THE SITE UNLESS DIRECTED OTHERWISE BY THE OWNER.
- CONTRACTOR SHALL VISIT SITE PRIOR TO TENDER TO DETERMINE EXTENT OF DEMOLITION REQUIRED. NO EXTRAS WILL BE CONSIDERED FOR WORK RESULTING FROM CONDITIONS THAT WOULD HAVE BEEN EVIDENT UPON THOROUGH EXAMINATION OF THE SITE.
- CONTRACTOR SHALL UPDATE AND CONFIRM PANEL SCHEDULES AND LOADS FOR ALL PANELS AFFECTED BY THIS RENOVATION.
- MAINTAIN CONTINUITY OF EXISTING BRANCH CIRCUITS AS REQUIRED TO PROVIDE POWER TO REMAINING EQUIPMENT, DEVICES AND LUMINAIRES THAT ARE NOT BEING REMOVED.
- ANY EXISTING CONDITIONS INDICATED ARE BASED UPON INFORMATION PROVIDED BY OTHERS. THE CONTRACTOR SHALL ADJUST FOR ACTUAL FIELD CONDITIONS AT NO ADDITIONAL EXPENSE TO THE OWNER.

