



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions/Travaux  
publics et Services gouvernementaux Canada  
The Cambridge Building  
3 Queen Street/3, rue Queen  
Charlottetown  
Prince Edward Island  
C1A 4A2

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

All enquiries are to be submitted in writing to the  
Contracting Authority, Darlene Reay, either by  
facsimile or by e-mail at:  
darlene.reay@pwgsc.gc.ca.

### Vendor/Firm Name and Address

Raison sociale et adresse du  
fournisseur/de l'entrepreneur

### Issuing Office - Bureau de distribution

Public Works and Government Services Canada  
The Cambridge Building  
3 Queen Street/3 rue, Queen  
PO Box 1268/CP 1268  
Charlottetown  
Prince Ed  
C1A 4A2

<b>Title - Sujet</b> Intrusion Alarm Systems	
<b>Solicitation No. - N° de l'invitation</b> W6898-180009/A	<b>Amendment No. - N° modif.</b> 003
<b>Client Reference No. - N° de référence du client</b> W6898-180009	<b>Date</b> 2017-12-22
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWC-008-4229	
<b>File No. - N° de dossier</b> PWC-7-40087 (008)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2018-01-09</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Atlantic Standard Time AST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Reay, D (PWC)	<b>Buyer Id - Id de l'acheteur</b> pwc008
<b>Telephone No. - N° de téléphone</b> (902) 566-7518 ( )	<b>FAX No. - N° de FAX</b> (902) 566-7514
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
W6898-180009/A  
Client Ref. No. - N° de réf. du client  
No./N° VME  
W6898-180009A

Amd. No. - N° de la modif.  
3  
File No. - N° du dossier  
PWC-7-40087

Buyer ID - Id de l'acheteur  
pwc008  
CCC No./N° CCC - FMS

---

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

This Addendum is raised to provide the following answers to questions provided by bidders.

**Q1**

Is software support for the Central Control Station to be included in this tender? If it is, what is the manufacture of the Central Control Station Software and the version it is running.

**A1**

No, the software is supplied by the Engineer. All work performed by the Contractor must integrate with the Security Information Systems Alarm Center software version 1.7 or the most current version identified by the Engineer.