



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:

Parks Canada Agency National Contracting Services

3, passage du Chien-d'Or Quebec, QC G1R 3Z8

INVITATION TO TENDER APPEL D'OFFRES

AMENDMENT #3 TO:

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission à: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes cijointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaires


Vendor/Firm Name and Address

Raison sociale et adresse du

fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency 3, passage du Chien-d 'Or Quebec, QC, G1R 3Z8









Amendment #3

THE PURPOSE OF THIS AMENDMENT IS TO PROVIDE DETAILS TO THE TECHNICAL SPECIFICATIONS AND TO PROVIDE ANSWERS TO THE FIRST SERIES OF QUESTIONS ASKED BY POTENTIAL BIDDERS. ANOTHER SERIES OF QUESTIONS AND ANSWERS WILL BE PROVIDED PRIOR TO BID CLOSING

YOU MUST CONSIDER THE INFORMATION BELOW, IN THE EVALUATION OF YOUR BID

Q2: In Drawing S100 there is mention of Pavement with a further note to "see landscape dwgs." I do not see any landscape drawing with the tender package and therefore do not know what site work may be involved with this project. Could you please clarify this point for me?

A2: There is no landscape work with this project.

Q3: The complexity of the steel structure, along with the sheer amount of galvanization required, will make it impossible to meet the project deadline of May 1st. Is it possible to extend the project completion date to July 1st as this is the more realistic time-frame for such a structure?

A3: The project completion date is extended to June 22, 2018.

Q4: Can we consider helical piles in place of caissons?

A4: The Bidder is to submit their bid assuming the foundation system as per the contract drawings.

Q5: What area of the site requires construction fencing?

A5: Contstruction fencing for this project is only limited to their working and storage area.

Q6: Do the pipe columns need to be galvanized?

A6: Yes.

Q7: How much time will there be between bid closing and award of contract?

A7: It is possible to award a contract within a week or two of bid closing, if there are no unforeseen circumstances.

Q8: Does Parks Canada keep the soil?

A8: Parks Canada (Point Pelee National Park) will keep the sand but any other removed materials are the responsibility of the contractor.







Q9: It was mentioned at the site meeting yesterday, as well noted in the Geotechnical Report, that alternate foundation designs are possible for this project. We would like to confirm that alternate foundation designs will be entertained and to know what is the process for proposing/including an alternate foundation design in the bid.

A9: The Bidder is to submit their bid assuming the foundation system as per the contract drawings, no alternative designs will be accepted.

Q10: On drawing S100 in Section 03 it calls for pavement around the footing. It says see Landscape drawings and when we refer to Drawing L-1 it doesn't show any paving. Please advise.

A10: There will be no paving work on this project. This will take place as part of Phase 2.

Q11: We are asking if the contractor's will have the opportunity to submit a bid based on a different foundation design using one of the foundation design approaches outlined in the Geotechnical report for this project, ie., using a "design/build" approach. If so, what would be the parameters of submitting such a bid.

A11: The Bidder is to submit their bid assuming the foundation system as per the contract drawings, no alternative designs will be accepted.

Q12: We are having great difficulty finding interested sub-contractors for the required drill size for the caissons, so we are unable to provide pricing for the current proposal. Please advise as to whether or not we are able to submit pricing using an alternate foundation design/plan for this project.

A12: The Bidder is to submit their bid assuming the foundation system as per the contract drawings, no alternative designs will be accepted.

Q13: Do we provide an alternate price for glass railing?

A13: Submit bid based on metal framing for all tower location aside from Resting Platforms 1 and 2 and the Observation Deck which will have glass railings.

End of section.

THE BID CLOSING DATE REMAINS THE 10TH OF JANUARY 2018, 2PM EST.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

Signed copy of this amendment should accompany each tender. If your tender has already been submitted please sign and fax the amendment along with any revisions to tender price, to this office before the close of Tender. Fax: 418 649-6971.

