



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Bid Receiving - PWGSC / Réception des soumissions -
TPSGC**

**11 Laurier/11,rue Laurier
Place du Portage, Phase III
Core 0B2 / Noyau 0B2
Gatineau, Québec K1A 0S5
Bid Fax: (613) 997-9776**

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Parliamentary Precinct Division/Acquisitions de la Cité
parlementaire
222 Queen Street / 222, rue Queen
Ottawa
Ontario
K1A 0S5

Title - Sujet High Density Mobile Shelving System	
Solicitation No. - N° de l'invitation EP758-181090/B	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client EP758-181090	Date 2018-01-02
GETS Reference No. - N° de référence de SEAG PW-\$PPS-013-26529	
File No. - N° de dossier 013pps.EP758-181090	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-01-15	
Time Zone Fuseau horaire Eastern Standard Time EST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Stone, Caitlin	Buyer Id - Id de l'acheteur 013pps
Telephone No. - N° de téléphone (613) 302-1235 ()	FAX No. - N° de FAX (613) 990-4447
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: See Annex A	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

QUESTION AND ANSWER SERIES 1

- Q.1. The specifications are unclear as they do not specify if a grouted system or floating floor (demountable) system is wanted. Generally, with a load bearing above 750 lbs per linear inch a grouted system is needed. This would match the requirement of steel plates. However, a demountable floating track system is specified. Can Public Services and Procurement Canada confirm?
- A.1. The proposed product must meet the Statement of Work and Mandatory Requirements. A floating floor (demountable) system is required and the system must be capable of carrying a minimum load of 1000 pounds per linear foot of carriage.
- Q.2. We use an alternative hook system to secure the shelves, however the specifications are written in a manner that denies this alternative. Do bidders have the ability to propose alternatives?
- A.2. An equivalent product can be proposed. Equivalent products will be reviewed to ensure that they are compliant with the Statement of Work and the Mandatory Requirements.
- Q.3. Is a modular floor acceptable?
- A.3. Yes, the proposed product must meet the statement of work and mandatory requirements. A modular floor (floating floor, demountable) system is required. A modular floor for the floor deck is acceptable as that is what is specified in the Statement of Work.
- Q.4. Are aisle brakes a requirement?
- A.4. Yes, aisle brakes are a requirement and must be included.
- Q.5. Can PSPC confirm the meaning of preformed edging?
- A.5. Annex A1.1 General Specifications, Section 1.3, Finish, Sub-section "C", is revised to read: "Edgings are to be of one continuous moulded form. Sharp edges are unacceptable."
- Q.6. In Appendix II, Financial Bid Presentation Sheet, Table One include installation in the unit prices. If the successful bidders is requested to complete installation outside of regular working hours, how will they be paid?
- A.6. Bidders should enter unit prices and the price for installation and delivery during regular working hours in Table One of Appendix II. If Bidders are requested to work outside regular working hours, they will be compensated an additional amount per labourer, per hour. Bidders should input this additional charge (if applicable), in Table Three of Appendix II.
- Q.7. In Appendix II, the Financial Bid Presentation Sheet, Table 2, can PSPC explain the purpose of the storage space and what is being stored?
- A.7. The storage space would be required in the event that Canada cannot receive the components on site during the delivery period specified in the Request for Proposal. This could include all or only some of the components specified in this requirement. The Bidder would be responsible for storing and moving the components. The value of the materials could be up to the entire value of the requirement. The Bidder has the option of engaging a moving and storage company for this requirement if requested to store the components by the Project Authority, but the prices submitted in their bid must be honoured if they are the successful proponent.
- Q.8. Can PSPC confirm if the shelves are to be full depth or back to back?

Solicitation No. - N° de l'invitation
EP758-181090/B
Client Ref. No. - N° de réf. du client
EP758-181090

Amd. No. - N° de la modif.
002
File No. - N° du dossier
013ppsEP758-181090

Buyer ID - Id de l'acheteur
013pps
CCC No./N° CCC - FMS No./N° VME

A.8. Where applicable, the shelves are to be back to back depth.

Q.9. Do any of the systems require to be locked?

A.9. No, a locking mechanism is not required.

Q.10. Is there an astragal/top screen mechanism required in any of the systems?

A.10. No, this is not a requirement.

Q.11. Can PSPC confirm the sprinkler height in each room and are the requirements such that there has to be more than 18" of clearance for each system to meet fire code?

A.11. The clearance is in excess of 18", meeting fire code requirements. The ceiling height is in excess of 4m AFF in all 3 rooms.

Q.12. Do all carriages have a requirement to be anti-tip, or only the single, movable carriages?

A.12. All carriages must be anti-tipping.

Q.13. Each mobile indicates an aisle of 36" and a 2" bumper, however, the total allowable space indicated is not large enough to accommodate 2" bumpers and a 36" aisle. Can PSPC clarify?

A.13. A smaller aisle is acceptable in order to fit the bumper requirement, as long as no clear width is less than 815mm (32").

Q.14. Can PSPC confirm that all the systems are to have a demountable finished steel floor?

A.14. The entire floor area (deck) that is accessible to the operator shall be provided with a finished steel flooring system with durable non-slip textured powder paint. Deck must be able to accommodate both a carpet and a linoleum finish. Decks from a floating demountable system shall be designed such that the sections are secure during normal use and operation, but can be assembled or disassembled without the use of any tools. Decks must be easily removed for accessibility to all track parts, cleaning and ease of maintenance and for access to floor below.

Q.15. Can PSPC confirm if dividers are needed? If so, how many per shelf?

A.15. The requirement is for 1 file divider per 18 inches (457 linear mm) for all shelves.

END OF QUESTION AND ANSWER SERIES 1
