



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Parks Canada Agency
1869 Upper Water Street, Suite AH 201
Halifax, Nova Scotia B3J 1S9

Bid Fax: 902-426-1775

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
1869 Upper Water Street, Suite AH 201
Halifax, Nova Scotia B3J 1S9

Title-Sujet Water Supply System, Cape Spear Lighthouse National Historic Site		
Solicitation No. - No. de l'invitation 5P201-17-5168/A	Amendment No./N° de modification de l'invitation 001	
Client Ref. No. - No. de réf du client. 1327	Date: January 4, 2017	
GETS Reference No. - No de reference de SEAG PW-17-00808390		
Solicitation Closes:		
at - à 02:00 PM	on - le January 9, 2018	Time Zone - Fuseau horaire AST - HNA
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/>	Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à :		
Tanya Allen – tanya.allen@pc.gc.ca		
Telephone No. - No de téléphone	Fax No. - No de FAX:	
(902) 426-7543	(902) 426-1775	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:		
See Herein – Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)
À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)

Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur	
Address – Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de téléphone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

AMENDMENT 001

1.0 Question

Q1 Can you please provide some clarification with respect to the overall water quality, any test results of the type of water that is being presently supplied via this older system and what you would like to achieve with this new Water Supply System.

A1 -

- Water treatment is not part of scope of work.
- Contract objective is to supply water from source, newly constructed well, to 2 on-site buildings.
- Disinfection of waterline to be as per AWWA C651.

ALL OTHER TERMS AND CONDITONS REMAIN THE SAME.
