



# TENDER AMENDMENT

## RETURN BIDS TO:

Parks Canada Agency  
635 – 8 Avenue S.W., Suite 1300  
Calgary, AB T2P 3M3  
Bid Fax: (403) 292-4475

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

## Issuing Office:

Parks Canada Agency  
635 – 8 Avenue S.W., Suite 1300  
Calgary, AB T2P 3M3

# MODIFICATION D'APPEL D'OFFRES

## RETOURNER LES SOUMISSIONS À :

Agence Parcs Canada  
635 – 8 Avenue S.O., pièce 1300,  
Calgary, AB T2P 3M3  
N° de télécopieur pour soumissions : (403) 292-4475

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

## Bureau de distribution :

Agence Parcs Canada  
635 – 8 Avenue S.O., pièce 1300  
Calgary (AB) T2P 3M3

<b>Title:</b> Apartment Block A & Block B Roofing Replacement – Glacier National Park, Rogers Pass		
<b>Solicitation No.: / N° de l'invitation :</b> 5P420-17-5309/B	<b>Amendment No.: / N° de modification de l'invitation :</b> 001	<b>Date:</b> January 08, 2018  <b>Date :</b> 08 janvier 2018
<b>GETS Reference No.: / N° de référence de SEAG :</b> PW-17-00809060		
<b>Solicitation Closes: / L'invitation prend fin :</b>		
<b>At:</b> 02:00 PM	<b>On:</b> January 16, 2018	<b>Time Zone:</b> Pacific Standard Time (PST)
<b>À :</b> 14h00	<b>Le :</b> 16 janvier 2018	<b>Fuseau horaire :</b> Heure Standard du Pacifique (HNP)
<b>Address Inquiries to: / Adresser toute demande de renseignements à :</b> Danny Ahn		
<b>Telephone No.: / N° de téléphone :</b> (403) 292-5451	<b>Fax No.: / N° de télécopieur :</b> 1-866-246-6893	<b>Email Address: / Courriel :</b> Danny.ahn@pc.gc.ca
<b>TO BE COMPLETED BY THE BIDDER (type or print) À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)</b>		
<b>Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur</b>		
<b>Address - Adresse</b>		
<b>Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur</b>		
<b>Title - Titre</b>		
<b>Signature</b>		<b>Date</b>

## **Amendment 01**

This amendment is being raised to provide information requested through e-mail and extend the bid closing date. All such revisions will become part of the Work and the effects shall be included in the Tender Price. All work shall be performed in accordance with the Contract Documents.

### **A) Questions and Answers**

- Q1.** Please advise if roof plan, roof details, existing roof system info. are available to bidders, since we cannot find any in the currently posted files.  
**A1.** Attached are existing roof system drawings and photos. For new roof specification please see the specification package provided.
- Q2.** How many drains, vents and scuppers on each building and location?  
**A2.** Pictures with drains, vents and scuppers are attached.
- Q3.** Layout of drains for tapered insulation?  
**A3.** As existing. Pictures attached.
- Q4.** Height and size (width) of existing parapets?  
**A4.** Drawings attached.
- Q5.** Height of Building? Scaffold, ladder or roof hatch access?  
**A5.** Height of the building – 7m. Portable ladder access. Contractor to provide all access.
- Q6.** Any Pictures of existing roof?  
**A6.** Attached.
- Q7.** Is the intent to not have a vapour barrier?  
**A7.** Vapour barrier is part of the existing ceiling and wall system.
- Q8.** Is it the intent to have mechanically fastened the insulation and coverboard, hot asphalt adhered, or low rise foam adhered?  
**A8.** Mechanically fastened.
- Q9.** No insulation is specifically specified in the products section. Is the intent to increase the R value?  
**A9.** Yes, the intent is to increase the R value. Products such as IKOTerm III shall be used.
- Q10.** Have you got a roof inspector for this project?  
**A10.** Yes.

## B) Drawings

Please see attached folder *drawings* within DSP2 – 17-5309.zip

## C) Images









**All other terms and conditions remain the same.**