



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

**Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada**  
**Pacific Region**  
**401 - 1230 Government Street**  
**Victoria, B.C.**  
**V8W 3X4**  
**Bid Fax: (250) 363-3344**

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada - Pacific  
Region  
401 - 1230 Government Street  
Victoria, B. C.  
V8W 3X4

<b>Title - Sujet</b> CCGS Neocaligus - Genset	
<b>Solicitation No. - N° de l'invitation</b> F1782-17C871/A	<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b> F1782-17C871	<b>Date</b> 2018-01-09
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$XLV-176-7391	
<b>File No. - N° de dossier</b> XLV-7-40157 (176)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2018-01-24</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Pacific Standard Time PST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Godin, Andre	<b>Buyer Id - Id de l'acheteur</b> xlv176
<b>Telephone No. - N° de téléphone</b> (250) 216-2504 ( )	<b>FAX No. - N° de FAX</b> ( ) -
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

**This solicitation amendment is to promulgate the following:**

**1) Bidder questions and Canada responses**

<b>Items</b>	<b>Bidder's questions</b>	<b>Canada Responses</b>	<b>Date</b>
1	Section 3.2.1.1 Please confirm AC voltage 120/240VAC with 3 phase (Not what we typically see but can be done)	Yes, that is correct	2018-01-08
2	Section 3.2.1.18 Is the requirement to load test 4 hours 100% load and 4 hours at 110% load? Or is the request to load test at 100% load for 4 hours total and also show that the unit can perform at 110% load during the 4 hours?  The manufacturer does not recommend testing at 100% or 110% load for extended period of time. When additional time for load testing and break is requested, the manufacturer would test at varying load levels. On units of this size, data is taken at 0%, 25%, 50%, 75%, 100% and 110% levels.	The contractor must break in the engine and generator as per the manufacturer's instructions on a dynamometer in their shop. All engine and generator temperatures must be recorded at ½ hour intervals and provided to Canada in a report.	2018-01-08