



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

Revision to a Request for a Standing Offer

Révision à une demande d'offre à commandes

Regional Individual Standing Offer (RISO)

Offre à commandes individuelle régionale (OCIR)

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Interior and Exterior Painting		
Solicitation No. - N° de l'invitation W6897-180002/A		Date 2018-01-10
Client Reference No. - N° de référence du client W6897-180002		Amendment No. - N° modif. 001
File No. - N° de dossier pwu066.W6897-180002	CCC No./N° CCC - FMS No./N° VME	
GETS Reference No. - N° de référence de SEAG PW-\$PWU-066-11287		
Date of Original Request for Standing Offer Date de la demande de l'offre à commandes originale		2017-12-21
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-01-15		Time Zone Fuseau horaire Mountain Standard Time MST
Address Enquiries to: - Adresser toutes questions à: Lee, Mony		Buyer Id - Id de l'acheteur pwu066
Telephone No. - N° de téléphone (780) 224-6675 ()		FAX No. - N° de FAX (780) 497-3510
Delivery Required - Livraison exigée		
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:		
Security - Sécurité This revision does not change the security requirements of the Offer. Cette révision ne change pas les besoins en matière de sécurité de la présente offre.		

Instructions: See Herein

Instructions: Voir aux présentes

Acknowledgement copy required Accusé de réception requis	Yes - Oui <input type="checkbox"/>	No - Non <input type="checkbox"/>
The Offeror hereby acknowledges this revision to its Offer. Le proposant constate, par la présente, cette révision à son offre.		
Signature	Date	
Name and title of person authorized to sign on behalf of offeror. (type or print) Nom et titre de la personne autorisée à signer au nom du proposant. (taper ou écrire en caractères d'imprimerie)		
For the Minister - Pour le Ministre		

This solicitation amendment has been raised to make the following clarification:

Question 1:

In the Basis of Payment, Col. 1 item 11 and 12 describe fire retardant base and finish coat paint respectively.

What fire rating is required – 1 hr, 2 hr, etc?

What surface is being painted with the fire retardant?

Response:

The fire rating would be dependent on surface applied too and asset it may protect; ie. Fire rated door in ammonia plant would be painted to a fire rating of 1.5 hrs. Minimum of 1hr to max 2 hrs. for fire rating.

Fire retardant coatings and Intumescent Fire Resistant paints are for interior and exterior use and could include the following:

- Doors
- Decking
- Bar-tops
- Paneling and Matchboard
- Cladding
- Floors
- Industrial buildings and

In addition can refer to NBC Chapter 3: 3.1.13.2 (1)