



RETURN BIDS TO :

RETOURNER LES SOUMISSIONS :

Bid Receiving Unit / Groupe de la réception des soumissions

Procurement & Contracting Services / Services d'acquisitions et des marchés.

VISITOR'S CENTRE
Royal Canadian Mounted Police
73 Leikin Drive, Ottawa, Ontario

Telephone No.

no de téléphone: (613) 843-3798

AMENDMENT TO THE INVITATION TO TENDER

Royal Canadian Mounted Police

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefore.

MODIFICATION À L'APPEL D'OFFRES

Gendarmerie royale du Canada

Nous offrons par la présente de vendre à Sa Majesté I Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments – Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Telephone No. – No de téléphone:

()

Facsimile No. – No de télécopieur:

()

Title-Sujet Construction – Site Clearing and Parking Lot Construction		
Solicitation No. – No. de l'invitation 201805065	Amend. – Modif. No. : 4	Date Jan. 11th, 2018 / 11 janvier, 2018
Client Reference No. - No. de Référence du Client 201805065		
GETS Reference No. – No de Référence du SEAG PW-17-00809889		
Solicitation Closes – L'invitation prend fin at – à 2:00 P.M. EST on – January 16th, 2018., 16 janvier, 2018		
F.O.B. - F.A.B. Destination		
Address Enquiries to: - Adresser toute questions à : Jordan McKenna		
Telephone No. - No de téléphone 613-843-5518	Fax: 613-825-0082	
Destination of Goods - Destinations des biens: See Herein		
Instructions : See Herein / Voir aux présentes		
Delivery Required – Livraison exigée: See Herein		
Name and Title of person authorized to sign on behalf of Vendor/Firm. Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		

Amendment No. 4

Construction – Site Clearing and Parking Lot Construction
SOLICITATION NO. : 201805065

Date: January 11th, 2018

Amendment #4 is being issued in order to respond to Questions PART 1 as follows:

Q1) Please explain what the security clearance for this project is. Documents say RCMP Facility Access Level 2 Status Security Clearance. What is this level and how long does it take to be cleared?

A1) Yes Facility Access Level 2 is required. However, security clearances are only issued upon award of a contract, so bidders do not need to submit anything during the bidding period. Unfortunately I'm not able to give you a definitive time frame right now regarding the length of time it takes to be cleared.

Q2) What is the expected start and completion date for this project?

A2) Expected start date is upon contract award. The Contractor shall perform and complete the site clearing work by March 31st, 2018.

The Contractor shall perform and complete the parking lot construction and paving work by September 28th, 2018.

Q3) Could you please confirm that the security requirements for this project related to the RCMP Facility Access Level 2 requirements only have to be in place/completed if lowest bidder or awarded the project? Or do we have to have in place to bid this project? We currently have DOS security clearances for our employees, would DOS security clearances be acceptable? or do we have to rescreen all of our employees/sub contractors based on the RCMP Facility Access Level 2 requirements?

A3) Please refer to answer number 1 above.

Q4) Is the completion date (March 31, 2018) provided firm or can we negotiate a revised completion date if low bidder? As no local asphalt suppliers will be available for supply of asphalt until usually mid May 2018. As well placement of sodding and landscaping will not be ideal in March

A4) Site clearing must be done by March 31, no flexibility. Balance of work to be completed by Sept. 28th.

Q5) Item BA06 of the ITT specifies a completion date of March 31st, 2018 for all work. Therefore, are we to complete all work including asphalt, curbs, sidewalks, landscaping, etc. by this date?

A5) See A4 above.

Q6) Drawing C11 rev A seems to be for another project (Building A) and is not mentioned on the Civil Drawing List. Can you confirm that C11 is not relevant to this tender?

A6) C11 is relevant for this tender for the additional area for clearing and grubbing.

Q7) We noticed multiple references to the Site Furnishing Specifications (i.e. Note 19 on L300). However, we are unable to locate the specifications within the documents. Can you please provide the project specifications?

A7) See spec section 32 33 00, posted under Amendment 2.

Q8) Can you please provide the specifications for the tender? At this stage, we are not able to provide proper pricing regarding the work (i.e. permit fees by?, service connection fees?, etc) and General Conditions.

Q8) Specification issued under Amendment 2

Q9) Note 14 on AD100 calls to remove existing trees, undergrowth, roots, shrubs, and topsoil down to bed rock. We also noticed multiple Test Pit on C100. However, we are unable to locate the Geotechnical Report within the documents. Can you please provide the bedrock survey or any assumptions for pricing purposes?

A9) Bedrock is at or near the surface with varying shallow soil depths up to a maximum of approximately .5M

Q10) Note 25 on C101 calls for painted parking tails. However, Note 23 states that the surface course is by others (future). Do we need to provide line painting on the base course or this will be completed at a later time?

A10) Painting in the parking lot will be completed at a later time. Painting in the roadways to be completed as part of this tender.

Q11) Is there an electrical specification for all the required equipment as our suppliers will need this to provide costs for the items?

A11) See specification provided as Amendment 2

Q12) Is there any ground survey to provide rock levels or is a m3 rate to be provided?

A12) Bedrock is at or near the surface with varying shallow soil depths up to a maximum of approximately .5M

Q13) Is the code blue and the cameras to be supplied and installed by others? Is there a required sizing for the service kiosk?

A13) Yes, and yes, base sizing info in drawings.

Q14) Is there a quantity slip for this project, so we could bid all the same items?

A14) No

Q15) Does the lighting control required relate to the pole or the fixture?

A15) On fixture

Q16) Do you have a control system existing which these need to work with (could you let us know whose) or is the control infrastructure required as well?

A16) No central control

Q17) Does the type C fixture require a house shield?

A17) No

Q18) Please specify the model and suppliers for the proposed bench and waste receptacle.

A18) Please refer to specification under Amendment A.

Q19) Please specify the type and colour of unit pavers to be installed. Spec.

A19) Please refer to specification under Amendment A.

Q20) What is the depth of Frost Treatment and Frost Penetration for the formula on OPSD 803.030?

A20) It is up to the bidder to check out the OPSD requirements which are publicly available Standards

Q21) Is there information on the depth of topsoil to be stripped prior to construction?
Spec

A21) It is up to the bidder to check out the OPSD requirements which are publicly available Standards

Q22) Is there information on the depth of topsoil to be stripped prior to construction?

A22) Please refer to specification under Amendment A.

Q23) What is the dark black outline on dwg C100 that the proposed storm undermines?

A23) Thick black box is an outline of a temporary shelter, now removed.

Q24) Could you please send a copy of the Bidders list for our reference.

A24) No Bidders list is available. For similar information, you can view the voluntarily provided 'List of Interested Suppliers' list here...
<https://buyandsell.gc.ca/procurement-data/tender-notice/PW-17-00809889/list-of-interested-suppliers>

Q25) Square tapered aluminum poles are not available. It can be Straight Square Aluminum, Round tapered Aluminum, or Square Tapered Steel.

A25) Straight square aluminum is fine

Q26) Is there a geotechnical report for this project?

A26) Will be made available to the successful bidder

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

END