



0	ISSUED FOR TENDER	2017/11/30
Revision/Revisión	Description/Description	Date/Date
Client/client		

PARKS CANADA

Project title/Titre du projet
23433 Mavis Avenue
Fort Langley, British Columbia

FORT LANGLEY NATIONAL HISTORIC PARK KITCHEN UPGRADE

Consultant Signature Only

Designed by/Conçu par
M.K.

Drawn by/Dessiné par
W.E.

PWGSC Project Manager/Administrateur de Projets TPSGC
TOM DUNPHY





Regional Manager, Architectural and Engineering Services
Gestionnaire régionale, Services d'architectural et de génie, TPSGC
PREETIPAL PAUL

Drawing title/Titre du dessin

KITCHEN AND WASHROOMS ELECTRICAL AND LIGHTING PLANS

Project No./No. du projet R.081108.001	Sheet/Feuille E-02 OF 4	Revision no./No. de Révision
--	--------------------------------------	------------------------------

- DEMOLITION NOTES:**
- DEMOLITION WORK TO BE CARRIED OUT BY QUALIFIED ELECTRICAL CONTRACTOR
 - ALL EXISTING ELECTRICAL OUTLETS TO BE REMOVED.
 - ALL EXISTING LIGHTING FIXTURES, EXIT SIGNS AND LIGHTING CONTROLS TO BE REMOVED.
 - ALL WIRING TO BE REMOVED BACK TO TERMINATION PANEL.
 - EXISTING 100A PANEL, MAIN FEEDER AND BRANC WIRING TO BE REMOVED. FEEDER TERMINATES IN MAIN DISTRIBUTION CENTRE. SEE LOCATION ON DRAWING E1.
 - ALL REMOVED EQUIPMENT TO BE DISPOSED IN ACCORDANCE WITH LOCAL BYLAWS.
 - RELOCATE EXISTING SECURITY DEVICES TO SUIT NEW SPACE LAYOUT.
 - EXISTING LIGHTING FIXTURES (FLUORESCENT STRIPS) AND CONTROLS IN BOTH WASHROOMS TO BE REMOVED. RETAIN CIRCUITS TO CONNECT NEW LIGHTING FIXTURES.
 - EXISTING HAND DRYERS TO BE REMOVED. RETAIN CIRCUITS TO CONNECT NEW ELECTRIC HAND DRYERS.
 - RELOCATE SECURITY CONTROL PANEL AND EXISTING DEVICES AS SHOWN ON REVISED ELECTRICAL PLAN.
 - REMOVE TWO WALL MOUNTED, EXTERIOR LIGHTING FIXTURES TYPE 'X'. REROUTE EXISTING FEEDERS TO NEW PANEL 'K'. REUSE FEEDER TO SUPPLY NEW LIGHTING FIXTURES TYPE 'C'.



PROFESSIONAL ENGINEER
J. F. FERNANDEZ
33531
NOV 29 2017

