


OPERATION BUILDING - EXISTING PARTIAL GROUND FLOOR PLAN
1:50



OPERATION BUILDING - EXISTING BASEMENT FLOOR PLAN
1:50

EXISTING BASEMENT CEILING IS AFFECTED BY THIS RENOVATION AND MAY BE RE-ARE AND PATCHED AND MAKE GOOD, SPRINKLER SYSTEM MAY BE REQUIRED TO BE RE-ARE TO ALLOW FOR MECHANICAL AND PLUMBING RENOVATION. TYPICAL IN THE AREAS OF RENOVATIONS.

DRAWING F-02 NOTES:

- F2.1 EXISTING SPRINKLER HEADS AND PIPING TO REMAIN - CEILING DEMO
- F2.2 EXISTING RISER DOWN TO REMAIN.

GENERAL NOTES:

1. SPRINKLER CONTRACTOR TO ACCOMMODATE MODIFICATION IN BUILDING BASEMENT, RE AND RE EX. SPRINKLER HEADS.
2. PROVIDE FIRE WATCH IF ANY OF THE FIRE ALARM SYSTEM, AUTOMATIC SPRINKLER SYSTEM, OR EMERGENCY POWER SYSTEM OR IF ANY PORTION OF THESE SYSTEMS IN THE BUILDING IS NOT OPERATING.
3. SYSTEM MUST BE OPERATIONAL IF FIRE WATCH IS NOT PRESENT ON THE SITE.
4. REVIEW ALL EXPOSED PIPE ROUTING WITH DESIGN TEAM PRIOR TO PROCEEDING WITH CONSTRUCTION.

Revision/Revision	Description/Description	Date/Date
2	ISSUED FOR 100%	2017-11-30
1	ISSUED FOR 90% CD REVIEW	2017-11-23
0	ISSUED FOR DD	20170803

Client/Client
PARKS CANADA

Project title/Titre du projet
23433 Mavis Avenue
Fort Langley, British Columbia
FORT LANGLEY NATIONAL HISTORIC PARK KITCHEN UPGRADE

Consultant Signature Only
Designed by/Concept par
I.N.
Drawn by/Dessine par
S.E.
PWGSC Project Manager/Administrateur de Projets TPSGC
TOM DUNPHY
Regional Manager, Architectural and Engineering Services
Gestionnaire régionale, Services d'architectural et de génie, TPSGC
PREETIPAL PAUL

Drawing title/Titre du dessin
EXISTING FLOOR PLANS - FIRE PROTECTION

Project No./No. du projet R.081108.001	Sheet/Feuille F-02	Revision no./La Révision no. 2
--	------------------------------	--