



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency
1869 Upper Water Street, Suite AH 201
Halifax, Nova Scotia B3J 1S9

Bid Fax: 902-426-1775

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
1869 Upper Water Street, Suite AH 201
Halifax, Nova Scotia B3J 1S9

Title-Sujet Corney Brook Campground, Renewable Energy System and Water Disinfection System		
Solicitation No. - No. de l'invitation 5P201-17-5105/B		Amendment No.:/N° de modification de l'invitation 002
Client Ref. No. - No. de réf du client.		Date: January 12, 2018
GETS Reference No. - No de reference de SEAG PW-17-00809194		
Solicitation Closes:		
at - á 02:00 PM	on - le January 18, 2018	Time Zone - Fuseau horaire AST - HNA
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à :		
Tanya Allen - tanya.allen@pc.gc.ca		
Telephone No. - No de téléphone		Fax No. - No de FAX:
(902) 426-7543		(902) 426-1775
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:		
See Herein - Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)
À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)

Vendor/Firm Name - Nom du fournisseur/de l'entrepreneur	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de téléphone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

AMENDMENT 002

1.0 Bid Closing Date

The closing date for tender 5P201-17-5105/B is extended from January 16, 2018 until January 18, 2018 at 2:00PM Atlantic Standard Time (AST).

2.0 Questions

Q1 On drawing A01, the Washroom Facility Plan shows the louver on the south wall, while the North Elevation shows the louver installed in the double doors on the North wall.

A1 *Louvers should be provided at both locations (in double doors on north wall and on south wall). Omissions on drawing were made in error.*

Q2 Is there a specification / dimension for the louver and motorized damper?

A2 *No mechanical or manual damper is required for the proposed louvers. Each louver to be aluminum drainable stationary type. Minimum 2 ft² free area. Extruded aluminum frame construction, standard mill finish, complete with extended sill and bird/insect screen.*

Q3 There is a flow meter in the drawing after the hypochlorination system and before the storage tank. What is the purpose of this flow meter?

A3 *The purpose of the flow meter is to be able to adjust and calibrate the chlorination based on flow.*

Q4 Section 22 31 13 a.Subsection 1.2.1 i. Our proposed water treatment filters carry a CUL designation, not CSA. Will this be acceptable?

A4 *Water treatment products with a CUL designation are an acceptable equivalent to the CSA designation.*

Q5 Reference Drawing MO1. Is there a design line size for the interconnecting pipe between equipment?

A5 *The interconnecting pipe between equipment can vary depending on the final supplier but we anticipate a typical range of 0.5 – 1 inch diameter piping.*

Q6 Reference Section 22 10 10 a.Part 2.2.4 (Valves). Is there a specified check valve to be used for each pump?

A6 *Check valves must meet referenced standards at a minimum.*

Q7 Section 22 42 01 a. Part 2.4 (Flow Meter): What kind of flow meter is required? What data should be on the readout? Does the readout need to transfer data to a plc or scada system?

A7 *The flow meter should be able to measure flow and provide flow data capable of being transferred to a PLC system.*

Solicitation No. - N° de l'invitation
5P201-17-5105/B

Amd. No. - N° de la modif.
002

Buyer - l'acheteur
Tanya Allen

Client Ref. No. - N° de réf. du client

File Name - Nom du dossier

Corney Brook Campground, Renewable Energy System and Water Disinfection System

Q8 Clarification on electric heat.

A8 *Electric heat will not be required as part of this contract.*

ALL OTHER TERMS AND CONDITONS REMAIN THE SAME.
