



Parks Canada
Parcs Canada



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Parks Canada
National Contracting Services**

**3, passage du Chien-d'Or
Quebec, QC
G1R 3Z8**

INVITATION TO TENDER
APPEL D'OFFRES

AMENDMENT #3 TO:

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission à: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments – Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
3, passage du Chien-d'Or
Quebec, QC, G1R 3Z8

Title-Sujet Fort Wellington National Historic Site Fortifications Rehabilitation		Date 2018.01.15
Solicitation No. - No. de l'invitation 5P201-17-5171/A		Client Ref. No. - No. de réf du client.
GETS Reference No. - No de reference de SEAG		
Solicitation Closes L'invitation prend fin – at – à 2:00 PM on – le 2018-01-18		Time Zone Fuseau horaire - EASTERN STANDARD TIME (EST)
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Josée Gagnon josee.gagnon@pc.gc.ca		
Telephone No. - No de téléphone 418-648-2502		Fax No. - No de FAX: 418-649-6971
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur Telephone No. - No de telephone: _____ Facsimile No. - N° de télécopieur: _____		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur _____ Name / Nom Title / Titre _____ Signature Date		



AMENDMENT #3

THE PURPOSE OF THIS AMENDMENT IS TO PROVIDE DETAILS TO THE TECHNICAL SPECIFICATIONS AND TO PROVIDE ANSWERS TO THE QUESTIONS ASKED BY POTENTIAL BIDDERS.

YOU MUST CONSIDER THE INFORMATION IN THE EVALUATION OF YOUR BID.

QUESTIONS AND ANSWERS:

1.1 Question	Does Parks Canada know a manufacturer for the historic nails?
1.1 Answer	<p>“Cut spikes” are available from traditional nail mills using traditional hand-fed nail machinery. Alternatively, the shape may be simulated and custom-fabricated by a machine shop or metal-working facility.</p> <p>Contractor to propose historic nails and obtain Departmental Representative’s approval.</p>
1.2 Question	Item #5 and #6 for the Palisade Wall are provisional, and item #1 Revetment wall requires the wood to be reused from the Palisade wall, what if the Palisade wall does not go forward, what would we use for the wood for the revetment wall?
1.2 Answer	<p>For purposes of pricing under Item #1, account for the greater of the following:</p> <ul style="list-style-type: none"> (a) supply new wood for revetment; and/or (b) prepare and reuse use wood from palisades. <p>For purposes of pricing under Items #5 and #6, account for the greater of the following:</p> <ul style="list-style-type: none"> (a) completely remove wood from site; and/or (b) set aside portions of wood for reuse on Revetment wall. <p>Obtain written approval from Departmental Representative prior to reusing wood material from existing Palisades.</p>
1.3 Question	<p>I need clarification on the cedar post diameter for the palisade wall.</p> <p>Specifications state Anchor Post = Avg 235mm Intermediate Post = Avg 220mm</p> <p>Drawing Shows Anchor Post = 230mm Intermediate Post = Min 205mm</p>



<p>1.3 Answer</p>	<p>The post members are a natural product and will not all be exactly the same size; sizes given on drawings are <u>minimum</u> at mid-height stringer. To ensure an appropriate level of variability, <u>average</u> diameters are also given (in project specifications). To clarify, values provided in specification also apply at mid-height stringer.</p>
<p>1.4 Question</p>	<p>Will any other cedar type be acceptable? The eastern white cedar in a 10 foot length is proving tuff to source.</p>
<p>1.4 Answer</p>	<p>Provide members and species as specified.</p>
<p>1.5 Question</p>	<p>Also the Work schedule as per section 01 11 00 states Thanksgiving 2017 to Victoria day 2018 And Thanksgiving 2018 to Victoria day 2019 with a substantial date of April 30, 2019</p> <p>Since some of the above time has passed, will there be any adjustment to the completion date?</p>
<p>1.5 Answer</p>	<p>Please refer to Addendum #1 regarding dates.</p>
<p>1.6 Question</p>	<p>Is there record of the previous contractor that replaced the fraising in the 90's? If so can it be published so we can ask them questions on methods used?</p>
<p>1.6 Answer</p>	<p>This information will not be made available at this time.</p>
<p>1.7 Question</p>	<p>Back pointing is not listed in the cost breakdown schedule, however upon review of the drawings appears to be required/necessary. Should back pointing be included with the repointing cost?</p>
<p>1.7 Answer</p>	<p>Measurement and payment for repointing shall be as per 01 29 00, Item 1.3.7. ADD the following text to item 1.3.7.2: "Where backpointing is required along a segment to a depth greater than 100mm (but not more than 200mm), pro-rate length of measurement for this segment by total average depth divided by 100mm."</p>
<p>1.8 Question</p>	<p>Under the Masonry spec there are a number of requirements listed, can you please clarify and confirm how strict or if all are required?</p> <ul style="list-style-type: none"> A) Submit recordings of temperature and humidity weekly. If required, would it only be required to provide readings during work hours? B) Are masons required to have red seal certification or is approx. 10 years' experience adequate? C) Can you please clarify the meaning of 'Examination Work'? <p>i.e. (see page 4 of 01 11 00) - Examination work is permitted between after Labour Day weekend to Thanksgiving Weekend on Tuesdays and</p>



	<p>Wednesday only, with no closure/permanent work items on site to take place during examination work.</p> <p>D) See spec section 04 03 07 part 1.4.4 action and informational submittals. Are all of these items necessary/required or will a submittal consisting of product data and material characteristic/properties report if available suffice?</p> <p>E) See spec section 04 03 07 part 1.4.5 action and informational submittals. Are record drawings of stone repairs and repointing required upon completion per spec?</p> <p>F) See spec section 04 03 08 part 1.7. Is the vicat along with the other listed tests required for every batch of mortar? Can you confirm this cost is covered by client/allowance?</p>
<p>1.8 Answer</p>	<p>A) Comply with Section 04 03 08, Item 1.9.3.</p> <p>B) For Qualifications, comply with the requirements of Section 04 03 08, Paragraph 1.7 and 04 03 41, Paragraph 1.6.</p> <p>C) Examination Work (and “Approved other activities”) may include site activities that can be commenced and completed between Tuesday Morning and end of business Wednesday. Commencement and completion shall include all mobilization, demobilization and cleaning. No stored materials, equipment, staging, hoarding, or other disruption shall be present on site or perceptible outside the Tuesday-Wednesday window. Full site shall be restored to a clean and safe condition prior to end of day Wednesday with no trace of construction activities.</p> <p>D) Submittals are required in accordance with section 04 03 07, Part 1.4.4.</p> <p>E) Yes.</p> <p>F) Preconstruction testing and testing during site work shall be as per Section 04 03 08, Part 1.7. Frequency of testing during site work shall be as per referenced standards. As a minimum, conduct site testing on first three consecutive mortar batches. Payment Procedures for Testing Laboratory are in accordance with Section 01 29 83.</p>

No change to the bid closing date.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

**Signed copy of this amendment should accompany each tender. If your tender has already been submitted please sign and fax the amendment along with any revisions to tender price, to this office before the close of Tender.
Fax: 418 649-6971.**