



Royal Canadian Mounted Police
Gendarmerie royale du Canada

RETURN BIDS TO :

RETOURNER LES SOUMISSIONS :

Bid Receiving Unit / Grope de la réception des soumissions

Procurement & Contracting Services / Services d'acquisitions et des marchés.

VISITOR'S CENTRE
Royal Canadian Mounted Police
73 Leikin Drive, Ottawa, Ontario

Telephone No.

no de téléphone: (613) 843-3798

AMENDMENT TO THE INVITATION TO TENDER

Royal Canadian Mounted Police

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefore.

MODIFICATION À L'APPEL D'OFFRES

Gendarmerie royale du Canada

Nous offrons par la présente de vendre à Sa Majesté I Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments – Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Telephone No. – No de téléphone:

()

Facsimile No. – No de télécopieur:

()

Title-Sujet Construction – Site Clearing and Parking Lot Construction		
Solicitation No. – No. de l'invitation 201805065	Amend. – Modif. No. : 5	Date Jan. 15th, 2018 / 15 janvier, 2018
Client Reference No. - No. de Référence du Client 201805065		
GETS Reference No. – No de Référence du SEAG PW-17-00809889		
Solicitation Closes – L'invitation prend fin at – à 2:00 P.M. EST on – January 18th, 2018., 18 janvier, 2018		
F.O.B. - F.A.B. Destination		
Address Enquiries to: - Adresser toute questions à : Jordan McKenna		
Telephone No. - No de téléphone 613-843-5518	Fax: 613-825-0082	
Destination of Goods - Destinations des biens: See Herein		
Instructions : See Herein / Voir aux présentes		
Delivery Required – Livraison exigée: See Herein		
Name and Title of person authorized to sign on behalf of Vendor/Firm. Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		

Amendment No. 5

Construction – Site Clearing and Parking Lot Construction
SOLICITATION NO. : 201805065

Date: January 15th, 2018

Amendment #5 is being issued in order to amend the tender, and respond to Questions PART 2 as follows:

THE FOLLOWING CHANGES IN THE TENDER DOCUMENTS ARE EFFECTIVE IMMEDIATELY.

- 1) The closing date of this tender is extended to January 18th, 2018, at 2:00 EST

Questions and Answer Part 2

Q1) Is an ACAD drawing available to share for the parking lot grading showing both existing grades, proposed grades and test pit locations?

A1) ACAD drawing will not be released to bidders during tender. Reference C100 and C101 for requested information and bid as per contract documents.

Q2) Is there a preferred limit for site protection fencing or is it only required at connections to the existing roads?

A2) Fence the entire site to keep the wildlife out of the construction area, and construction personnel and equipment out of wildlife habitat. Fence the perimeter identified as “extent of site” on drawings.

Q3) Can the existing topsoil be stripped, stockpiled and re-used?

A3) Import new topsoil to site. Existing topsoil is not of sufficient quality to be stripped, stockpile and re-used and must be removed.

Q4) Are there grades available for the proposed storm structures?

A4) Grades for the proposed storm structures are identified on drawing C101. Bid as per contract documents.

Q5) Can excess fill and rock remain on the RCMP property?

A5) No, all excess fill and rock is to be removed from site. The only exception is the boulders that are to be stockpiled (reference AD101 note 28 and L100 note 20).

- Q6) Drawing E1 detail 7/E1, could someone look into this detail as visually with the rock I do not think this will be done , also the depth of the footing is 2440mm but at the bottom right it states the footing is 600 x 600 x 600mm, could it be clarified please.
- A6) Detail 7/E1 indicates that it will be the responsibility of the contractor to provide sealed engineered shop drawings, as such detail 7/E1 shows general intent only. The expectation is that a variation of this detail will be implemented based on the design the contractors engineer provides.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

END