



Procurement Hub – Ottawa Office,
Station 9W072, 9th Floor,
200 Kent Street,
Ottawa, Ontario K1A 0E6

ADDENDUM NO. 2

Subject: Invitation to Tender No. FP802-170311
Accessibility Upgrades to the Torrent River Fish-way Observation Chamber

Dear Sir/Madam:

Further to the above-mentioned Request for Proposal, this Addendum (#2) is to advise potential bidders of the question(s) received during this tender call to date. Both the question(s) and the response(s) are indicated in the attached Annex A

All other terms and conditions remain unchanged.

Tenderers are to acknowledge this Addendum by signing in the space provided below and enclosing a copy of this document with their tender submission.

Yours truly,

(Original signed by)

Beverly Shawana
Senior Contracting Officer,
Financial & Materials Management Operations

RECEIPT ACKNOWLEDGED

Name of Company

Signature _____

Canada

Annex A

Questions:

We will be bidding the above subject project as a General Contractor.

Could you please clarify the requirements for a Company Safety Officer for this project. Currently the spec reads that the Contractor must provide a "Full Time Company Safety Officer". Normally on projects of this size our Company Safety Officer would make periodic visits but would not be on site full time. Daily on site enforcement of our company safety program would be the responsibility of the site superintendent.

Can you please clarify if this is required?

Also, In the General Instructions – 1.6 Winter Conditions – It specifies that Winter Condition Requirements – "Snow Clearing". Is this referring to the work area at the site only? (i.e will the access road and parking lot to the site be kept cleared by the Owner?)

Answers:

See attached Document #1 and Document #2

Document #1

The Tender Documents shall be amended and the new information issued as part of this Addendum will become part of the Contract Documents as follows:

The attention of the bidders is drawn to the following facts in relation to the above captioned project:

SPECIFICATION

1. Section 01 00 50 - General Instructions
 - .1 Add the following to 1.6.1, under Snow Clearing:

The access road from highway #430 to the Site is not cleared of snow in winter.
The Contractor is responsible for snow clearing for construction purposes.
See attached Google Earth screen shot photo.

2. Section 01 32 9.06 - Health and Safety Requirements
 - .1 Delete editorial note for article 1.6.1 requiring full-time dedicated Contractor's Safety Officer.
Contractor's Safety Officer is required to visit the site to assess the hazards and prepare the Site Specific Safety Plan prior to work start-up and visit weekly to ensure the work process is in compliance. Daily enforcement of the Safety Plan will be the responsibility of the Contractor's Project Site Superintendent.

END OF ADDENDUM