



REVISED SINGLE LINE DIAGRAM
SCALE: NOT TO SCALE

- NOTES:**
1. REVISE LOCATION OF MANUAL TRANSFER SWITCH TO BE INSIDE MAIN DISTRIBUTION KIOSK.
 - 1.1. COORDINATE WITH VALID MANUFACTURING FOR EXACT INSTALLATION LOCATION AND REQUIREMENTS.
 - 1.2. MODIFY EXISTING BUILDING DISTRIBUTION FEEDER TO SUIT TRANSFER SWITCH LOCATION.
 - 1.3. PROVIDE ALL NECESSARY MOUNTING HARDWARE, CONDUCTORS, SHIELDING AND OTHER ANCILLARY EQUIPMENT AS REQUIRED FOR A COMPLETE AND OPERATIONAL SYSTEM.

- F/A PANEL
- POWER FILTER
- TRANSFORMER 600V, PUMP IV, RIVER
- PANEL A
- PANEL A1
- PANEL B
- PANEL C
- PANEL D
- PANEL H
- PANEL J
- PANEL K
- PANEL L
- PANEL M
- PANEL N
- PANEL P
- PANEL Q
- PANEL R

Rev	Date	Description	Drawn	Design	App'd
1	2018-01-16	ISSUED FOR ADDENDUM	TI	TI	LL

THIS DRAWING AND DESIGN IS THE PROPERTY OF McELHANNEY CONSULTING SERVICES LTD. (McELHANNEY) AND SHALL NOT BE USED, REUSED OR REPRODUCED WITHOUT THE CONSENT OF McELHANNEY. McELHANNEY WILL NOT BE HELD RESPONSIBLE FOR THE IMPROPER OR UNAUTHORIZED USE OF THIS DRAWING AND DESIGN.

THIS DRAWING AND DESIGN HAS BEEN PREPARED FOR THE CLIENT IDENTIFIED, TO MEET THE STANDARDS AND REQUIREMENTS OF THE APPLICABLE PUBLIC AGENCIES AT THE TIME OF PREPARATION. McELHANNEY, ITS EMPLOYEES, SUBCONSULTANTS AND AGENTS WILL NOT BE LIABLE FOR ANY LOSSES OR OTHER CONSEQUENCES RESULTING FROM THE USE OR RELIANCE UPON, OR ANY CHANGES MADE TO, THIS DRAWING, BY ANY THIRD PARTY, INCLUDING CONTRACTORS, SUPPLIERS, CONSULTANTS AND STAKEHOLDERS, OR THEIR EMPLOYEES OR AGENTS, WITHOUT McELHANNEY'S PRIOR WRITTEN CONSENT.

Issue Date	2018-01-16	Issued For	ADDENDUM
Drawn By	TI	Checked By	LL
ORIGINAL DWG SIZE: ANSI B (11" x 17")			


McElhanney
 McElhanney Resource Services Ltd.

Suite 12
 556 North Nechako Road
 Prince George BC
 Canada V2K 1A1
 Tel 250 561 2229

PARKS CANADA AGENCY
 BANFF, AB
BANFF ADMINISTRATION BUILDING
PARKING LOT REHABILITATION
REVISED SINGLE LINE
 BANFF TOWN CENTRE
 BANFF NATIONAL PARK, BANFF AB

Drawing No.	E-SK-01
Project Number	2531-13503-00
Rev.	1