

Part 1 General

1.1 NOT USED

- .1 Not used.

Part 2 Products

2.1 MATERIALS

- .1 All fixture and branch wiring joints in junction and outlet boxes shall be made with a CSA certified pressure type connector rated at 600 volts maximum. Connector body shall consist of a cone shaped coil spring insert, insulated with a colour coded flame retardant, thermoplastic shell, which shall be knurled for easy grip.
- .2 Lugs, terminals, and screws used for termination of conductors, shall be suitable for type of conductor used.
- .3 Wire connectors to CSA C22.2 No. 65-93.

Part 3 Execution

3.1 INSTALLATION

- .1 Remove insulation carefully from ends of conductors and:
 - .1 Install mechanical pressure type connectors and tighten as recommended by Manufacturer as specified in CSA C22.2 No. 65-93. Installation shall meet secureness tests.

END OF SECTION 26 05 20