

Part 1 General

1.1 NOT USED

- .1 Not used.

Part 2 Products

2.1 SUPPORT CHANNELS

- .1 Support channels, length as indicated, U-shape, size 41 mm x 41 mm, 2.5 mm thick, surface mounted or suspended.

2.2 FASTENERS

- .1 Acceptable Fasteners:
 - Hilti "HKD"
 - Hilti "kwik" bolts
 - beam clamps

Part 3 Execution

3.1 INSTALLATION

- .1 Lead anchors and plastic anchors will not be permitted.
- .2 Secure equipment to poured concrete with expandable inserts.
- .3 Secure equipment to hollow masonry walls or suspended ceilings with toggle bolts.
- .4 Support equipment, conduit or cables using clips, spring-loaded bolts, cable clamps designed as accessories to basic channel members.
- .5 Fasten conduit or cables to building construction or support system using straps.
 - .1 One-hole steel straps to secure surface conduits and cables 50 mm and smaller.
 - .2 Two-hole steel straps for conduits and cables larger than 50 mm.
 - .3 Clamps to secure conduit to exposed steel work.
- .6 Suspended support systems:
 - .1 Support individual cable or conduit runs with 6 mm diameter threaded rods and spring clips.
 - .2 Support 2 or more cables or conduits on channels supported by 6 mm diameter threaded rod hangers where direct fastening to building construction is impractical.
- .7 Provide metal brackets, frames, hangers, clamps and related types of support structures where indicated or as required to support conduit and cable runs.

- .8 Provide adequate support for raceways and cables dropped vertically to equipment where there is no wall support.
- .9 Do not use wire lashing, tie wraps, or perforated strap to support or secure raceways or cables.
- .10 Do not use supports or equipment installed for other trades for conduit or cable support except with permission of other trade and approval of the electrical representative.
- .11 Install fastenings and supports as required for each type of equipment cables and conduits, and to Manufacturer's installation recommendations.
- .12 Do not install screws through upper flute portion of metal roof deck when roof membrane is located directly on top of metal roof deck. Confirm with general contractor.

END OF SECTION 26 05 29