

**Part 1 General**

**1.1 REFERENCES**

- .1 American Society of Heating, Refrigeration and Air-Conditioning Engineers (ASHRAE)
  - .1 ASHRAE 90.1 2016, Energy Standard for Buildings Except Low-Rise Residential Buildings (IESNA cosponsored; ANSI approved; Continuous Maintenance Standard).
- .2 Electrical Equipment Manufacturers' Association Council (EEMAC)
- .3 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
  - .1 Material Safety Data Sheets (MSDS).

**1.2 SUBMITTALS**

- .1 Submittals: in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Product Data:
  - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
    - .1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.
- .3 Quality Control: in accordance with Section 01 45 00 - Quality Control.
  - .1 Instructions: submit manufacturer's installation instructions.
- .4 Closeout Submittals
  - .1 Provide maintenance data for motors, drives and guards for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

**1.3 DELIVERY, STORAGE, AND HANDLING**

- .1 Packing, shipping, handling and unloading:
  - .1 Deliver, store and handle in accordance with Section 01 61 00 – Common Product Requirements.
  - .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.

**Part 2 Products**

**2.1 GENERAL**

- .1 Motors: high efficiency, in accordance with ASHRAE 90.1.

## 2.2 MOTORS

- .1 Provide motors for mechanical equipment as specified.
- .2 Motors under 560 W (3/4 HP) : speed as indicated, continuous duty, built-in overload protection, resilient mount, single phase, 120 V, unless otherwise specified or indicated.
- .3 Motors 560 w (3/4 HP) and larger: EEMAC Class B, squirrel cage induction, speed as indicated, continuous duty, drip proof, ball bearing, maximum temperature rise 40 degrees C, 3 phase, 575 V, unless otherwise indicated.

## 2.3 TEMPORARY MOTORS

- .1 If delivery of specified motor will delay completion or commissioning work, install motor approved by Departmental Representative for temporary use. Work will only be accepted when specified motor is installed.

## 2.4 BELT DRIVES

- .1 Fit reinforced belts in sheave matched to drive. Multiple belts to be matched sets.
- .2 Use cast iron or steel sheaves secured to shafts with removable keys unless otherwise indicated.
- .3 For motors under 7.5 kW 10 HP: standard adjustable pitch drive sheaves, having plus or minus 10% range. Use mid-position of range for specified r/min.
- .4 For motors 7.5 kW 10 HP and over: sheave with split tapered bushing and keyway having fixed pitch unless specifically required for item concerned. Provide sheave of correct size to suit balancing.
- .5 Correct size of sheave determined during commissioning.
- .6 Minimum drive rating: 1.5 times nameplate rating on motor. Keep overhung loads within manufacturer's design requirements on prime mover shafts.
- .7 Motor slide rail adjustment plates to allow for centre line adjustment.
- .8 Supply one set of spare belts for each set installed in accordance with Section 01 78 00 - Closeout Submittals.

## 2.5 DRIVE GUARDS

- .1 Provide guards for unprotected drives.
- .2 Guards for belt drives;
  - .1 Expanded metal screen welded to steel frame.
  - .2 Minimum 1.2 mm thick sheet metal tops and bottoms.

- .3 38 mm dia. holes on both shaft centres for insertion of tachometer.
- .4 Removable for servicing.
- .3 Provide means to permit lubrication and use of test instruments with guards in place.
- .4 Install belt guards to allow movement of motors for adjusting belt tension.-
- .5 Guard for flexible coupling:
  - .1 "U" shaped, minimum 1.6 mm thick galvanized mild steel.
  - .2 Securely fasten in place.
  - .3 Removable for servicing.
- .6 Unprotected fan inlets or outlets:
  - .1 Wire or expanded metal screen, galvanized, 19 mm mesh.
  - .2 Net free area of guard: not less than 80% of fan openings.
  - .3 Securely fasten in place.
  - .4 Removable for servicing.

### **Part 3 Execution**

#### **3.1 MANUFACTURER'S INSTRUCTIONS**

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

#### **3.2 INSTALLATION**

- .1 Fasten securely in place.
- .2 Make removable for servicing, easily returned into, and positively in position.

#### **3.3 FIELD QUALITY CONTROL**

- .1 Manufacturer's Field Services:
  - .1 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.
  - .2 Schedule site visits to review Work as required.

#### **3.4 CLEANING**

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.

- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

**END OF SECTION 23 05 13**