



**Ritenburg &
Associates Ltd.**
Consulting Electrical Engineers

Addendum No. 1

TO: RCMP

#200-2222 Albert Street

Regina, SK

S4P 2V2

P: (306) 569-1303

F: (306) 569-1307

E: ral@ritenburg.com

I: www.ritenburg.com

PROJECT: Electrical Upgrades for Drill Hall Parking Lot

FROM: Ritenburg & Associates Ltd.

RAL File #: 12838

DATE: January 19, 2018

PAGES: 1

ADDENDUM NO. 1

ALL BIDDERS SHALL READ THE ENTIRE ADDENDUM AND TAKE INTO ACCOUNT ITEMS AFFECTING THEIR RESPECTIVE RESPONSIBILITIES.

This Addendum forms part of the Bid/Tender documents issued for the above project and no consideration will be entertained for extras to contract due to failure of any bidder to become thoroughly familiar with the Addendum.

A-1.0 Reference Drawing E2

1. Revise feeder cable size for Panel 'B' to 4C #250MCM TECK90 + #4 AWG integral copper bond.
2. Revise feeder cable size for Panel 'E' to 4C #250MCM TECK90 + #4 AWG integral copper bond.

END OF ADDENDUM