



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Parks Canada Agency
1869 Upper Water Street, Suite AH 201
Halifax, Nova Scotia B3J 1S9

Bid Fax: 902-426-1775

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
1869 Upper Water Street, Suite AH 201
Halifax, Nova Scotia B3J 1S9

Title-Sujet Corney Brook Campground, Renewable Energy System and Water Disinfection System		
Solicitation No. - No. de l'invitation 5P201-17-5105/B		Amendment No.:/N° de modification de l'invitation 004
Client Ref. No. - No. de réf du client.		Date: January 22, 2018
GETS Reference No. - No de reference de SEAG PW-17-00809194		
Solicitation Closes:		
at - à 02:00 PM	on - le January 25, 2018	Time Zone - Fuseau horaire AST - HNA
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Tanya Allen – tanya.allen@pc.gc.ca		
Telephone No. - No de téléphone (902) 426-7543		Fax No. - No de FAX: (902) 426-1775
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein – Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)
À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)

Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur	
Address – Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de téléphone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

AMENDMENT 004

1.0 Questions/Clarifications

Q9 We need to know from consultants what the load of the uv system is as the solar system needs to be designed around total load of building. The solar system that is specified now is not big enough to handle all the load they have in the building. We need to know from engineers total load of building.

A9 *The total design load of the water treatment system is 5,000 watts, 20 amps, 120/240 v. The solar panel system is to provide power to the treatment system only. As such, the hot water heater and space heater are to be deleted from the contract.*

Q10 Distribution: No breaker Schedule for new Panel (to be determined by Contractor).

A10 *No panel schedule is provided as this is to be provided by the contactor responsible for the construction of the addition. The addition or the new panel does not form part of this contract. Once the panel schedule is confirmed, this information will be made available to the successful contractor under this contract.*

Q11

Q11a Unit Heater: Can't tell if its existing or not.

A11a *The unit heater is not existing. As per response above, bidders should note that this item is being removed from the scope under this contract.*

Q11b If not, according to attached spec they may require explosion proof heater and explosion proof stat?

A11b *Heater is not required. Explosion proof would not have been required based on classification.*

Q11c Also, no indication on KW required. Usually 10W per SQ FT roughly in a well insulated room with most heaters, pending what else in running in that same room.

A11c *Heater is no longer required.*

Q12 Lights: Equipment list says 3 LED lights, one per room, but no luminaire schedule. Just a vague spec on Div 26 but if the heater is required explosion-proof the light might need to be as well.

A12 *Explosion proof lighting is not required. Lighting is not included in this contract.*

ALL OTHER TERMS AND CONDITONS REMAIN THE SAME.
