



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: 1-866-246-6893

AMENDMENT / MODIFICATION

002

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada
 Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
 Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 – 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Mistaya Canyon Parking Lot Reconstruction – Banff National Park		
Solicitation No. - No. de l'invitation 5P420-17-5440/A	Date: January 24, 2018	
GETS Reference No. – No de reference de SEAG PW-18-00811014	Amendment No. - N° de la modif. 906	
Solicitation Closes:		
at – á 02:00 PM	on – le February 6, 2018	Time Zone - Fuseau horaire MST - HNR
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Rebecca Chen		
Telephone No. - No de téléphone (403) 292-8509	Fax No. – No de FAX: 1-866-246-6893	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein – Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone:	_____
Facsimile No. - N° de télécopieur:	_____
Signature	Date

Amendment 02

This amendment is being raised to extend the solicitation closing date, add the geotechnical report to the tender documents, distribute the sign in sheet, and questions and answers from the optional site visit.

A) BID CLOSING DATE

The closing date for tender 5P420-17-5440/A is extended from January 30, 2018 to **February 6, 2018 at 2:00PM Mountain Standard Time (MST)**.

B) TENDER DOCUMENTS

Add the following document: DSP 2 (includes geotechnical report)

C) SITE VISIT ATTENDEES

	Vendor	Name
1	JACTCO	Jason Deuchar
2	LBCO Contracting Ltd	Fernando Nogueira
3	Slimdor Contracting Ltd.	Derek Goett
4	Nissa Enterprises	Dominic Aollo
5	BECL	Sam Allen
6	Wilco Contracting	Gerett Brink
7	Rubydale Asphalt Works	Cole Paladeau
8	Dawson Construction	Luc Thibault
9	Year Round Landscaping	Brad Turner

Contact information for the attendees are available upon request and approval from the vendors.

D) QUESTIONS & ANSWERS

Q1 – Is course of construction insurance required (builder's risk insurance)?

A1 – No, see Appendix D

Q2 – Can you clarify that survey layout and topo for quantity verification is on the Contractor?

A2 – The contractor will be responsible for the survey layout and topo for quantities, this will need to be submitted to Parks Canada for verification before payment can be approved.

Q3 – Please clarify if third compaction testing is the responsibility of the Contractor.

A3 – The Contractor will be responsible for all Quality Control testing Section 01 45 00. Required tests are covered in the technical specifications. The contractor must submit all reports Parks Canada Agency before associated payment can be released.

Q4 – Can you please clarify how much it will cost to pull water from a park source for construction purposes? Is this free because we are working for parks?

A4 – There is no fee to withdraw water from within the National Park, a permit will need to be approved. It is the responsibility of the contractor to apply for the proper permits, approval of this permit is not guaranteed. The contractor should research alternative options. Parks Canada will not be responsible for any related costs or time delays associated to this. Please note there is also the potential to acquire water from the Lake Louise water treatment plant at no costs.

Q5 – Can you provide a reference for the expected temporary traffic control? Are digital message boards expected?

A5 – The Contractor is responsible to follow Alberta's Traffic accommodation in a work zone, 2008. And

provide Parks Canada Agency with a traffic management plan before the contractor can mobilize.

Q6 – What type of site security is expected?

A6 – Site security is the responsibility of the contractor to make sure the site is safe to the public and wildlife.

Q7 – Can you please provide a copy of the Geotechnical report? Is rock expected?

A7 – The geotechnical report will be provided.

Q8 – No existing utilities are shown on the plan. Are any expected? Have locates been performed?

A8 – No utilities are expected. It is the responsibility of the contractor to get locates before they dig.

Q9 – What is expected of ameliorated topsoil? Is harrowing sufficient? Or is screened topsoil expected?

A9 – It is preferred that the contractor salvage and reuse the existing topsoil for the landscape areas. If more topsoil is needed then the contractor must follow the BIA and all National Park Guidelines. All imported topsoil must be certified weed free. This certification must be submitted to the Departmental Representative and approved before any imported soil may enter the National Park.

Q10 – What is the expected thickness of the existing asphalt?

A10 – This information is not available.

Q11 – Can please clarify how payment for undercuts (removal of unsuitable subgrade and replacement with granular sub-base) will be handled?

A11 – Removal of unsuitable material will be paid under Item No. 2.5 and work associated with the replacement of sub-base under Item No. 2.4.

Q12.A – Can you please clarify the Bid Item 2.4 and 2.5. The BIA indicates that 2,950 m³ will need to be disposed of offsite however only 1,930 m³ are identified in Item 2.5.

A12.A – The BIA was completed in 2016, the design and drawings have been adjusted since. Please use Bid Form. The Contractor is responsible for verifying all quantities and notifying the Departmental Representative of any omissions. The Contractor is to verify all dimensions and report any discrepancies to the Departmental Representative.

Q12.B – Is item 2.4 for onsite cut and fill? Is item 2.5 for offsite excess material?

A12.B – Removal of unsuitable material will be paid under Item No. 2.5 and work associated with the replacement of sub-base under Item No. 2.4.

Q13 – Please clarify that either Type 1 or Type 2 Mix can be used on this project.

A13 – Type 1 is to be used.

Q14 – Are we required to mill in a joint in order to tie-in to HWY 93?

A14 – Yes, the entry and exit will require (refer Drawing C-101, Drawing C-105 Section A and D C-105). This work is incidental to Items No. 2.6 and 2.9.

Q15 – Is level coursing of the existing parking required? If so, how will it be paid for?

A15 – Level coursing may be required, this work will be incidental to Item No. 2.9.

Q16 – Is it acceptable to pave the new parking lot addition in one lift (100 mm thick)?

A16 – Paving in one lift is not acceptable

Q17 – Please clarify whether temporary line painting or inlaid thermoplastic is required.

A17 – Line painting as per Specification 32 17 23 Pavement Markings.

Q18 – Please clarify whether Class 1M or Class 1 rip rap is required.

A18 – Alberta Transportation Riprap Class 1M as per Specification Section 31 37 00 Rip Rap, refer also to Hand Laid Riprap detail on C-401.

Q19 – What is the expectation for tree protection? Is snow fence sufficient?

A19 – All tree removal to be approved by the Departmental Representative prior to starting work as part of the Environmental Protection Plan (EPP) prepared by the Contractor. Trees identified as existing-to-remain within or adjacent to the limit of Work require a Tree Protection Zone (TPZ) during construction by means of a protective barrier or fencing by the contractor. Fencing may be standard snow fence 1200 min. height or equivalent to approval of Departmental Representative.

Q20 – Regarding material delivery and trucking in the parkway, will a permit be needed or will that be taken care of by Parks Canada?

A20 – The contractor will be responsible to apply for a restricted activity permit (RAP) to haul anything over 4550kg GVW on the Icefields Parkway (93N Hwy).

Q21 – Is there a gravel pit in the area capable of supplying the required materials?

A21 – It is the responsibility of the contractor to source the required material.

Q22 – Can snow from the site be removed and placed in the adjacent ditch?

A22 – No, Any snow removed from the landscaping areas must be collected in a pile with sediment fences surrounding the pile approved by Parks Canada to prevent sediment run off.

Q23 – How early can the ground survey be done?

A23 – The contractor may commence the ground survey after the contract has been awarded.

Q24 – When can the tree clearing commence?

A24 – Trees can be cut any time after the contract is awarded and all permits are in place. Please note that the Parking lot must stay open to all visitors until May 1st 2018. The Contractor will be responsible to keep the parking lot safe to all visitors and wildlife.

Q25 – Can the contractor set up a camp within the national park?

A25 – No, Parks Canada will provide 6 Spots at the Lake Louise Over flow parking lot along the Trans-Canada Highway (TCH-1) from May 01, 2018 to May 31, 2018. Then 6 spots at Rampart Campground along the Icefields Parkway (93N Hwy) from May 31, 2018 till June 30, 2018. The contractor will be responsible to apply for a permit to camp at these locations before approval is granted. At both camp sites there are no services, contractors are responsible for their own water and wastewater needs. Dumping is available at the Lake Louise Campground.

Q26 – Inquiring regarding any Quality Control Materials Testing and Inspection during construction for the above noted project would be required by Parks Canada.

A26 – Section 01 45 00 Quality Control covers the inspection procedures. Required tests are covered in technical specifications.

All other terms and conditions remain unchanged.