

PART 1 - GENERAL

1.1 REFERENCE STANDARDS

- .1 CSA Group
 - .1 CSA C22.2 No.46 (Latest Edition), Electric Air-Heaters.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for duct heaters and include product characteristics, performance criteria, physical size, finish and limitations.
 - .2 Submit product data and include:
 - .1 Element support details.
 - .2 Heater: total kW rating, voltage, phase.
 - .3 Number of stages.
 - .4 Rating of stage: rating, voltage, phase.
 - .5 Heater element watt/density and maximum sheath temperature.
 - .6 Maximum discharge temperature.
 - .7 Unit support.
 - .8 Clearance from combustible materials.
 - .9 Internal components wiring diagrams.
 - .10 Minimum operating airflow.
 - .11 Pressure drop operating minimum airflow.

1.3 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials off ground indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect duct heaters from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.

PART 2 - PRODUCTS

2.1 DUCT HEATERS

- .1 Duct heaters: insert type.
- .2 Elements:
 - .1 Helical coils of nickel chrome alloy resistance wire.
 - .2 Finned tubular.
 - .3 Incoloy sheathed.
- .3 Staging:
 - .1 Staged heaters: balanced line current at each stage.
 - .2 Each stage: uniform face distribution.
- .4 Maximum temperature at discharge: 35 degrees Celsius.
- .5 Controls:
 - .1 Factory mounted and wired in control box. Use terminal blocks for power and control wiring to thermostat and sail switch.
 - .2 Controls mounted in a CSA Type NEMA 1 enclosure and to include:
 - .1 Magnetic contactors.
 - .2 Control transformers.
 - .3 SCR and/or Step controller.
 - .3 Where controls are mounted in heater, exercise care in mounting contactors to minimize switching noise transmission through ductwork.
 - .4 High temperature cutout manual and automatic reset, and air proving switch.
- .6 Electrical:
 - .1 Duct heater rating:
 - .1 15 kW.
 - .2 208 voltage.
 - .3 3 phase.
 - .2 Stages:
 - .1 3 number.
 - .2 2 stages of step control + 1 stage SCR.
 - .3 5 kW.
 - .4 208 voltage.
 - .5 3 phase.
- .7 Main isolation disconnect switch.

PART 3 - EXECUTION

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for duct heaters installation in accordance with manufacturer's written instructions.

- .1 Visually inspect substrate in presence of Departmental Representative.
- .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
- .3 Proceed with installation only after unacceptable conditions have been remedied [and after receipt of written approval to proceed from Departmental Representative.

3.2 INSTALLATION

- .1 Make power and control connections to CSA C22.2 No.46.

3.3 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 01 91 13 - General Commissioning (Cx) Requirements and Section 26 05 00 - Common Work Results for Electrical.
- .2 Perform tests in presence of Departmental Representative.
 - .1 Provide test report and include copy with Operations and Maintenance Manuals.

3.4 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.

END OF SECTION