

EXISTING DEVICES LEGEND:

OUTLETS:

- EXISTING DUPLEX RECEPTACLE, 15 A, 120 V MOUNTED LOW ON WALL.
- EXISTING DUPLEX RECEPTACLE, 15 A, 120 V MOUNTED AT COUNTER HEIGHT OR UP NEAR CEILING WHEN USED FOR EMERGENCY LIGHT.
- EXISTING SINGLE RECEPTACLE, 15 A, 120 V MOUNTED UP NEAR CEILING FOR EMERGENCY LIGHT.
- EXISTING SINGLE RECEPTACLE, 15A, 120V, MOUNTED AT COUNTER HEIGHT.

LIGHTS:

- EXISTING RECESSED 2' x 4' LIGHT FIXTURE.
- EXISTING RECESSED 2' x 2' LIGHT FIXTURE.
- EXISTING SURFACE 1' x 4' LIGHT FIXTURE.
- EXISTING SURFACE 4' STRIP LIGHT FIXTURE.
- EXISTING RECESSED POT LIGHT.
- EXISTING EMERGENCY LIGHTING BATTERY UNIT WITH TWO HEADS.
- EXISTING EMERGENCY LIGHTING REMOTE HEAD.
- EXISTING EXIT SIGN.
- EXISTING BEACON LIGHT.

HEATING:

- EXISTING WALL MOUNTED CONVECTION HEATER.
- EXISTING WALL MOUNTED FAN FORCED HEATER.
- EXISTING CEILING MOUNTED FAN FORCED HEATER.

SWITCHING:

- EXISTING LIGHT SWITCH.

SECURITY:

- EXISTING MOTION SENSOR.
- EXISTING KEYPAD.

COMMUNICATION:

- EXISTING PA SPEAKER.
- EXISTING DATA/TEL. OUTLET.
- EXISTING INTERCOM BUZZER.

CONTROLS:

- EXISTING DISCONNECT SWITCH.
- EXISTING STARTER.

FIRE ALARM:

- EXISTING SMOKE DETECTOR TO BE DISCONNECTED AND REINSTATED ONCE NEW CEILING IS INSTALLED.

DEMOLITION NOTES:

- REMOVE JUNCTION BOX AND ANY ASSOCIATED CONDUIT AND WIRING BACK TO SOURCE.
- REMOVE TWO (2) CONDUITS RUN DOWN ON WALL AND ANY ASSOCIATED WIRING BACK TO SOURCE.
- RELOCATE EMERGENCY BATTERY PACK AND RECEPTACLES AND BELL TO NEAREST AVAILABLE WALL SPACE. PROVIDE ALL NECESSARY JUNCTION BOXES, WIRING, CONDUIT AND CONNECTIONS. SEE DWG E2 FOR EXACT LOCATIONS.
- REMOVE KEYPAD, CONDUIT AND CONDUCTORS BACK TO SOURCE.
- EXISTING WALL FAN FORCED HEATER TO BE RELOCATED. SEE DWG E3 FOR EXACT LOCATION.
- ELECTRICAL FOR EXISTING DISCONNECTS AND HUMIDIFIERS TO BE DISCONNECTED. REMOVE CONDUIT AND CONDUCTORS BACK TO SOURCE.
- ELECTRICAL FOR EXISTING CEILING MOUNTED BLOWER CONVECTOR TO BE DISCONNECTED. REMOVE CONDUIT AND CONDUCTORS BACK TO SOURCE.
- ELECTRICAL FOR CEILING EXHAUST FAN TO BE DISCONNECT. REMOVE CONDUIT AND CONDUCTORS BACK TO SOURCE.
- ELECTRICAL FOR EXISTING OUTDOOR CONDENSING UNIT TO BE DISCONNECTED. REMOVE CONDUIT AND CONDUCTORS BACK TO SOURCE.
- ELECTRICAL FOR EXISTING INDOOR EVAPORATOR UNIT TO BE DISCONNECTED. REMOVE CONDUIT AND CONDUCTORS BACK TO SOURCE.
- ELECTRICAL FOR EXISTING ROOF MOUNTED EXHAUST FAN TO BE DISCONNECTED. REMOVE CONDUIT AND CONDUCTORS BACK TO SOURCE.
- ELECTRICAL FOR EXISTING DUCT HEATER IN ATTIC SPACE TO BE DISCONNECT. REMOVE CONDUIT AND CONDUCTORS BACK TO SOURCE.
- ELECTRICAL FOR EXISTING A/C UNITS IN ATTIC SPACE TO BE DISCONNECTED. REMOVE CONDUIT AND CONDUCTORS BACK TO SOURCE.
- ELECTRICAL FOR EXISTING A/C UNIT MOUNTED ON ROOF TO BE DISCONNECTED. REMOVE CONDUIT AND CONDUCTORS BACK TO SOURCE.
- EXISTING DISCONNECT UPS PANEL TO BE REMOVED AND TURNED OVER TO OWNER.
- RELOCATE BELL AND STROBE TO NEAREST AVAILABLE WALL SPACE. PROVIDE ALL NECESSARY JUNCTION BOXES, WIRING, CONDUIT AND CONNECTIONS. SEE DWG E3 FOR EXACT LOCATION.
- PULL STATION TO BE RELOCATED TO EXTERIOR DOOR. SEE DWG E3 FOR LOCATION.
- ELECTRICAL FOR EXISTING BY PASS BOX DISCONNECTED. REMOVE CONDUIT AND CONDUCTORS BACK TO SOURCE.
- EXISTING DOOR BUZZER TO BE DISCONNECTED.
- EXISTING CIRCULATOR PUMPS TO BE DISCONNECTED AND RECONNECTED TO NEW.
- STOVE TOP, WALL OVEN AND RANGE HOOD TO BE DISCONNECTED. RE USE EXISTING WIRE TO CONNECT TO NEW. SEE DWG E3 FOR LOCATIONS.
- EXISTING SMOKE DETECTORS TO BE DISCONNECTED AND RECONNECTED ONCE NEW CEILINGS ARE INSTALLED. RE USE EXISTING WIRE.


GENERAL NOTES:

- ALL ELECTRICAL DEVICES INDICATED ON DEMOLITION FLOOR PLAN ARE TO BE REMOVED INCLUDING ANY ASSOCIATED CONDUIT AND WIRING BACK TO NEAREST SOURCE. REFER TO DRAWING NOTES FOR EXISTING DEVICES TO BE RELOCATED OR REPLACED UNLESS OTHERWISE NOTED.
- EXISTING LAYOUT IS BASED ON INFORMATION OBTAINED FROM SITE VISIT AND MAY NOT REFLECT AS-BUILT CONDITIONS IN ALL CASES. CONTRACTOR TO CONFIRM ALL ELECTRICAL DEVICES TO BE REMOVED PRIOR TO START OF WORK.
- REMOVE, STORE AND REINSTATE ALL SMOKE/HEAT DETECTOR DEVICES TO ACCOMMODATE NEW CEILINGS.
- ALL SINGLE REMOTE HEADS TO BE UPGRADED TO DOUBLE REMOTE HEAD. SEE DWG E2.
- ALL EXIT SIGNS TO BE UPGRADED TO THE RUNNING MAN PICTOGRAM.
- ALL LIGHTING TO BE DISCONNECTED. WIRING TO REMAIN AND CONNECTED TO NEW LIGHTING. SEE DWG E2 FOR LAYOUT.



SCALE : 1:100

0m 1m 2m 3m 4m 5m 6m 7m 8m 9m 10m




PROVINCE OF NEWFOUNDLAND
PERMIT HOLDER
CLASS "A"
This Permit Allows

SNC-LAVALIN Inc.

To practice Professional Engineering
in Newfoundland and Labrador:
Permit No. as issued by PEGNL N0458
which is valid for the year 2017.

ENGINEER IN RESPONSIBLE CHARGE



C01 ISSUED FOR TENDER 12/21/2017

revisions date

project projet

SAR STATION
REFURBISHMENT
ST. ANTHONY

LIFEBOAT STATION

drawing dessin

ELECTRICAL DEMOLITION
FLOOR PLAN

designed SU conçu

date 2017-11-14

drawn GW dessiné

date 2017-11-14

approved MK MK approuvé

date 2017-11-17

Tender DB Soumission

PWGC Project Manager Administrateur de projets TPSC

project number no. du projet

R.089934.001

drawing no. no. du dessin

E1