

PART 1 - GENERAL

1.1 REFERENCE STANDARDS

- .1 CSA International
- .2 Underwriters' Laboratories of Canada (ULC)

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for door chimes and include product characteristics, performance criteria, physical size, finish and limitations.

PART 2 - PRODUCTS

2.1 EQUIPMENT

- .1 Door bells:, buzzer, ac 24 V, 3 A, indoor outdoor weatherproof, mounting surface, colour white, sound level 10 dB at 3.0 m, ULC listed.
- .2 Class II transformers: 24 V, 3 A secondary. 120 V, 60 Hz primary, with two gang mounting, CSA listed, thermal protected.
- .3 Pushbuttons: low voltage, lighted, style for surface mounting.
- .4 Low voltage wiring: type LUT.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Attach components to box where indicated with screws and expanded shields.
- .2 Install wiring.
- .3 Remove packing material and construction dirt around plunger.

3.2 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Test system for operation and sound level.

END OF SECTION