

Amendment 002- Questions and Answers

Q1) Is there a Designated Substance report for this project?

A1) Yes, see attachment 004

Q2) Confirm the make, model and color of the existing solar wall panels

A2) Current model, black. Coordinate on site.

Q3) Confirm gas meter location on the drawings

A3) The gas meter/connection for the main building is on the South East corner, adjacent to the "main gate" and stairway providing access to/from the rear (southern) yard.

Q4) Confirm whether seismic is not required on BUOY Building

A4) Seismic curb is not required for new make-up air unit on buoy building.

Q5) Confirm the new MAU in Main building will fit within the steel joists

A5) New MAU units will fit above the overhead joist.

Q6) Confirm all systems controls are stand-alone and not part of a building automation system

A6) All equipment are stand-alone control, no interconnection to building automation system.