



SOLICITATION AMENDMENT # 2

THIS AMENDMENT CONSISTS OF QUESTIONS AND ANSWERS TO THE ITT IN ADDITION TO A 2ND SCHEDULED SITE VISIT MEETING

1. ANSWER QUESTIONS ASKED BY POTENTIAL BIDDERS.

QUESTION AND ANSWERS

Q1: Are there present leaks or is the work for aesthetic reasons?

A1: Yes, the work is to address existing leaks

Q2: Will tie offs be required for working on the edge?

A2: Yes, tie offs are an option. There are no existing tie-off anchors. New anchors will only be permitted to be installed in the masonry joints. No stone drilling allowed.

Q3: Has it been confirmed that the waterproofing system is compatible to go over the existing? Does the manufacturer stand behind 3 year warranty asked for in the contract documents?

A3: The specified waterproofing systems have been chosen by consultant after consultations with manufacturers. The Consultant confirms discussion with manufacturers regarding compatibility with substrate and warranty requirements.

Q4: We noticed that there are drainage problems. Is rectification of these problems a part of the project?

A4: Drainage work is not in scope.

Q5: Bridge design to cross the ditch is by the contractor?

A5: Yes.

Q6: How old are the mock ups on site?

A6: Summer 2016

2. AMENDMENT TO THE ITT

Due to the recent icy weather conditions, a second site visit has been scheduled to take place on **Tuesday, January 30, 2018 at 11:00 AM, Eastern Standard Time.**

Site Visit Meeting Address:

1 Fort Henry Drive
Fort Henry National Historic Site, Fort Henry West gate.

END OF SECTION.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.