

January 25, 2018

ADDENDUM – INVITATION TO TENDER
FOR
SCOTT RESEARCH FARM
CONTRACT NO. 2 – ASBESTOS ABATEMENT & BUILDING DEMOLITION
CONTRACT #465-1-35-C2

Addendum No. 1

Questions and Answers

Q1 - We were wondering how we should bid on the vermiculite that was found in the attic area of the residential house in regards to where it is located. Should we assume it is in the whole attic floor, just the one corner that was noted in the report drawing where it was visible, or all 4 attic space corners as seen on the drawing?

A1 – Vermiculite is found throughout the entire attic floor.

Colby Collinge
Materiel Manager AAFC
Regina, Saskatchewan S4P 0M3

Le 25 janvier 2018

ADDENDA – AVIS D’APPEL D’OFFRES
POUR LA
FERME EXPÉRIMENTALE DE SCOTT
CONTRAT N° 2 - DÉSAMIANTAGE ET DÉMOLITION DE BÂTIMENTS
CONTRAT N° 465-1-35-C2

Addenda N° 1

Questions et réponses

Q1 - Nous nous demandions comment nous devrions offrir sur la vermiculite qui a été retrouvée dans la zone de grenier de la maison résidentielle quant à où elle est localisée. Devrions-nous supposer qu'elle est dans le plancher de grenier entier, juste un coin tel que noté dans le dessin de rapport où c'était visible, ou les 4 coins du grenier tel qu'illustré sur le dessin ?

R1 – La vermiculite est présente dans le grenier entier.

Colby Collinge
Gestionnaire du matériel AAC
Regina, Saskatchewan S4P 0M3