



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Parks Canada Agency
1869 Upper Water Street, Suite AH 201
Halifax, Nova Scotia B3J 1S9

Agence Parcs Canada
1869 rue Upper Water, Pièce AH201
Halifax (Nouvelle- Écosse) B3J 1S9

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
1869 Upper Water Street, Suite AH 201
Halifax, Nova Scotia B3J 1S9

Agence Parcs Canada
1869 rue Upper Water, Pièce AH201
Halifax (Nouvelle- Écosse) B3J 1S9

Title-Sujet Supply and Install a heat pump at the Cavalier Building, Halifax Citadel National Historic Site		
Solicitation No. - No. de l'invitation 5P201-17-5179/A		Amendment No.:/N° de modification de l'invitation 002
Client Ref. No. - No. de réf du client. 737		Date: January 29, 2018
GETS Reference No. - No de reference de SEAG PW-18-008110600		
Solicitation Closes:		
at - à 02:00 PM	on - le February 1, 2018	Time Zone - Fuseau horaire AST - HNA
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Tanya Allen – tanya.allen@pc.gc.ca		
Telephone No. - No de téléphone (902) 426-7543		Fax No. - No de FAX: (902) 426-1775
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein – Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)
À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)

Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur	
Address – Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de téléphone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

AMENDMENT 002

A. Tender Package

1. General

Note that room numbers have been updated. Refer to attached drawing M1.

It is anticipated that the boiler will be shut off in the process to replace current hydronic zone valves. Contractor will be required to provide temporary heating during this time. Once valves are in place, to be left in open position until commissioning of heat pump and zone valves is completed. Refer to attached photo for existing thermostatic valve configuration.

Seismic restraints are not required. Section 23 05 48 and all references to this section can be disregarded.

Excavation work is to be scheduled in May and coordinated with Parks Canada to avoid winter conflicts. All other work be completed within the contract agreement.

2. Drawings

Drawing A1

Add note: Access panel to be provided in drop ceiling to allow access to junction box in Entry #1. Access panel to be 300mm by 300mm for hand entry.

Drawing E1

Update location of panel to align with revised room numbers: "Cavalier 3rd Floor Office 9" to be "Cavalier 3rd Floor Office 14".

General Note: Teck Cable will be accepted within the chimney riser.

Drawing M1

Add note: refrigerant piping and electrical wiring shall be laid through slab through to wall before rising to chimney in the Sand Room. Additional exposed conduit will not be acceptable.

3. Add the following documents

M1 - Issue for Addendum1.pdf

Photo Existing Thermostatic Valve.pdf

ALL OTHER TERMS AND CONDITONS REMAIN THE SAME.
