

Amendment 004

Q1) The drawings are missing information on the existing panel / breakers. Could you please look into provide me with such details.

A1) The drawings have sufficient information for the contractors to provide a proposal, including material quantities. The contractor is to connect to the existing electrical panel 'A' and will need to provide a new breaker to match existing manufacturer and interrupting capacity. This would be field verified by the contractor during the shop drawing process.