



RETURN BIDS TO:  
 RETOURNER LES SOUMISSIONS À:

**Parks Canada Agency  
 Mailroom  
 30 Victoria Street  
 Gatineau, Quebec, J8X 0B3**

## Amendment #1

INVITATION TO TENDER  
 APPEL D'OFFRES

**Tender To: Parks Canada Agency**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

**Soumission aux: l'Agence Parcs Canada**

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Vendor/Firm Name and Address

Raison sociale et adresse du  
 fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency  
 Mailroom  
 30 Victoria Street  
 Gatineau, Quebec, J8X 0B3**

<b>Title-Sujet</b> <b>Rehabilitation of Kiosks and Entrances Prince Edward Island National Park</b>		<b>Date</b> <b>30 January , 2018</b>
<b>Solicitation No. - No. de l'invitation</b> <b>5P047-17-5241/A</b>	<b>Client Ref. No. - No. de réf du client.</b>	
<b>GETS Reference No. - No de reference de SEAG</b> PW-18-00812878		
<b>Solicitation Closes</b> <b>L'invitation prend fin -</b>	<b>Time Zone</b> <b>Fuseau horaire -</b>	
<b>at - à 02:00 PM</b> <b>on - le 2018-02-07</b>	<b>Eastern Standard Time</b> <b>(EST)</b>	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/></b>		
<b>Address Inquiries to: - Adresser toute demande de renseignements à :</b> <b>Patrick Sullivan at Patrick.Sullivan@pc.gc.ca</b>		
<b>Telephone No. - No de téléphone</b> <b>(819) 420-9557</b>	<b>Fax No. - No de FAX:</b>	
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b>  <b>See Herein</b>		
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>		
<b>Name and title of person authorized to sign on behalf of the Vendor/Firm</b> <b>Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur</b>		
<b>Signature</b>	<b>Date</b>	



## **AMENDMENT #1**

### **THE PURPOSE OF THIS AMENDMENT IS TO POST QUESTIONS AND ANSWERS AND ALSO POST SITE VISIT REGISTER**

#### **Question #1**

On the Kiosks layout plans C1-C4 they refer to drawing C5 for details on the new entry gate complete with reset loops and push button. Drawing C5 does not contain the details or specification for the required entry gate and accessories. Can this be made available please?

#### **Answer #1**

Details 9 and 12 on drawing C5 includes what they're looking for.

#### **Question #2**

I would like to get an alternate profile approved for the specified sheet metal roofing in section 07 61 00 item 2.1.1.3. I would like to get Agway Metals AR-38 approved as alternate profile to the Tradition 100-4. The AR-38 is a mechanically seamed architectural standing seam that doesn't require the need for snap caps. With the metal roof being fully supported on plywood I would like to change the core material thickness from 22 gauge (0.76mm) to 24 ga (0.65 mm) as with this new thickness of 24 gauge in the AR 38 we can give you 180 degree mechanically seamed sided lap; whereas, with the specified 22 gauge material we can only give you 90 degree side lap seam.

As with profile coverage will have to change from the specified 400 mm (15 3/4") to 509.5 (20 .06") for the AR-38

#### **Answer #2**

Parks Canada Agency is not accepting this alternative specified roofing at this time.

#### **Question #3**

Request for alternatives mechanical components has been made.

#### **Answer #3**

##### **DRAWINGS**

1 Reference Drawing M1 - Mechanical Plans, Details & Schedules

.1 Reference Heat Pump Unit Schedule:

.1 Add Manufacturers: Mitsubishi, Daikin, Carrier, LG as approved equals.



2 Reference Exhaust Fan Schedule:

.1 Add Manufacturers: Delta Electronics.

.2 Add following to comments: Fan to be a DC Brushless Exhaust Fan.

#### **Question #4**

We were just wondering if the 4 site specific landscape plans were to be allocated in the original tender price or if they were to be designed and quoted after the project is awarded?

#### **Answer #4**

Contractor to provide \$20,000 allowance per kiosk replacement location for design, supply and installation of landscaping specified on drawing C6.

The site visit register is posted in the attachments

**ALL OTHER TERMS AND CONDITIONS OF THE ITT REMAIN UNCHANGED**