

ADDENDUM No. 3

The following changes to the tender documents are effective immediately and will form part of the contract documents:

1. GENERAL

1.1	The Bidding Documents are amended as noted in this Addendum, which consists of one (1) page plus the following attachments: 1. Drawing #A1.10 – Interior Fence Elevations 2. Drawing #A1.11 – Interior Fence Elevations & Sections
1.2	This Addendum is issued prior to bid closing to incorporate revisions noted herein. Include in the Bid price all such revisions which will become part of the Work. Perform all such Work in accordance with the Contract Documents.
1.3	All affected drawings, schedules and panel changes shall be reflected in final as-built and manual submissions.

2. ANSWERS TO BIDDERS' QUESTIONS

2.1	Not used.
-----	-----------

3. SPECIFICATIONS

3.1	Not used.
-----	-----------

4. DRAWINGS

4.1	Drawing #A1.9 – Interior Manual Gates: 1) Revise any vehicle gate post diameter dimensions shown as 150 mm to read “143.3 mm min.”.
4.2	Drawing #A1.10 – Interior Fence Elevations: 1) See attached revised drawing.
4.3	Drawing #A1.11 – Interior Fence Elevations & Sections: 1) See attached revised drawing.

5. REVISIONS TO ADDENDUM #1

5.1	Revise item #3.6 in Addendum #1 to read: “Section 32 31 00 - Vehicle Sallyport Gates: Refer to answers to questions #8 and #9 above for description of changes.”
5.2	Revise item #3.7 in Addendum #1 to read: “Section 32 31 13 - Chain Link Fences and Gates: Refer to answer to question #17 above for description of changes.”
5.3	Revise Answer to Question #17 to read: “Revise corner and gate post diameters on Drawing A1.9 to read: ‘ 143.3 mm min. ’. Revise corner and gate post minimum size in New Construction Fence Legend on Drawing A0.2 to read 143.3 mm O.D. 21.0 kg/m.”

END OF ADDENDUM NO. 3