

EXISTING PANEL														
VOLTS <u>120/208</u>			PANEL <u>P5A</u>			TYPE <u>MAINS</u>			AMPS <u>225A</u>					
PHASE <u>3</u>			LOCATION <u>ELECTRICAL ROOM 507</u>			ENTER AT <u></u>			MTG. <u>s</u>					
WIRE <u>4</u>			FED FROM <u></u>											
DESIGNATION	WATTS			CIR. No.	BKR NO	A B C	BKR NO	CIR. No.	WATTS			DESIGNATION		
	A	B	C						A	B	C			
Δ CEILING GRID JUNCTION BOX#1	250			1	15A	+	15A	2	250			CEILING GRID JUNCTION BOX#5	Δ	
Δ CEILING GRID JUNCTION BOX#1		250		3	15A	+	15A	4		250		CEILING GRID JUNCTION BOX#5	Δ	
Δ CEILING GRID JUNCTION BOX#1			250	5	15A	+	15A	6			250	CEILING GRID JUNCTION BOX#5	Δ	
Δ CEILING GRID JUNCTION BOX#1	250			7	15A	+	15A	8	250			CEILING GRID JUNCTION BOX#5	Δ	
Δ CEILING GRID JUNCTION BOX#1		250		9	15A	+	15A	10		250		CEILING GRID JUNCTION BOX#5	Δ	
Δ CEILING GRID JUNCTION BOX#2			250	11	15A	+	15A	12			250	CEILING GRID JUNCTION BOX#6	Δ	
Δ CEILING GRID JUNCTION BOX#2	250			13	15A	+	15A	14	250			CEILING GRID JUNCTION BOX#6	Δ	
Δ CEILING GRID JUNCTION BOX#2		250		15	15A	+	15A	16		250		CEILING GRID JUNCTION BOX#6	Δ	
Δ CEILING GRID JUNCTION BOX#2			250	17	15A	+	15A	18			250	CEILING GRID JUNCTION BOX#6	Δ	
Δ CEILING GRID JUNCTION BOX#2	250			19	15A	+	15A	20	250			CEILING GRID JUNCTION BOX#6	Δ	
Δ CEILING GRID JUNCTION BOX#3		250		21	15A	+	15A	22		100		TRAP PRIMER	Δ	
Δ CEILING GRID JUNCTION BOX#3			250	23	15A	+	15A	24			100	LIGHTING RM 508H	Δ	
Δ CEILING GRID JUNCTION BOX#3	250			25	15A	+		26						
Δ CEILING GRID JUNCTION BOX#3		250		27	15A	+	20A	28		700		RECEPT. KITCHENETTE MICROWAVE	▲	
Δ CEILING GRID JUNCTION BOX#3			250	29	15A	+	20A	30			700	RECEPT. KITCHENETTE MICROWAVE	▲	
Δ CEILING GRID JUNCTION BOX#4	250			31	15A	+	20A	32	600			RECEPT. KITCHENETTE COUNTER	▲	
Δ CEILING GRID JUNCTION BOX#4		250		33	15A	+	20A	34		600		RECEPT. KITCHENETTE COUNTER	▲	
Δ CEILING GRID JUNCTION BOX#4			250	35	15A	+	20A	36			600	RECEPT. KITCHENETTE COUNTER	▲	
Δ CEILING GRID JUNCTION BOX#4	250			37	15A	+	15A	38	400			FLOOR RECEPT. RM 508G	Δ	
Δ CEILING GRID JUNCTION BOX#4		250		39	15A	+	15A	40		400		FLOOR RECEPT. RM 508G	Δ	
Δ RECEPTS. ROOM 508H			600	41	15A	+	20A	42			800	RECEPT. CORRIDORS	Δ	
Δ FLOOR RECEPTACLE RM 508A	400			43	15A	+		44	800			RECEPT. CORRIDORS	Δ	
Δ FLOOR RECEPTACLE RM 508B		400		45	15A	+	15A	46		400		RECEPT. ELEC. RM	Δ	
Δ FLOOR RECEPTACLE RM 508C			400	47	15A	+	15A	48			400	RECEPT. COMM. RM	Δ	
Δ FLOOR RECEPTACLE RM 508G	400			49	15A	+	20A	50	400			RECEPT. KITCHENETTE COUNTER	Δ	
Δ LIGHTING 508A, 508B, 508C		456		51	20A	+	15A	52				SPARE	Δ	
Δ LIGHTING 508G			380	53	20A	+	15A	54			600	RECEPT. KITCHENETTE FRIDGE	Δ	
Δ SPARE				55	20A	+	15A	56				MECHANICAL CONTROLS	Δ	
Δ SPARE				57	20A	+	15A	58				MECHANICAL CONTROLS	Δ	
Δ SPARE				59	20A	+	15A	60				SPARE	Δ	