



RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS À:

**Parks Canada Agency  
Mailroom  
30 Victoria Street  
Gatineau, Quebec, J8X 0B3**

## Amendment #5

INVITATION TO TENDER  
APPEL D'OFFRES

**Tender To: Parks Canada Agency**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

**Soumission aux: l'Agence Parcs Canada**

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency  
Mailroom  
30 Victoria Street  
Gatineau, Quebec, J8X 0B3**

<b>Title-Sujet</b> <b>Rehabilitation of Kiosks and Entrances Prince Edward Island National Park</b>		<b>Date</b> <b>12 February , 2018</b>
<b>Solicitation No. - No. de l'invitation</b> <b>5P047-17-5241/A</b>		<b>Client Ref. No. - No. de réf du client.</b>
<b>GETS Reference No. - No de reference de SEAG</b> PW-18-00812878		
<b>Solicitation Closes</b> <b>L'invitation prend fin -</b>		<b>Time Zone</b> <b>Fuseau horaire -</b>
<b>at - à 02:00 PM</b> <b>on - le 2018-02-14</b>		<b>Eastern Standard Time (EST)</b>
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/></b>		
<b>Address Inquiries to: - Adresser toute demande de renseignements à :</b> <b>Ginette Aliaga at Ginette.Aliaga@pc.gc.ca</b>		
<b>Telephone No. - No de téléphone</b> <b>(819) 420-4667</b>		<b>Fax No. - No de FAX:</b>
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b>  <b>See Herein</b>		
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>		
<b>Name and title of person authorized to sign on behalf of the Vendor/Firm</b> <b>Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur</b>		
<b>Signature</b>		<b>Date</b>



## AMENDMENT #5

### THIS AMENDMENT CONSISTS OF QUESTION AND ANSWERS TO THE ITT

#### 1. ANSWER QUESTIONS ASKED BY POTENTIAL BIDDERS.

---

Q-1 I have a question about the blinds for this job. I was just asked to take a look at it today, by my co-worker Eric Marshall. I'm not sure if I'm too late for a question or not but in section 2.1.1.1, it says the blinds are to have side and bottom channels and be an opaque window shade system for total opacity. In section 2.2.2.1 the acceptable fabric is listed as Altex 4000 10% open. With this amount of openness, there will be light transmission so the window shade system will not be a total opacity system, even with the side and bottom channels. May I make a suggestion that the side and bottom channels be omitted, as they are not needed and are fairly pricey. Also, the Altex 4000 is a 5% openness. The 10% openness fabric is the 4100. Just wanted to confirm if you do want the 10% open.

A-1: Reference Specification Section 12 24 13 – Roller Window Shades: Delete existing clause 2.1.1.1 as written and replace with “Bead chain and clutch operated. Vertical roll-up fabric opaque window shade system complete with headbox.”

Reference Specification Section 12 24 13 – Roller Window Shades: Delete existing clause 2.2.2.1.1 as written and replace with “Altex Sheerwave 4100 fabric.”

Q-2 The way I read the contract documents there is a requirement for 24 hour site security at each location during the length of the project. Is this correct? And if not is anything required in the form of site security?

A-2: Clarification: General Contractor will be responsible for site security for the duration of the contract at each of the four locations. Although no specific temporary fencing and barricades are specified, the owner will not be responsible for any vandalism, theft, etc. that may occur over the duration of this contract.

Q-3 In specifications section 01 45 00 subsection 1.2.1, it indicates that the contractor is to engage concrete testers & compaction testers. Is this correct? Typically parks engages their own?

A-3: Clarification: General Contractor will be responsible for all material testing, as called for in the specifications.

Q-4 In specifications section 01 50 00 subsection 1.1.5 it implies there is a requirement for temporary fencing however there is no specific mention of this requirement in regards to height and type etc. Is this a requirement of the contract to provide temp construction fencing or just if we desire to use it?

A-4: See response to question number 2.



Q-5 For operation and maintenance manuals and closeout binders, do we need to submit 3 copies for each separate kiosk or just 3 copies for the entire job of all kiosks?

A-5: Reference Specification Section 01 78 00 – Closeout Submittals: Delete existing clause 1.4.3.2 as written and replace with “Upon review and acceptance by Departmental Representative, submit 3 final copies per kiosk location (12 total). Initial copies are not to be considered as part of the final copies unless they have been fully revised and are identical to the final approved version.”

Q-6 There is a section in the specifications (section 07 11 13) for bituminous damp-proofing for the foundations however there is no indication on the drawings in any details for this. Is this required to be installed on the foundation walls?

A-6: Reference Drawing A2, Detail 3: Add note: “PROVIDE BITUMINOUS DAMP-PROOFING ON NEW FOUNDATION WALLS IN ACCORDANCE WITH SPECIFICATION SECTION 07 11 13 (TYP)”

Q-7 Under specification section 07 21 13 subsection 2.1 it indicates there is 25mm thick Type 4 foam under the concrete slabs and on the inside face of the foundation walls however there is nothing showing on the plans or in details of the foundation or listed under the floor type F1 that indicates foam under the slabs. Is there form under the slabs or not? and is there foam on the inside face of the foundation walls or not?

A-7: Reference Specification Section 07 21 13 – Board Insulation: Delete section entirely.

Q-8 I am requesting an approved equal in regards to the shingles and wood siding portion of the job.

A-8: Reference Specification Section 07 31 29 – Wood Shingles and Shakes: Add new clause 2.1.1.1.2 to read:

“.2 Approved equal product: Fraser Wood Siding – Classic Series”

**ALL OTHER TERMS AND CONDITIONS OF THE ITT REMAIN UNCHANGED**