

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.

1.2 SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Shop drawings; submit drawings stamped and signed by professional engineer registered or licensed in Province of Nova Scotia, Canada when requested.
 - .3 Shop drawings to show:
 - .1 Mounting arrangements.
 - .2 Operating and maintenance clearances.
 - .4 Shop drawings and product data accompanied by:
 - .1 Detailed drawings of bases, supports, and anchor bolts.
 - .2 Acoustical sound power data, where applicable.
 - .3 Points of operation on performance curves.
 - .4 Manufacturer to certify current model production.
 - .5 Certification of compliance to applicable codes.
 - .5 In addition to transmittal letter referred to in Section 01 33 00 - Submittal Procedures: use MCAC "Shop Drawing Submittal Title Sheet". Identify section and paragraph number.
 - .6 Closeout Submittals:
 - .1 Provide operation and maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.
 - .2 Operation and maintenance manual approved by, and final copies deposited with, Departmental Representative before final inspection.
 - .3 Operation data to include:
 - .1 Control schematics for systems including environmental controls.
 - .2 Description of systems and their controls.
 - .3 Description of operation of systems at various loads together with reset schedules and seasonal variances.
 - .4 Operation instruction for systems and component.
 - .5 Description of actions to be taken in event of equipment failure.
 - .6 Valves schedule and flow diagram.
 - .7 Colour coding chart.
 - .4 Maintenance data to include:
 - .1 Servicing, maintenance, operation and trouble-shooting instructions for each item of equipment.
-

- .2 Data to include schedules of tasks, frequency, tools required and task time.
- .5 Performance data to include:
 - .1 Equipment manufacturer's performance datasheets with point of operation as left after commissioning is complete.
 - .2 Equipment performance verification test results.
 - .3 Special performance data as specified.
 - .4 Testing, adjusting and balancing reports as specified in Section 23 05 93 - Testing, Adjusting and Balancing for HVAC.
- .6 Approvals:
 - .1 Submit 3 copies of draft Operation and Maintenance Manual to Departmental Representative for approval. Submission of individual data will not be accepted unless directed by Departmental Representative.
 - .2 Make changes as required and re-submit as directed by Departmental Representative.
- .7 Additional data:
 - .1 Prepare and insert into operation and maintenance manual additional data when need for it becomes apparent during specified demonstrations and instructions.
- .8 Site records:
 - .1 Provide sets of white prints as required for each phase of work. Mark changes as work progresses and as changes occur. Include changes to existing mechanical systems, control systems and low voltage control wiring.
 - .2 Transfer information weekly to reproducibles, revising reproducibles to show work as actually installed.
 - .3 Use different colour waterproof ink for each service.
 - .4 Make available for reference purposes and inspection.
- .9 As-built drawings:
 - .1 Prior to start of Testing, Adjusting and Balancing for HVAC, finalize production of as-built drawings.
 - .2 Identify each drawing in lower right hand corner in letters at least 12 mm high as follows: - "AS BUILT DRAWINGS: THIS DRAWING HAS BEEN REVISED TO SHOW MECHANICAL SYSTEMS AS INSTALLED" (Signature of Contractor) (Date).
 - .3 Submit to Departmental Representative for approval and make corrections as directed.
 - .4 Perform testing, adjusting and balancing for HVAC using as-built drawings.
 - .5 Submit completed reproducible as-built drawings with Operating and Maintenance Manuals.
- .10 Submit copies of as-built drawings for inclusion in final.

1.3 QUALITY ASSURANCE

- .1 Quality Assurance: in accordance with Section 01 45 00 - Quality Control.

- .2 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 29 - Health and Safety Requirements.

1.4 MAINTENANCE

- .1 Furnish spare parts in accordance with Section 01 78 00 - Closeout Submittals as follows:
 - .1 One set of packing for each pump.
 - .2 One casing joint gasket for each size pump.
 - .3 One filter cartridge or set of filter media for each filter or filter bank in addition to final operating set.
- .2 Provide one set of special tools required to service equipment as recommended by manufacturers and in accordance with Section 01 78 00 - Closeout Submittals.
- .3 Furnish one commercial quality grease gun, grease and adapters to suit different types of grease and grease fittings.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Waste Management and Disposal:
 - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 NOT USED

- .1 Not used.

PART 3 - EXECUTION

3.1 PAINTING REPAIRS AND RESTORATION

- .1 Apply at least one coat of corrosion resistant primer and fished enameled coat to site fabricated steel supports and uninsulated steel piping.
 - .2 Prime and touch up marred finished paintwork to match original.
-

- .3 Restore to new condition, finishes which have been damaged.

3.2 CLEANING

- .1 Clean interior and exterior of all systems including strainers. Vacuum interior of ductwork and air handling units.

3.3 FIELD QUALITY CONTROL

- .1 Manufacturer's Field Services:
 - .1 Obtain written report from manufacturer verifying compliance of Work, in handling, installing, applying, protecting and cleaning of product and submit Manufacturer's Field Reports as described in PART 1 - SUBMITTALS.
 - .2 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.
 - .3 Schedule site visits, to review Work, as directed in PART 1 - QUALITY ASSURANCE.

3.4 DEMONSTRATION

- .1 Departmental Representative will use equipment and systems for test purposes prior to acceptance. Supply labour, material, and instruments required for testing.
- .2 Supply tools, equipment and personnel to demonstrate and instruct operating and maintenance personnel in operating, controlling, adjusting, trouble-shooting and servicing of all systems and equipment during regular work hours, prior to acceptance.
- .3 Use operation and maintenance manual, as-built drawings, and audio visual aids as part of instruction materials.
- .4 Departmental Representative will record these demonstrations on video tape for future reference.

3.5 PROTECTION

- .1 Protect equipment and systems openings from dirt, dust, and other foreign materials with materials appropriate to system.

PART 1 - GENERAL

1.1 SUMMARY

- .1 Section Includes:
 - .1 Use of mechanical systems during construction.

1.2 USE OF SYSTEMS

- .1 Use of existing permanent heating and ventilating systems for supplying temporary heat or ventilation is permitted only under following conditions:
 - .1 Entire system is complete, pressure tested, cleaned, flushed out.
 - .2 Building has been closed in, areas to be heated/ventilated are clean and will not thereafter be subjected to dust-producing processes.
 - .3 There is no possibility of damage.
 - .4 Supply ventilation systems are protected by 60 % filters, inspected daily, changed every 2 weeks or more frequently as required.
 - .5 Return systems have approved filters over openings, inlets, outlets.
 - .6 Systems will be:
 - .1 Operated as per manufacturer's recommendations and instructions.
 - .2 Operated by Contractor.
 - .3 Monitored continuously by Contractor.
 - .7 Warranties and guarantees are not relaxed.
 - .8 Regular preventive and other manufacturers recommended maintenance routines are performed by Contractor at own expense and under supervision of Departmental Representative.
- .2 Filters specified in this Section are over and above those specified in other Sections of this project.
- .3 Exhaust systems are not included in approvals for temporary heating ventilation.

PART 2 - PRODUCTS

2.1 NOT USED

- .1 Not Used.
-

PART 3 - EXECUTION

3.1 NOT USED

.1 Not Used.

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Section 01 74 11 - Cleaning.
- .2 Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

1.2 REFERENCES

- .1 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-1.181-99, Ready-Mixed Organic Zinc-Rich Coating.

1.3 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
- .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal paper, plastic, polystyrene and corrugated cardboard packaging material in appropriate on-site for recycling in accordance with Waste Management Plan.
- .4 Divert unused metal materials from landfill to metal recycling facility approved by Departmental Representative.

PART 2 - PRODUCTS

2.1 NOT USED

- .1 Not used.

PART 3 - EXECUTION

3.1 CONNECTIONS TO EQUIPMENT

- .1 In accordance with manufacturer's instructions unless otherwise indicated.
-

- .2 Use valves and either unions or flanges for isolation and ease of maintenance and assembly.
- .3 Use double swing joints when equipment mounted on vibration isolation and when piping subject to movement.

3.2 CLEARANCES

- .1 Provide clearance around systems, equipment and components for observation of operation, inspection, servicing, maintenance and as recommended by manufacturer.
- .2 Provide space for disassembly, removal of equipment and components as recommended by manufacturer or as indicated (whichever is greater) without interrupting operation of other system, equipment, components.

3.3 DRAINS

- .1 Install piping with grade in direction of flow except as indicated.
- .2 Install drain valve at low points in piping systems, at equipment and at section isolating valves.
- .3 Pipe each drain valve discharge separately to above floor drain. Discharge to be visible.
- .4 Drain valves: NPS 3/4 ball valves unless indicated otherwise, with hose end male thread, cap and chain.

3.4 AIR VENTS

- .1 Install automatic air vents at high points in closed loop piping systems.
- .2 Install isolating valve at each automatic air vent.
- .3 Install drain piping from vent to approved location and terminate where discharge is visible.

3.5 DIELECTRIC COUPLINGS

- .1 General: Compatible with system, to suit pressure rating of system.
-

- .2 Locations: Where dissimilar metals are joined.
- .3 NPS 2 and under: isolating unions or bronze valves.
- .4 Over NPS 2: Isolating flanges.

3.6 PIPEWORK INSTALLATION

- .1 Protect openings against entry of foreign material.
 - .2 Install to isolate equipment and allow removal without interrupting operation of other equipment or systems.
 - .3 Assemble piping using fittings manufactured to ANSI standards.
 - .4 Saddle type branch fittings may be used on mains if branch line is no larger than half the size of main.
 - .1 Hole saw (or drill) and ream main to maintain full inside diameter of branch line prior to welding saddle.
 - .5 Install exposed piping, equipment, rectangular cleanouts and similar items parallel or perpendicular to building lines.
 - .6 Install concealed pipework to minimize furring space, maximize headroom, conserve space.
 - .7 Slope piping, except where indicated, in direction of flow for positive drainage and venting.
 - .8 Install, except where indicated, to permit separate thermal insulation of each pipe.
 - .9 Group piping wherever possible and as indicated.
 - .10 Ream pipes, remove scale and other foreign material before assembly.
 - .11 Use eccentric reducers at pipe size changes to ensure positive drainage and venting.
 - .12 Provide for thermal expansion.
 - .13 Valves:
 - .1 Install in accessible locations.
 - .2 Remove interior parts before soldering.
 - .3 Install with stems above horizontal position unless otherwise indicated.
 - .4 Valves accessible for maintenance without removing adjacent piping.
-

- .5 Install globe valves in bypass around control valves.
- .6 Use ball or butterfly valves at branch take-offs for isolating purposes except where otherwise specified.
- .7 Install butterfly valves between weld neck flanges to ensure full compression of liner.
- .8 Install ball valves for glycol service.
- .9 Use chain operators on valves NPS 2-1/2 and larger where installed more than 2400 mm above floor in Mechanical Rooms.

.14 Check Valves:

- .1 Install swing check valves in horizontal lines, on discharge of pumps, and elsewhere as indicated.

3.7 SLEEVES

- .1 General: Install where pipes pass through masonry, concrete structures, fire rated assemblies, and elsewhere as indicated.
- .2 Material: Schedule 40 black steel pipe.
- .3 Construction: Foundation walls and where sleeves extend above finished floors to have annular fins continuously welded on at mid-point.
- .4 Sizes: 6 mm minimum clearance between sleeve and uninsulated pipe or between sleeve and insulation.
- .5 Installation:
 - .1 Concrete, masonry walls, concrete floors on grade: Terminate flush with finished surface.
 - .2 Other floors: Terminate 25 mm above finished floor.
 - .3 Before installation, paint exposed exterior surfaces with heavy application of zinc-rich paint to CAN/CGSB-1.181.
- .6 Sealing:
 - .1 Foundation walls and below grade floors: Fire retardant, waterproof non-hardening mastic.
 - .2 Elsewhere: Provide space for firestopping. Maintain fire rating integrity.
 - .3 Sleeves installed for future use: Fill with lime plaster or other easily removable filler.
 - .4 Ensure no contact between copper pipe or tube and sleeve.

3.8 ESCUTCHEONS

- .1 Install on pipes passing through walls, partitions, floors, and ceilings in finished areas.
-

- .2 Construction: One piece type with set screws. Chrome or nickel plated brass or type 302 stainless steel.
- .3 Sizes: Outside diameter to cover opening or sleeve. Inside diameter to fit around pipe or outside of insulation if so provided.

3.9 PREPARATION FOR FIRESTOPPING

- .1 Uninsulated unheated pipes not subject to movement: No special preparation.
- .2 Uninsulated heated pipes subject to movement: Wrap with non-combustible smooth material to permit pipe movement without damaging firestopping material or installation.
- .3 Insulated pipes and ducts: Ensure integrity of insulation and vapour barriers.

3.10 FLUSHING OUT OF PIPING SYSTEMS

- .1 Before start-up, clean interior of piping systems in accordance with requirements of Section 01 74 11 - Cleaning supplemented as specified in relevant sections of Division 21, 22 and/or 23.
- .2 Preparatory to acceptance, clean and refurbish equipment and leave in operating condition, including replacement of filters in piping systems.

3.11 PRESSURE TESTING OF EQUIPMENT AND PIPEWORK

- .1 Advise Departmental Representative 48 hours minimum prior to performance of pressure tests.
 - .2 Pipework: Test as specified in relevant sections of Divisions 21, 22 and 23. In absence of specific requirements, test piping to the greater of 860 kPa or 1-1/2 times the required system pressure.
 - .3 Maintain specified test pressure without loss for 4 hours minimum unless specified for longer period of time in relevant sections of Divisions 21, 22 or 23.
 - .4 Prior to tests, isolate equipment and other parts which are not designed to withstand test pressure or media.
 - .5 Conduct tests in presence of Departmental Representative.
-

- .6 Pay costs for repairs or replacement, retesting, and making good. Departmental Representative to determine whether repair or replacement is appropriate.

- .7 Insulate or conceal work only after approval and certification of tests by Departmental Representative.

PART 1 - GENERAL

1.1 REFERENCES

- .1 American Society of Heating, Refrigeration and Air-Conditioning Engineers (ASHRAE)
 - .1 ASHRAE 90.1-13, Energy Standard for Buildings Except Low-Rise Residential Buildings (IESNA cosponsored; ANSI approved; Continuous Maintenance Standard).
- .2 Electrical Equipment Manufacturers' Association Council (EEMAC).
- .3 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
- .3 Quality Control: in accordance with Section 01 45 00 - Quality Control.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .2 Instructions: submit manufacturer's installation instructions.
- .4 Closeout Submittals
 - .1 Provide maintenance data for motors, drives and guards for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.3 QUALITY ASSURANCE

- .1 Regulatory Requirements: work to be performed in compliance with CEPA, CEAA, TDGA, and applicable Provincial /Territorial regulations.
-

1.4 DELIVERY, STORAGE, AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
 - .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Waste Management and Disposal:
 - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 GENERAL

- .1 Motors: high efficiency, in accordance with local electrical power company standards and to ASHRAE 90.1.

2.2 MOTORS

- .1 Provide motors for mechanical equipment as specified.
- .2 Motors under 373 W (1/2 HP): speed as indicated, continuous duty, built-in overload protection, resilient mount, single phase, 120 V, unless otherwise specified or indicated.
- .3 Motors 373 W (1/2 HP) and larger: EEMAC Class B, squirrel cage induction, speed as indicated, continuous duty, drip proof, ball bearing, maximum temperature rise 40 degrees C, 3 phase, 575 V, unless otherwise indicated.
- .4 Provide inverter duty motors for variable speed applications.

2.3 TEMPORARY MOTORS

- .1 If delivery of specified motor will delay completion or commissioning work, install motor approved by Departmental Representative for temporary use. Work will only be accepted when specified motor is installed.
-

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 Fasten securely in place.
- .2 Make removable for servicing, easily returned into and positively in position.
- .3 Associated VFD devices to be installed remote from motor or vibrating equipment.

3.3 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.

PART 1 - GENERAL

1.1 SECTION INCLUDES

- .1 Materials and installation for flexible connections, expansion joints, anchors and guides for building services piping.

1.2 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
- .3 Section 01 78 00 - Closeout Submittals.
- .4 Section 03 30 00 - Cast-in-Place Concrete.
- .5 Section 23 08 01 - Performance Verification Mechanical Piping Systems.

1.3 REFERENCES

- .1 American Society for Testing and Materials International, (ASTM)
 - .1 ASTM A 53/A53M-12, Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc-Coated Welded and Seamless.
 - .2 ASTM A 105/A105M-14, Standard Specification for Carbon Steel Forgings, for Piping Applications.

1.4 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Submit product data and indicate for items as applicable:
 - .1 Manufacturer, model number, line contents, pressure and temperature rating.
 - .2 Movement handled, axial, lateral, angular and the amounts of each.
 - .3 Nominal size and dimensions including details of construction and assembly.
 - .3 Submit maintenance data in accordance with Section 01 78 00 - Closeout Submittals.
-

- .4 Data to include:
 - .1 Servicing requirements, including special requirements, stuffing box packing, lubrication and recommended procedures.

1.5 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management And Disposal.

PART 2 - PRODUCTS

2.1 FLEXIBLE CONNECTION

- .1 Application: to suit traverse and longitudinal motion.
- .2 Minimum length in accordance with manufacturer's recommendations to suit offset.
- .3 Inner hose: bronze or stainless steel, corrugated.
- .4 Braided wire mesh, stainless steel outer jacket.
- .5 Diameter and type of end connection: NPS 2 and under: threaded, NPS 2-1/2 and above: flanged.
- .6 Operating conditions:
 - .1 Working pressure: 1034 kPa.
 - .2 Working temperature: 100 degrees C.
 - .3 To match system requirements.

2.2 ANCHORS AND GUIDES

- .1 Anchors:
 - .1 Steel: Provide supplementary steel channel and angle iron welded to building steel structure.
 - .2 Alignment guides:
 - .1 Provide as indicated.
 - .2 To accommodate specified thickness of insulation.
 - .3 Vapour barriers, jackets to remain uninterrupted.
-

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Install flexible connections in accordance with manufacturer's instructions. Install flexible connections on all rotating or vibrating equipment piping connections.
- .2 Install pipe anchors and guides. Anchors to withstand 150% of axial thrust.

3.2 ALIGNMENT GUIDE SPACING

- .1 Alignment guide spacing to be in accordance with expansion joint manufacturers recommendations, and in accordance with the following charts:

.1 Spacing for steel piping alignment guides:

Nominal Pipe Size	First Guide Dist. from Anchors	Guide Spacing After First Guide Expansion Joints
-------------------	--------------------------------	--

1-1/2	0.5m	3.0m
2-1/2	0.8m	5.0m
3	1.0m	6.3m
4	1.4m	7.8m
6	2.0m	11.8m
8	2.8m	5.2m

- .2 Spacing for FRP piping alignment guides:
 - .1 First pipe guide distance from anchors, expansion joints: 4 pipe diameters.
 - .2 Second pipe guide distance from anchors, expansion joints: 14 pipe diameters.

3.3 PERFORMANCE VERIFICATION

- .1 In accordance with Section 23 08 01 - Performance Verification: Mechanical Piping Systems.

PART 1 - GENERAL

1.1 SECTION INCLUDES

- .1 Materials and installation for thermometers and pressure gauges in piping systems.

1.2 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .3 Section 23 05 53.01 - Mechanical Identification.

1.3 REFERENCES

- .1 American Society of Mechanical Engineers (ASME).
 - .1 ASME B40.100-2013, Pressure Gauges and Gauge Attachments.
 - .2 ASME B40.200-2013, Thermometers, Direct Reading and Remote Reading.

1.4 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit shop drawings and product data.
- .3 Submit manufacturer's product data for following items:
 - .1 Thermometers.
 - .2 Pressure gauges.
 - .3 Stop cocks.
 - .4 Syphons.
 - .5 Wells.

PART 2 - PRODUCTS

2.1 GENERAL

- .1 Design point to be at mid point of scale or range.
-

- .2 Ranges: as required. Where pressure gauges are across pumps, etc, both pressure values shall fall within scale or range.

2.2 DIRECT READING THERMOMETERS

- .1 Industrial, variable angle type, liquid filled, 125 mm scale length: to CAN/CGSB 14.4 ASME B40.200.

2.3 REMOTE READING THERMOMETERS

- .1 100 mm diameter mercury-free liquid filled activated dial type: to CAN/CGSB-14.5 ASME B40.200, accuracy within one scale division, brass movement, stainless steel capillary, stainless steel spiral armour, stainless steel bulb and polished brass or stainless steel case for wall mounting.

2.4 THERMOMETER WELLS

- .1 Copper pipe: copper or bronze.
- .2 Steel pipe: brass or stainless steel.

2.5 PRESSURE GAUGES

- .1 112 mm, dial type: to ASME B40.100, Grade 2A, stainless steel or phosphor bronze bourdon tube having 0.5% accuracy full scale unless otherwise specified.
- .2 Provide:
 - .1 Snubber for pulsating operation.
 - .2 Gasketed pressure relief back with solid front.
 - .3 NPS 1/4 ball valves for gauge isolation.
 - .4 Oil filled for high vibration applications.

PART 3 - EXECUTION

3.1 GENERAL

- .1 Install so they can be easily read from floor or platform. If this cannot be accomplished, install remote reading units.
 - .2 Install between equipment and first fitting or valve.
-

3.2 THERMOMETERS

- .1 Install in wells on piping. Provide heat conductive material inside well.
- .2 Use extensions where thermometers are installed through insulation.

3.3 PRESSURE GAUGES

- .1 Install in following locations:
 - .1 Across suction and discharge of pumps.
 - .2 Upstream and downstream of PRV's.
 - .3 Upstream and downstream of control valves.
 - .4 Inlet and outlet of coils.
 - .5 In other locations as indicated.
- .2 Install gauge cocks for shut off purposes, elsewhere as indicated.
- .3 Use extensions where pressure gauges are installed through insulation.

3.4 NAMEPLATES

- .1 Install engraved lamicoid nameplates as specified in Section 23 05 53.01 - Mechanical Identification, identifying medium.

PART 1 - GENERAL

1.1 SUMMARY

- .1 Related Sections:
 - .1 Section 01 33 00 - Submittal Procedures.
 - .2 Section 01 74 21 - Construction /Demolition Waste Management and Disposal.
 - .3 Section 01 78 00 - Closeout Submittals
 - .4 Section 23 05 05 - Installation of Pipework.

1.2 REFERENCES

- .1 American National Standards Institute (ANSI)/ American Society of Mechanical Engineers (ASME).
 - .1 ANSI/ASME B1.20.1-2013, Pipe Threads, General Purpose (Inch).
 - .2 ANSI/ASME B16.18-2012, Cast Copper Alloy Solder Joint Pressure Fittings.
- .2 American Society for Testing and Materials International, (ASTM).
 - .1 ASTM A 276-16, Specification for Stainless Steel Bars and Shapes.
 - .2 ASTM B 62-15, Specification for Composition Bronze or Ounce Metal Castings.
 - .3 ASTM B 283-14a, Specification for Copper and Copper Alloy Die Forgings (Hot-Pressed).
 - .4 ASTM B 505/B 505M-14, Specification for Copper-Base Alloy Continuous Castings.
- .3 Manufacturers Standardization Society of the Valve and Fittings Industry, Inc. (MSS).
 - .1 MSS-SP-25-2013, Standard Marking System for Valves, Fittings, Flanges and Unions.
 - .2 MSS-SP-80-2013, Bronze Gate Globe, Angle and Check Valves.
 - .3 MSS-SP-110-2010, Ball Valves, Threaded, Socket-Welding, Solder Joint, Grooved and Flared Ends.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.
 - .3 Submit data for valves specified in this section.
-

- .4 Closeout Submittals:
 - .1 Submit maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.4 DELIVERY STORAGE AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 MATERIALS

- .1 Valves:
 - .1 Except for specialty valves, to be single manufacturer.
 - .2 All products to have CRN registration numbers.
 - .2 End Connections:
 - .1 Connection into adjacent piping/tubing:
 - .1 Steel pipe systems: Screwed ends to ANSI/ASME B1.20.1.
 - .2 Copper tube systems: Solder ends to ANSI/ASME B16.18.
 - .3 Lockshield Keys:
 - .1 Where lockshield valves are specified, provide 10 keys of each size: malleable iron cadmium plated.
 - .4 Gate Valves:
 - .1 NPS 2 and under, non-rising stem, solid wedge disc, Class 125.
 - .1 Body: with long disc guides, screwed bonnet with stem retaining nut.
 - .2 Operator: Handwheel.
 - .2 NPS 2 and under, rising stem, split wedge disc, Class 125:
 - .1 Body: with long disc guides, screwed bonnet.
 - .2 Disc: split wedge, bronze to ASTM B 283, loosely secured to stem.
 - .3 Operator: Handwheel Lockshield.
 - .3 NPS 2 and under, rising stem, solid wedge disc, Class 125:
 - .1 Body: with long disc guides, screwed bonnet.
 - .2 Operator: Handwheel.
 - .5 Check Valves:
 - .1 Requirements common to check valves, unless specified otherwise:
 - .1 Standard specification: MSS SP-80.
 - .2 Connections: screwed with hexagonal shoulders.
 - .2 NPS 2 and under, swing type, bronze disc, Class 125:
-

- .1 Body: Y-pattern with integral seat at 45 degrees, screw-in cap with hex head.
 - .2 Disc and seat: renewable rotating disc, two-piece hinge disc construction; seat: regrindable.
- .6 Ball Valves:
- .1 NPS 2 and under:
 - .1 Body and cap: cast high tensile bronze to ASTM B 62.
 - .2 Pressure rating: Class 125.
 - .3 Connections: Screwed ends to ANSI B1.20.1 and with hexagonal shoulders, or solder ends to ANSI or as required.
 - .4 Stem: tamperproof ball drive.
 - .5 Stem packing nut: external to body.
 - .6 Ball and seat: replaceable stainless steel or hard chrome solid ball and teflon seats.
 - .7 Stem seal: TFE with external packing nut.
 - .8 Operator: removable lever handle.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Install rising stem valves in upright position with stem above horizontal.
- .2 Remove internal parts before soldering.
- .3 Install valves with unions at each piece of equipment arranged to allow servicing, maintenance, and equipment removal.

PART 1 - GENERAL1.1 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .3 Section 01 78 00 - Closeout Submittals.
- .4 Section 23 05 05 - Installation of Pipework.
- .5 Section 23 05 23.01 - Valves - Bronze.
- .6 Section 23 05 23.02 - Valves - Cast Iron.
- .7 Section 23 05 93 - Testing, Adjusting and Balancing for HVAC.

1.2 REFERENCES

- .1 American National Standards Institute (ANSI)/American Society of Mechanical Engineers (ASME).
 - .1 ANSI/ASME B16.1-2015, Cast Iron Pipe Flanges and Flanged Fittings.
 - .2 American Society for Testing and Materials International (ASTM).
 - .1 ASTM A 49-12, Specification for Heat-Treated Carbon Steel Joint Bars.
 - .2 ASTM A 126-04(2014), Specification for Gray Iron Castings for Valves, Flanges, and Pipe Fittings.
 - .3 ASTM B 61-15, Specification for Steam or Valve Bronze Castings.
 - .4 ASTM B 62-09, Specification for Composition Bronze or Ounce Metal Castings.
 - .5 ASTM B 85-09, Specification for Aluminum-Alloy Die Castings.
 - .6 ASTM B 209-14, Specification for Aluminum and Aluminum-Alloy Sheet and Plate.
 - .3 Manufacturers Standardization Society of the Valve and Fittings Industry, Inc. (MSS).
 - .1 MSS SP-70-2011, Cast Iron Gate Valves, Flanged and Threaded Ends.
 - .2 MSS SP-71-2011, Grey Iron Swing Check Valves, Flanged and Threaded Ends.
 - .3 MSS SP-85-2011, Cast Iron Globe and Angle Valves, Flanged and Threaded Ends.
-

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.
- .3 Submit data for valves specified in this section.
- .4 Closeout Submittals:
 - .1 Submit maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.4 DELIVERY STORAGE AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management And

PART 2 - PRODUCTS

2.1 MATERIAL

- .1 Valves:
 - .1 Except for specialty valves, to be of single manufacturer.
 - .2 Standard specifications:
 - .1 Gate valves: MSS SP-70.
 - .2 Globe valves: MSS SP-85.
 - .3 Check valves: MSS SP-71.
 - .3 Requirements common to valves, unless specified otherwise:
 - .1 Body, bonnet: cast iron to ASTM B 209 Class B.
 - .2 Connections: flanged ends plain face to ANSI B16.1.
 - .3 Inspection and pressure testing: to MSS SP-82.
 - .4 Bonnet gasket: non-asbestos.
 - .5 Stem: to have precision-machined Acme or 60 degrees V threads, top screwed for handwheel nut.
 - .6 Stuffing box: non-galling two-piece ball-jointed packing gland, gland bolts and nuts.
 - .7 Gland packing: non-asbestos.
 - .8 Handwheel: Die-cast aluminum alloy to ASTM B 85 or malleable iron to ASTM A 49. Nut of bronze to ASTM B 62.
 - .9 Identification tag: with catalogue number, size, other pertinent data.
 - .4 All products to have CRN registration numbers.
-

PART 1 - GENERAL

1.1 REFERENCES

- .1 American National Standards Institute/American Society of Mechanical Engineers (ANSI/ASME)
 - .1 ANSI/ASME B31.1-2010, Power Piping.
- .2 American Society for Testing and Materials International (ASTM)
 - .1 ASTM A 125-96(2013)e1, Specification for Steel Springs, Helical, Heat-Treated.
 - .2 ASTM A 307-14, Specification for Carbon Steel Bolts and Studs, 60,000 PSI Tensile Strength.
 - .3 ASTM A 563-15, Specification for Carbon and Alloy Steel Nuts.
- .3 Factory Mutual (FM)
- .4 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .5 Manufacturer's Standardization Society of the Valves and Fittings Industry (MSS)
 - .1 MSS SP 58-2009, Pipe Hangers and Supports - Materials, Design and Manufacture.
- .6 Underwriter's Laboratories of Canada (ULC)

1.2 SYSTEM DESCRIPTION

- .1 Design Requirements:
 - .1 Construct pipe hanger and support to manufacturer's recommendations utilizing manufacturer's regular production components, parts and assemblies.
 - .2 Base maximum load ratings on allowable stresses prescribed by MSS SP 58 or ASME B31.1.
 - .3 Ensure that supports, guides, anchors do not transmit excessive quantities of heat to building structure.
 - .4 Design hangers and supports to support systems under conditions of operation, allow free expansion and contraction, prevent excessive stresses from being introduced into pipework or connected equipment.
 - .5 Provide for vertical adjustments after erection and during commissioning. Amount of adjustment in accordance with MSS SP 58.
-

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit shop drawings and product data for following items:
 - .1 Bases, hangers and supports.
 - .2 Connections to equipment and structure.
 - .3 Structural assemblies.
- .3 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .2 Instructions: submit manufacturer's installation instructions.
- .4 Closeout Submittals:
 - .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.4 DELIVERY, STORAGE, AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
 - .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Waste Management and Disposal:
 - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 GENERAL

- .1 Fabricate hangers, supports and sway braces in accordance with ANSI B31.1 and MSS SP 58.
 - .2 Use components for intended design purpose only. Do not use for rigging or erection purposes.
-

2.2 PIPE HANGERS

- .1 Finishes:
 - .1 Pipe hangers and supports: galvanized after manufacture.
 - .2 Use electro-plating galvanizing process or hot dipped galvanizing process.
 - .3 Ensure steel hangers in contact with copper piping are copper plated or have method to isolate copper from steel.
 - .2 Upper attachment structural: suspension from lower flange of I-Beam:
 - .1 Cold piping NPS 2 maximum: malleable iron C-clamp with hardened steel cup point setscrew, locknut and carbon steel retaining clip.
 - .1 Rod: 13 mm FM approved.
 - .2 Cold piping NPS 2 1/2 or greater, hot piping: malleable iron beam clamp, eye rod, jaws and extension with carbon steel retaining clip, tie rod, nuts and washers, ULC listed and approved to MSS-SP 58 and MSS-SP 69.
 - .3 Upper attachment structural: suspension from upper flange of I-Beam:
 - .1 Cold piping NPS 2 maximum: ductile iron top-of-beam C-clamp with hardened steel cup point setscrew, locknut and carbon steel retaining clip, ULC listed and approved to MSS SP 69.
 - .2 Cold piping NPS 2 1/2 or greater, hot piping: malleable iron top-of-beam jaw-clamp with hooked rod, spring washer, plain washer and nut ULC listed and approved.
 - .4 Upper attachment to concrete:
 - .1 Ceiling: carbon steel welded eye rod, clevis plate, clevis pin and cotters with weldless forged steel eye nut. Ensure eye 6 mm minimum greater than rod diameter.
 - .2 Concrete inserts: wedge shaped body with knockout protector plate ULC listed and approved to MSS SP 69.
 - .5 Shop and field-fabricated assemblies:
 - .1 Trapeze hanger assemblies: as indicated.
 - .6 Hanger rods: threaded rod material to MSS SP 58:
 - .1 Ensure that hanger rods are subject to tensile loading only.
 - .2 Provide linkages where lateral or axial movement of pipework is anticipated.
 - .3 Do not use 22 mm or 28 mm rod.
 - .7 Pipe attachments: material to MSS SP 58:
 - .1 Attachments for steel piping: carbon steel black.
 - .2 Attachments for copper piping: copper plated black steel.
 - .3 Use insulation shields for hot pipework.
 - .4 Oversize pipe hangers and supports.
-

- .8 Adjustable clevis: material to MSS SP 69 UL listed FM approved, clevis bolt with nipple spacer and vertical adjustment nuts above and below clevis.
 - .1 Ensure "U" has hole in bottom for rivetting to insulation shields.
- .9 Yoke style pipe roll: carbon steel yoke, rod and nuts with cast iron roll, to MSS SP 69.
- .10 U-bolts: carbon steel to MSS SP 69 with 2 nuts at each end to ASTM A 563.
 - .1 Finishes for steel pipework: black.
 - .2 Finishes for copper, glass, brass or aluminum pipework: black, with formed portion plastic coated.
- .11 Pipe rollers: cast iron roll and roll stand with carbon steel rod to MSS SP 69.

2.3 RISER CLAMPS

- .1 Steel or cast iron pipe: black, carbon steel to MSS SP 58, type 42, UL listed, FM approved.
- .2 Copper pipe: carbon steel copper plated to MSS SP 58, type 42.
- .3 Bolts: to ASTM A 307.
- .4 Nuts: to ASTM A 563.

2.4 INSULATION PROTECTION SHIELDS

- .1 Insulated cold piping:
 - .1 64 kg/m³ density insulation plus insulation protection shield to: MSS SP 69, galvanized sheet carbon steel. Length designed for maximum 3 m span.

2.5 EQUIPMENT SUPPORTS

- .1 Fabricate equipment supports not provided by equipment manufacturer from structural grade steel meeting requirements of Section 05 50 00 - Metal Fabrications. Submit calculations with shop drawings.

2.6 EQUIPMENT ANCHOR BOLTS AND TEMPLATES

- .1 Provide templates to ensure accurate location of anchor bolts.
-

2.7 HOUSE-KEEPING PADS

- .1 Provide 100 mm high concrete housekeeping pads for base-mounted equipment; size pads 100 mm larger than equipment; chamfer pad edges.
- .2 Concrete: to Section 03 30 00 - Cast-in-place Concrete.

2.8 OTHER PIPING AND EQUIPMENT SUPPORTS

- .1 Fabricate other piping and equipment supports from structural grade steel meeting requirements of Section 05 50 00 - Metal Fabrications.
- .2 Submit structural calculations with shop drawings.

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 Install in accordance with:
 - .1 Manufacturer's instructions and recommendations.
 - .2 Vibration Control Devices:
 - .1 Install on piping systems at pumps, and as indicated.
 - .3 Clamps on riser piping:
 - .1 Support independent of connected horizontal pipework using riser clamps and riser clamp lugs welded to riser.
 - .2 Bolt-tightening torques to industry standards.
 - .3 Steel pipes: install below coupling or shear lugs welded to pipe.
 - .4 Cast iron pipes: install below joint.
 - .4 Clevis plates:
 - .1 Attach to concrete with 4 minimum concrete insets, one at each corner.
-

- .5 Provide supplementary structural steelwork where structural bearings do not exist or where concrete inserts are not in correct locations.

3.3 HANGER SPACING

- .1 Plumbing piping: to Canadian Plumbing Code or authority having jurisdiction.
- .2 Fire protection: to applicable fire code.
- .3 Copper piping: up to NPS 1/2: every 1.5 m.
- .4 Flexible joint roll groove pipe: in accordance with table below, but not less than one hanger at joints. Table listings are for straight runs without concentrated loads and where full linear movement is not required.

- .5 Within 300 mm of each elbow.

Maximum Pipe Size: NPS	Maximum Spacing Steel	Maximum Spacing Copper
up to 1-1/4	2.1 m	1.8 m
1-1/2	2.7 m	2.4 m
2	3.0 m	2.7 m
2-1/2	3.6 m	3.0 m
3	3.6 m	3.0 m
3-1/2	3.9 m	3.3 m
4	4.2 m	3.6 m
5	4.8 m	
6	5.1 m	
8	5.7 m	
10	6.6 m	
12	6.9 m	

3.4 HANGER INSTALLATION

- .1 Install hanger so that rod is vertical under operating conditions.
- .2 Adjust hangers to equalize load.
- .3 Support from structural members. Where structural bearing does not exist or inserts are not in suitable locations, provide supplementary structural steel members.

3.5 HORIZONTAL MOVEMENT

- .1 Angularity of rod hanger resulting from horizontal movement of pipework from cold to hot position not to exceed 4 degrees from vertical.
- .2 Where horizontal pipe movement is less than 13 mm, offset pipe hangers and support so that rod hangers is vertical in the hot position.

3.6 FINAL ADJUSTMENT

- .1 Adjust hangers and supports:
 - .1 Ensure that rod is vertical under operating conditions.
 - .2 Equalize loads.
- .2 Adjustable clevis:
 - .1 Tighten hanger load nut securely to ensure proper hanger performance.
 - .2 Tighten upper nut after adjustment.
- .3 C-clamps:
 - .1 Follow manufacturer's recommended written instructions and torque values when tightening C-clamps to bottom flange of beam.
- .4 Beam clamps:
 - .1 Hammer jaw firmly against underside of beam.

3.7 FIELD QUALITY CONTROL

- .1 Site Test: conduct following tests in accordance with Section 01 45 00 - Quality Control and submit report as described in PART 1 - SUBMITTALS.
- .2 Manufacturer's Field Services:
 - .1 Obtain written report from manufacturer verifying compliance of Work, in handling, installing, applying, protecting and cleaning of product and submit Manufacturer's Field Reports as described in PART 1 - SUBMITTALS.
 - .2 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.
 - .3 Schedule site visits, to review Work, as directed in PART 1 - QUALITY ASSURANCE.

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Section 21 13 13 - Wet Pipe Sprinkler Systems.

1.2 REFERENCES

- .1 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .2 National Fire Protection Association (NFPA)
 - .1 NFPA 13-2015, Standard for the Installation of Sprinkler Systems.
- .3 National Building Code of Canada (NBC) - 2015

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
 - .2 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Provide separate shop drawings for each isolated system system shop drawings complete with performance and product data.
 - .2 Indicate interior bases and locate vibration isolators, with static and dynamic loads on each.
 - .3 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .2 Instructions: submit manufacturer's installation instructions.
 - .3 Manufacturer's Field Reports: manufacturer's field reports specified.
 - .4 Product Data: Provide schedule of vibration isolator type with location and load on each.
-

1.4 DELIVERY, STORAGE, AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
 - .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Waste Management and Disposal:
 - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 GENERAL

- .1 Size and shape of bases type and performance of vibration isolation specified in technical section and indicated elsewhere.
- .2 Acceptable materials:
 - .1 Vibro-acoustics
 - .2 Kinetics Noise
 - .3 Korfund/VMC Group
- .3 Colour code springs for load carrying capacity - colour stripping is not acceptable.
- .4 Outdoor springs and housings to be corrosion resistant.

2.2 ELASTOMERIC PADS

- .1 Type EP1 - neoprene waffle or ribbed; 10 mm minimum thick; 50 durometer; maximum loading 350 kPa.
 - .2 Type EP2 - rubber waffle or ribbed 10 mm minimum thick; 30 durometer natural rubber; maximum loading 415 kPa.
 - .3 Type EP3 - neoprene-steel-neoprene; 9 mm minimum thick neoprene bonded to 1.71 mm steel plate; 50 durometer neoprene, waffle or ribbed; holes sleeved with isolation washers; maximum loading 350 kPa.
-

- .4 Type EP4 - rubber-steel-rubber; 9 mm minimum thick rubber bonded to 1.71 mm steel plate; 30 durometer natural rubber, waffle or ribbed; holes sleeved with isolation washers; maximum loading 415 kPa.

2.3 ELASTOMERIC MOUNTS

- .1 Type M1 - colour coded; neoprene in shear; maximum durometer of 60; threaded insert and two bolt-down holes; ribbed top and bottom surfaces.

2.4 SPRINGS

- .1 Design stable springs: ratio of lateral to axial stiffness is equal to or greater than 1.2 times ratio of static deflection to working height. Select for 50% travel beyond rated load. Units complete with levelling devices.
- .2 Ratio of height when loaded to diameter of spring between 0.8 to 1.0.
- .3 Cadmium plate for outdoor and 100% relative humidity installations.
- .4 Colour code springs.

2.5 SPRING MOUNT

- .1 Zinc or cadmium plated hardware; housings coated with rust resistant paint.
 - .2 Type M3 - stable open spring: 6 mm minimum thick ribbed neoprene or rubber friction and acoustic pad, bonded under isolator and on isolator top plate; levelling bolt for rigidly mounting to equipment.
 - .3 Type M4 - restrained stable open spring: supported on bonded 6 mm minimum thick ribbed neoprene or rubber friction and acoustic pad; built-in resilient limit stops, removable spacer plates.
 - .4 Type M5 - enclosed spring mounts with snubbers for isolation up to 950 kg maximum.
 - .5 Performance: 50 mm static deflection unless noted otherwise.
-

2.6 HANGERS

- .1 Colour coded springs, rust resistant, painted box type hangers. Arrange to permit hanger box or rod to move through a 30 degrees arc without metal to metal contact.
- .2 Type H2 - stable spring, elastomeric washer, cup with moulded isolation bushing which passes through hanger box.
- .3 Type H3 - stable spring, elastomeric element, cup with moulded isolation bushing which passes through hanger box.
- .4 Performance: as required.

2.7 ACOUSTIC BARRIERS FOR ANCHORS AND GUIDES

- .1 Acoustic barriers: between pipe and support, consisting of 25 mm minimum thick heavy duty neoprene isolation material.

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 Install vibration isolation equipment in accordance with manufacturers instructions and adjust mountings to level equipment.
 - .2 Ensure piping, ducting and electrical connections to isolated equipment do not reduce system flexibility. Ensure that piping, conduit and ducting passage through walls and floors do not transmit vibrations. A maximum of 25 mm clearance shall be allowed between the penetrating element and the entire perimeter of the penetration. The clearance shall be packed with fiberglass and sealed with non-hardening mastic on both sides.
 - .3 Unless indicated otherwise, support piping connected to isolated equipment with spring mounts or spring hangers with 25 mm minimum static deflection as follows:
-

- .1 Up to NPS 4: first 3 points of support. NPS 5 to NPS 8: first 4 points of support. NPS 10 and Over: first 6 points of support.
- .2 First point of support: static deflection of twice deflection of isolated equipment, but not more than 50 mm.
- .3 All hangers are to be installed such that mounting rods and springs are axially aligned.
- .4 Where isolation is bolted to floor use vibration isolation rubber washers.
- .5 All bases shall be blocked and shimmed level so that all ductwork and piping connections can be made to a rigid system, at operating level, before the isolation adjustment is made. The clearance shall be checked by the Contractor to ensure that no scraps have been left to short circuit the vibration isolators. Ensure that there is no physical connection between isolated equipment and the building structure.

3.3 FIELD QUALITY CONTROL

- .1 Inspection and Certification:
 - .1 Experienced and competent sound and vibration testing professional engineer to take vibration measurement for HVAC systems after start up and TAB of systems to Section 23 05 93 - Testing, Adjusting and Balancing for HVAC.
 - .2 Take vibration measurements for all rotating equipment.
 - .3 Provide Departmental Representative with notice 24 h in advance of commencement of tests.
 - .4 Establish adequacy of equipment isolation and acceptability of noise levels in occupied areas and where appropriate, remedial recommendations (including sound curves).
 - .5 Submit complete report of test results including sound curves.

3.4 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

PART 1 - GENERAL

1.1 REFERENCES

- .1 Canadian Gas Association (CGA)
 - .1 CSA/CGA B149.1-05, Natural Gas and Propane Installation Code.
- .2 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-24.3-92, Identification of Piping Systems.
- .3 National Fire Protection Association (NFPA)
 - .1 NFPA 13-2015, Standard for the Installation of Sprinkler Systems.
 - .2 NFPA 14-2015, Standard for the Installation of Standpipe and Hose Systems.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Product Data.
- .2 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .3 Product data to include paint colour chips, other products specified in this section.
- .4 Samples:
 - .1 Submit samples in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Samples to include nameplates, labels, tags, lists of proposed legends.

1.3 QUALITY ASSURANCE

- .1 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.

1.4 DELIVERY, STORAGE, AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
 - .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.
-

- .2 Waste Management and Disposal:
 - .1 Construction/Demolition Waste Management and Disposal:
separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 MANUFACTURER'S EQUIPMENT NAMEPLATES

- .1 Metal or plastic laminate nameplate mechanically fastened to each piece of equipment by manufacturer.
- .2 Lettering and numbers raised or recessed.
- .3 Information to include, as appropriate:
 - .1 Equipment: manufacturer's name, model, size, serial number, capacity.
 - .2 Motor: voltage, Hz, phase, power factor, duty, frame size.

2.2 SYSTEM NAMEPLATES

- .1 Colours:
 - .1 Hazardous: red letters, white background.
 - .2 Elsewhere: black letters, white background (except where required otherwise by applicable codes).
 - .2 Construction:
 - .1 3 mm thick laminated plastic or white anodized aluminum, matte finish, with square corners, letters accurately aligned and machine engraved into core.
 - .3 Sizes:
 - .1 Conform to following table:
-

Size # mm	Sizes (mm)	No. of Lines	Height of Letters (mm)
1	10 x 50	1	3
2	13 x 75	1	5
3	13 x 75	2	3
4	20 x 100	1	8
5	20 x 100	2	5
6	20 x 200	1	8
7	25 x 125	1	12
8	25 x 125	2	8
9	35 x 200	1	20

.2 Use maximum of 25 letters/numbers per line.

.4 Locations:

.1 Terminal cabinets, control panels: use size #5.

.2 Equipment in Mechanical Rooms: use size #9.

2.3 PIPING SYSTEMS GOVERNED BY CODES

.1 Identification:

.1 Sprinklers: to NFPA 13.

.2 Standpipe and hose systems: to NFPA 14.

.3 Other fire protection systems: in accordance with applicable codes and standards, and in accordance with authority having jurisdiction.

2.4 IDENTIFICATION OF PIPING SYSTEMS

.1 Identify contents by background colour marking, pictogram (as necessary), legend; direction of flow by arrows. To CAN/CGSB 24.3 except where specified otherwise.

.2 Pictograms:

.1 Where required: Workplace Hazardous Materials Information System (WHMIS) regulations.

.3 Legend:

.1 Block capitals to sizes and colours listed in CAN/CGSB 24.3.

.4 Arrows showing direction of flow:

.1 Outside diameter of pipe or insulation less than 75 mm: 100 mm long x 50 mm high.

.2 Outside diameter of pipe or insulation 75 mm and greater: 150 mm long x 50 mm high.

.3 Use double-headed arrows where flow is reversible.

- .5 Extent of background colour marking:
 - .1 To full circumference of pipe or insulation.
 - .2 Length to accommodate pictogram, full length of legend and arrows.

- .6 Materials for background colour marking, legend, arrows:
 - .1 Pipes and tubing 20 mm and smaller: waterproof and heat-resistant pressure sensitive plastic marker tags.
 - .2 Other pipes: pressure sensitive vinyl with protective overcoating, waterproof contact adhesive undercoating, suitable for ambient of 100% RH and continuous operating temperature of 150 degrees C and intermittent temperature of 200 degrees C.

- .7 Colours and Legends:
 - .1 Where not listed, obtain direction from Departmental Representative.
 - .2 Colours for legends, arrows: to following table:

Background colour:	Legend arrows:
Yellow	BLACK
Green	WHITE
Red	WHITE

.3 Background colour marking and legends for piping systems:

Contents marking	Background colour	Legend
Domestic hot water supply	Green	DOM. HW SUPPLY
Domestic HWS recirculation	Green	DOM. HW CIRC
Domestic cold water supply	Green	DOM. CWS
Sanitary	Green	SAN
Plumbing vent	Green	SAN. VENT
Sprinklers	Red	SPRINKLERS
Heating Glycol Supply	Yellow	GLYCOL HEATING SUPPLY
Heating Glycol Return	Yellow	GLYCOL HEATING RETURN
Refrigeration Suction	Yellow	REF. SUCTION
Refrigeration Liquid	Yellow	REF. LIQUID
Nitrogen Gas	Yellow	NITROGEN

2.5 IDENTIFICATION DUCTWORK SYSTEMS

- .1 50 mm high stencilled letters and directional arrows 150 mm long x 50 mm high.
 - .2 Colours: black, or co-ordinated with base colour to ensure strong contrast.
-

2.6 VALVES, CONTROLLERS

- .1 Brass tags with 12 mm stamped identification data filled with black paint.
- .2 Include flow diagrams for each system, of approved size, showing charts and schedules with identification of each tagged item, valve type, service, function, normal position, location of tagged item.

2.7 CONTROLS COMPONENTS IDENTIFICATION

- .1 Identify all systems, equipment, components, controls, sensors with system nameplates specified in this section.
- .2 Inscriptions to include function and (where appropriate) fail-safe position.

2.8 LANGUAGE

- .1 Identification in English.

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 TIMING

- .1 Provide identification only after painting specified Section 09 91 99 - Painting has been completed.

3.3 INSTALLATION

- .1 Perform work in accordance with CAN/CGSB-24.3 except as specified otherwise.
 - .2 Provide ULC and or CSA registration plates as required by respective agency.
-

3.4 NAMEPLATES

- .1 Locations:
 - .1 In conspicuous location to facilitate easy reading and identification from operating floor.
- .2 Standoffs:
 - .1 Provide for nameplates on hot and/or insulated surfaces.
- .3 Protection:
 - .1 Do not paint, insulate or cover.

3.5 LOCATION OF IDENTIFICATION ON PIPING AND DUCTWORK SYSTEMS

- .1 On long straight runs in open areas in boiler rooms, equipment rooms, galleries, tunnels: at not more than 17 m intervals and more frequently if required to ensure that at least one is visible from any one viewpoint in operating areas and walking aisles.
 - .2 Adjacent to each change in direction.
 - .3 At least once in each small room through which piping or ductwork passes.
 - .4 On both sides of visual obstruction or where run is difficult to follow.
 - .5 On both sides of separations such as walls, floors, partitions.
 - .6 Where system is installed in pipe chases, ceiling spaces, galleries, confined spaces, at entry and exit points, and at access openings.
 - .7 At beginning and end points of each run and at each piece of equipment in run.
 - .8 At point immediately upstream of major manually operated or automatically controlled valves, and dampers. Where this is not possible, place identification as close as possible, preferably on upstream side.
 - .9 Identification easily and accurately readable from usual operating areas and from access points.
 - .1 Position of identification approximately at right angles to most convenient line of sight, considering operating positions, lighting conditions, risk of physical damage or injury and reduced visibility over time due to dust and dirt.
-

3.6 VALVES, CONTROLLERS

- .1 Valves and operating controllers, except at plumbing fixtures, radiation, or where in plain sight of equipment they serve: Secure tags with non-ferrous chains or closed "S" hooks.
- .2 Install one copy of flow diagrams, valve schedules mounted in frame behind non-glare glass where directed by Departmental Representative. Provide one copy (reduced in size if required) in each operating and maintenance manual.
- .3 Number valves in each system consecutively.

3.7 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

PART 1 - GENERAL

1.1 GENERAL

- .1 TAB means to test, adjust and balance to perform in accordance with requirements of Contract Documents and to do other work as specified in this section.

1.2 QUALIFICATIONS OF TAB PERSONNEL

- .1 Names of personnel it is proposed to perform TAB to be submitted to and approved by Departmental Representative within 90 days of award of contract.
- .2 Provide documentation confirming qualifications, successful experience.

1.3 PURPOSE OF TAB

- .1 Test to verify proper and safe operation, determine actual point of performance, evaluate qualitative and quantitative performance of equipment, systems and controls at design, average and low loads using actual or simulated loads
- .2 Adjust and regulate equipment and systems so as to meet specified performance requirements and to achieve specified interaction with other related systems under normal and emergency loads and operating conditions.
- .3 Balance systems and equipment to regulate flow rates to match load requirements over full operating ranges.

1.4 EXCEPTIONS

- .1 TAB of systems and equipment regulated by codes, standards to be to satisfaction of authority having jurisdiction.

1.5 CO-ORDINATION

- .1 Schedule time required for TAB (including repairs, re-testing) into project construction and completion schedule so as to ensure completion before acceptance of project.
 - .2 Do TAB of each system independently and subsequently, where interlocked with other systems, in unison with those systems.
-

1.6 PRE-TAB REVIEW

- .1 Review contract documents before project construction is started and confirm in writing to Departmental Representative adequacy of provisions for TAB and other aspects of design and installation pertinent to success of TAB.
- .2 Review specified standards and report to Departmental Representative in writing all proposed procedures which vary from standard.
- .3 During construction, co-ordinate location and installation of TAB devices, equipment, accessories, measurement ports and fittings.

1.7 START-UP

- .1 Follow start-up procedures as recommended by equipment manufacturer unless specified otherwise.
- .2 Follow special start-up procedures specified elsewhere in Divisions 22 and 23.

1.8 OPERATION OF SYSTEMS DURING TAB

- .1 Operate systems for length of time required for TAB and as required by Departmental Representative for verification of TAB reports.

1.9 START OF TAB

- .1 Notify Departmental Representative 7 days prior to start of TAB.
 - .2 Start TAB when building is essentially completed, including:
 - .3 Installation of ceilings, doors, windows, other construction affecting TAB.
 - .4 Application of weatherstripping, sealing, caulking.
 - .5 All pressure, leakage, other tests specified elsewhere Divisions 22 and 23.
 - .6 All provisions for TAB installed and operational.
 - .7 Start-up, verification for proper, normal and safe operation of mechanical and associated electrical and control systems affecting TAB including but not limited to:
-

- .1 Proper thermal overload protection in place for electrical equipment.
- .2 Air systems:
 - .1 Filters in place, clean.
 - .2 Duct systems clean.
 - .3 Ducts, air shafts, ceiling plenums are airtight to within specified tolerances.
 - .4 Correct fan rotation.
 - .5 Fire, smoke, volume control dampers installed and open.
 - .6 Coil fins combed, clean.
 - .7 Access doors, installed, closed.
 - .8 Outlets installed, volume control dampers open.
- .3 Liquid systems:
 - .1 Flushed, filled, vented.
 - .2 Correct pump rotation.
 - .3 Strainers in place, baskets clean.
 - .4 Isolating and balancing valves installed, open.
 - .5 Calibrated balancing valves installed, at factory settings.

1.10 APPLICATION TOLERANCES

- .1 Do TAB to following tolerances of design values:
 - .1 HVAC systems: plus 5%, minus 5%.

1.11 ACCURACY TOLERANCES

- .1 Measured values to be accurate to within plus or minus 2% of actual values.

1.12 INSTRUMENTS

- .1 Prior to TAB, submit to Departmental Representative list of instruments to be used together with serial numbers.
- .2 Calibrate in accordance with requirements of most stringent of referenced standard for either applicable system or HVAC system.
- .3 Calibrate within 3 months of TAB. Provide certificate of calibration to Departmental Representative.

1.13 SUBMITTALS

- .1 Submit, prior to commencement of TAB:

- .2 Proposed methodology and procedures for performing TAB if different from referenced standard.

1.14 PRELIMINARY TAB REPORT

- .1 Submit for checking and approval of Departmental Representative, prior to submission of formal TAB report, sample of rough TAB sheets. Include:
 - .1 Details of instruments used.
 - .2 Details of TAB procedures employed.
 - .3 Calculations procedures.
 - .4 Summaries.

1.15 TAB REPORT

- .1 Format to be in accordance with referenced standard.
- .2 TAB report to show results in SI units and to include:
 - .1 Project record drawings.
 - .2 System schematics.
- .3 Submit 6 copies of TAB Report to Departmental Representative for verification and approval, in English in D-ring binders, complete with index tabs.

1.16 VERIFICATION

- .1 Reported results subject to verification by Departmental Representative.
- .2 Provide manpower and instrumentation to verify up to 30 % of reported results.
- .3 Number and location of verified results to be at discretion of Departmental Representative.
- .4 Bear costs to repeat TAB as required to satisfaction of Departmental Representative.

1.17 SETTINGS

- .1 After TAB is completed to satisfaction of Departmental Representative, replace drive guards, close access doors, lock devices in set positions, ensure sensors are at required settings.
-

- .2 Permanently mark settings to allow restoration at any time during life of facility. Markings not to be eradicated or covered in any way.

1.18 COMPLETION OF TAB

- .1 TAB to be considered complete when final TAB Report received and approved by Departmental Representative.

1.19 AIR SYSTEMS

- .1 Standard: TAB to be to most stringent of this section or TAB standards of AABC or NEBB.
- .2 Do TAB of systems, equipment, components, controls specified in Divisions 22 and 23.
- .3 Qualifications: personnel performing TAB to be current member in good standing of AABC or NEBB.
- .4 Quality assurance: Perform TAB under direction of supervisor qualified by AABC or NEBB.
- .5 Measurements: to include, but not limited to, following as appropriate for systems, equipment, components, controls: air velocity, static pressure, flow rate, pressure drop (or loss), temperatures (dry bulb, wet bulb, dewpoint), duct cross-sectional area, RPM, electrical power, voltage, noise, vibration.
- .6 Locations of equipment measurements: To include, but not be limited to, following as appropriate:
 - .1 Inlet and outlet of dampers, filter, coil, fan, other equipment causing changes in conditions.
 - .2 At controllers, controlled device.
- .7 Locations of systems measurements to include, but not be limited to, following as appropriate: Main ducts, main branch, sub-branch, run-out (or grille, register or diffuser).

1.20 OTHER SYSTEMS

- .1 Plumbing systems:
 - .1 TAB procedures:
 - .1 Flush valves: adjust to suit project pressure conditions.
 - .2 Pressure booster systems: test for capacity and pressures under all conditions and at all times.
-

.3 Pumped sanitary and storm water systems: test for proper operation at all possible flow rates.

.2 Refrigeration systems forming part of HVAC systems.

.3 Sprinkler system in accordance with authority having jurisdiction and ANSI/NFPA 13-2002.

1.21 OTHER TAB REQUIREMENTS

.1 General requirements applicable to work specified this paragraph:

.1 Qualifications of TAB personnel: as for air systems specified this section.

.2 Quality assurance: as for air systems specified this section.

PART 2 - PRODUCTS

2.1 NOT USED

.1 Not used.

PART 3 - EXECUTION

3.1 NOT USED

.1 Not used.

- .6 Witnessed certification of results.
- .3 Include test reports in final TAB report.
- .4 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .5 Instructions: submit manufacturer's installation instructions.
- .6 Manufacturer's field reports specified.

PART 2 - PRODUCTS

2.1 TEST INSTRUMENTS

- .1 Test apparatus to include:
 - .1 Fan capable of producing required static pressure.
 - .2 Duct section with calibrated orifice plate mounted and accurately located pressure taps.
 - .3 Flow measuring instrument compatible with the orifice plate.
 - .4 Calibration curves for orifice plates used.
 - .5 Flexible duct for connecting to ductwork under test.
 - .6 Smoke bombs for visual inspections.
- .2 Test apparatus: accurate to within +/- 3 % of flow rate and pressure.
- .3 Submit details of test instruments to be used to Departmental Representative at least three months before anticipated start date.
- .4 Test instruments: calibrated and certificate of calibration deposited with Departmental Representative no more than 28 days before start of tests.
- .5 Re-calibrated every six months thereafter.

2.2 EQUIPMENT LEAKAGE TOLERANCES

- .1 Equipment and system components such as VAV boxes, duct heating leakage: 2%.
-

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 TEST PROCEDURES

- .1 Maximum lengths of ducts to be tested consistent with capacity of test equipment.
- .2 Section of duct to be tested to include:
 - .1 Fittings, branch ducts, tap-ins.
- .3 Repeat tests until specified pressures are attained. Bear costs for repairs and repetition to tests.
- .4 Base partial system leakage calculations on SMACNA HVAC Air Duct Leakage Test Manual.
- .5 Seal leaks that can be heard or felt, regardless of their contribution to total leakage.

3.3 SITE TOLERANCES

- .1 System leakage tolerances specified are stated as percentage of total flow rate handled by system. Pro-rate specified system leakage tolerances. Leakage for sections of duct systems: not to exceed total allowable leakage.
- .2 Leakage tests on following systems not to exceed specified leakage rates.
 - .1 Small duct systems up to 250 Pa: leakage 2%.
 - .2 Large low pressure duct systems up to 500 Pa: leakage 2%.
- .3 Evaluation of test results to use surface area of duct and pressure in duct as basic parameters.

3.4 TESTING

- .1 Test ducts before installation of insulation or other forms of concealment.
 - .2 Test after seals have cured.
-

- .3 Test when ambient temperature will not affect effectiveness of seals, and gaskets.

3.5 FIELD QUALITY CONTROL

- .1 Performance Verification:
 - .1 Departmental Representative to witness tests and to verify reported results.
 - .2 To be certified by same TAB agency approved by Departmental Representative to undertake TAB on this project.

3.6 CLEANING

- .1 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

PART 1 - GENERAL1.1 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
- .3 Section 23 05 29 - Hangers and Supports for HVAC Piping and Equipment.

1.2 REFERENCES

- .1 American Society of Heating, Refrigeration and Air Conditioning Engineers (ASHRAE)
 - .1 ANSI/ASHRAE/IESNA 90.1-2013, SI; Energy Standard for Buildings Except Low-Rise Residential Buildings.
 - .2 American Society for Testing and Materials International, (ASTM)
 - .1 ASTM B 209M-14, Specification for Aluminum and Aluminum Alloy Sheet and Plate (Metric).
 - .2 ASTM C 335-10e1, Test Method for Steady State Heat Transfer Properties of Horizontal Pipe Insulation.
 - .3 ASTM C 411-11, Test Method for Hot-Surface Performance of High-Temperature Thermal Insulation.
 - .4 ASTM C 449/C 449-07(R2013), Standard Specification for Mineral Fiber-Hydraulic-Setting Thermal Insulating and Finishing Cement.
 - .5 ASTM C 547-15, Specification for Mineral Fiber Pipe Insulation.
 - .6 ASTM C 553-13, Specification for Mineral Fiber Blanket Thermal Insulation for Commercial and Industrial Applications.
 - .7 ASTM C 612-14, Specification for Mineral Fiber Block and Board Thermal Insulation.
 - .8 ASTM C 795-08(R2013), Specification for Thermal Insulation for Use with Austenitic Stainless Steel.
 - .9 ASTM C 921-10(R2015), Standard Specification for Thermal Insulation for Use in Contact with Austenitic Stainless Steel.
 - .3 Canadian General Standards Board (CGSB)
 - .1 CGSB 51-GP-52MA, Vapour Barrier, Jacket and Facing Material for Pipe, Duct and Equipment Thermal Insulation.
 - .4 Thermal Insulation Association of Canada (TIAC): National Insulation Standards (R1999).
 - .5 Underwriters Laboratories of Canada (ULC)
-

.1 CAN/ULC-S102-11, Surface Burning Characteristics of Building Materials and Assemblies.

.2 CAN/ULC-S701-05, Thermal Insulation Polyotrene, Boards and Pipe Covering.

1.3 DEFINITIONS

.1 For purposes of this section:

.1 "CONCEALED" - insulated mechanical services and equipment in suspended ceilings and non-accessible chases and furred-in spaces.

.2 "EXPOSED" - will mean "not concealed" as defined herein.

.3 Insulation systems - insulation material, fasteners, jackets, and other accessories.

.2 TIAC Codes:

.1 CRD: Code Round Ductwork,

.2 CRF: Code Rectangular Finish.

1.4 SHOP DRAWINGS

.1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.

.2 Submit for approval manufacturer's catalogue literature related to installation, fabrication for duct jointing recommendations.

1.5 MANUFACTURERS' INSTRUCTIONS

.1 Submit manufacturer's installation instructions in accordance with Section 01 33 00 - Submittal Procedures.

.2 Installation instructions to include procedures used, and installation standards achieved.

1.6 QUALIFICATIONS

.1 Installer: specialist in performing work of this section, and member of TIAC.

1.7 DELIVERY, STORAGE AND HANDLING

.1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.

- .2 Protect from weather and construction traffic.
- .3 Protect against damage from any source.
- .4 Store at temperatures and conditions recommended by manufacturer.

1.8 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management And Disposal.

PART 2 - PRODUCTS

2.1 FIRE AND SMOKE RATING

- .1 In accordance with CAN/ULC-S102:
 - .1 Maximum flame spread rating: 25.
 - .2 Maximum smoke developed rating: 50.

2.2 INSULATION

- .1 Mineral fibre: as specified includes glass fibre, rock wool, slag wool.
- .2 Thermal conductivity ("k" factor) not to exceed specified values at 24° C mean temperature when tested in accordance with ASTM C 335.
- .3 TIAC Code C-1: Rigid mineral fibre board to ASTM C 612, with factory applied vapour retarder jacket to CGSB 51-GP-52Ma (as scheduled in PART 3 of this Section).
- .4 TIAC Code C-2: Mineral fibre blanket to ASTM C 553 faced with factory applied vapour retarder jacket to CGSB 51-GP-52Ma (as scheduled in PART 3 of this section).
 - .1 Mineral fibre: to ASTM C 553.
 - .2 Jacket: to CGSB 51-GP-52Ma.
 - .3 Maximum "k" factor: to ASTM C 553.

2.3 JACKETS

- .1 Canvas:
 - .1 220 gm/m² cotton, plain weave, treated with dilute fire retardant lagging adhesive to ASTM C 921.
-

- .2 Lagging adhesive: Compatible with insulation.

2.4 ACCESSORIES

- .1 Vapour retarder lap adhesive:
 - .1 Water based, fire retardant type, compatible with insulation.
- .2 Indoor Vapour Retarder Finish:
 - .1 Vinyl emulsion type acrylic, compatible with insulation.
- .3 Insulating Cement: hydraulic setting on mineral wool, to ASTM C449.
- .4 ULC Listed Canvas Jacket:
 - .1 220 gm/m² cotton, plain weave, treated with dilute fire retardant lagging adhesive to ASTM C 921.
- .5 Outdoor Vapour Retarder Mastic:
 - .1 Vinyl emulsion type acrylic, compatible with insulation.
 - .2 Reinforcing fabric: Fibrous glass, untreated 305 g/m².
- .6 Tape: self-adhesive, aluminum, plain, 50 mm wide minimum.
- .7 Contact adhesive: quick-setting
- .8 Canvas adhesive: washable.
- .9 Tie wire: 1.5 mm stainless steel.
- .10 Banding: 12 mm wide, 0.5 mm thick stainless steel.
- .11 Facing: 25 mm stainless steel hexagonal wire mesh stitched on one face.
- .12 Fasteners: 2 mm diameter pins with 35 mm square clips, length to suit thickness of insulation.
- .13 Surfaces clean, dry, free from foreign material.

PART 3 - EXECUTION

3.1 PRE-INSTALLATION REQUIREMENTS

- .1 Pressure testing of ductwork systems complete, witnessed and certified.
-

- .2 Surfaces clean, dry, free from foreign material.

3.2 INSTALLATION

- .1 Install in accordance with TIAC National Standards.
- .2 Apply materials in accordance with manufacturers instructions and as indicated.
- .3 Use two layers with staggered joints when required nominal thickness exceeds 75 mm.
- .4 Maintain uninterrupted continuity and integrity of vapour retarder jacket and finishes.
.1 Hangers, supports to be outside vapour retarder jacket.
- .5 Supports, Hangers in accordance with Section 23 05 29 - Hangers and Supports for HVAC Piping and Equipment.
.1 Apply high compressive strength insulation where insulation may be compressed by weight of ductwork.
- .6 Fasteners: At 300 mm oc in horizontal and vertical directions, maximum two rows each side.

3.3 DUCTWORK INSULATION SCHEDULE

- .1 Insulation types and thicknesses: Conform to following table:

	TIAC Code	Vapour Retarder	Thickness (mm)
Supply, return and exhaust ducts exposed in space			none
Exhaust duct between dampers and louvres or outside vent	C-1	no	50
Round Warm Air	C-1	no	25

Ducts

.2 Finishes: conform to following table:

	Rectangular	Round
Indoor concealed	none	none
Indoor exposed	Canvas	Canvas

PART 1 - GENERAL

1.1 REFERENCES

- .1 American Society of Heating, Refrigeration and Air Conditioning Engineers (ASHRAE)
 - .1 ASHRAE Standard 90.1-15, Energy Standard for Buildings Except Low-Rise Residential Buildings (IESNA co-sponsored; ANSI approved; Continuous Maintenance Standard).

 - .2 American Society for Testing and Materials International (ASTM)
 - .1 ASTM B209M-14, Standard Specification for Aluminum and Aluminum Alloy Sheet and Plate Metric.
 - .2 ASTM C335-10e1, Standard Test Method for Steady State Heat Transfer properties of Horizontal Pipe Insulation.
 - .3 ASTM C411-05, Standard Test Method for Hot-Surface Performance of High-Temperature Thermal Insulation.
 - .4 ASTM C449/C449M-00, Standard Specification for Mineral Fiber-Hydraulic-Setting Thermal Insulating and Finishing Cement.
 - .5 ASTM C533-09, Calcium Silicate Block and Pipe Thermal Insulation.
 - .6 ASTM C547e1, Mineral Fiber Pipe Insulation.
 - .7 ASTM C795-08, Standard Specification for Thermal Insulation for Use in Contact With Austenitic Stainless Steel.
 - .8 ASTM C921-10(R2015), Standard Practice for Determining the Properties of Jacketing Materials for Thermal Insulation.

 - .3 Canadian General Standards Board (CGSB)
 - .1 CGSB 51-GP-52Ma, Vapour Barrier, Jacket and Facing Material for Pipe, Duct and Equipment Thermal Insulation.
 - .2 CAN/CGSB-51.53-95, Poly (Vinyl Chloride) Jacketing Sheet, for Insulated Pipes, Vessels and Round Ducts.

 - .4 Department of Justice Canada (Jus)
 - .1 Canadian Environmental Assessment Act (CEAA), 1995, C.37.
 - .2 Canadian Environmental Protection Act (CEPA), 1999, c.33.
 - .3 Transportation of Dangerous Goods Act (TDGA), 1992, C.34.

 - .5 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).

 - .6 Manufacturer's Trade Associations
 - .1 Thermal Insulation Association of Canada (TIAC): National Insulation Standards (Revised 2004).

 - .7 Underwriters' Laboratories of Canada (ULC)
-

- .1 CAN/ULC-S102-10, Surface Burning Characteristics of Building Materials and Assemblies.
- .2 CAN/ULC-S701-11, Thermal Insulation, Polystyrene, Boards and Pipe Covering.
- .3 CAN/ULC-S702-2014, Thermal Insulation, Mineral Fibre, for Buildings.
- .4 CAN/ULC-S702.2-2010, Thermal Insulation, Mineral Fibre, for Buildings, Part 2: Application Guidelines.

1.2 DEFINITIONS

- .1 For purposes of this section:
 - .1 "CONCEALED" - insulated mechanical services in suspended ceilings non-accessible chases, furred-in spaces, and tunnels or trenches.
 - .2 "EXPOSED" - will mean "not concealed" as specified.
- .2 TIAC ss:
 - .1 CRF: Code Rectangular Finish.
 - .2 CPF: Code Piping Finish.

1.3 SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 00 33 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
 - .1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.
 - .3 Shop Drawings:
 - .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Shop drawings: submit drawings stamped and signed by Professional Engineer registered or licensed in Province of Nova Scotia, Canada.
 - .4 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
-

.2 Instructions: submit manufacturer's installation instructions.

1.4 QUALITY ASSURANCE

- .1 Qualifications:
- .2 Installer: specialist in performing work of this Section, and qualified to standards member of TIAC.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with manufacturer's written instructions and Section 01 61 00 - Common Product Requirements.
 - .2 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .2 Storage and Protection:
 - .1 Protect from weather, construction traffic.
 - .2 Protect against damage.
 - .3 Store at temperatures and conditions required by manufacturer.
- .3 Waste Management and Disposal:
 - .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 FIRE AND SMOKE RATING

- .1 In accordance with CAN/ULC-S102.
 - .1 Maximum flame spread rating: 25.
 - .2 Maximum smoke developed rating: 50

2.2 INSULATION

- .1 Mineral fibre specified includes glass fibre, rock wool, slag wool.
-

- .2 Thermal conductivity ("k" factor) not to exceed specified values at 24 degrees C mean temperature when tested in accordance with ASTM C 335.
- .3 TIAC Code A-1: rigid moulded mineral fibre without factory applied vapour retarder jacket.
 - .1 Mineral fibre: to CAN/ULC-S702.
 - .2 Maximum "k" factor: to CAN/ULC-S702.
- .4 TIAC Code A-3: rigid moulded mineral fibre with factory applied vapour retarder jacket.
 - .1 Mineral fibre: to CAN/ULC-S702.
 - .2 Jacket: to CGSB 51-GP-52Ma.
 - .3 Maximum "k" factor: to CAN/ULC-S702.
- .5 TIAC Code C-2: mineral fibre blanket faced with factory applied vapour retarder jacket (as scheduled in PART 3 of this section).
 - .1 Mineral fibre: to CAN/ULC-S702.
 - .2 Jacket: to CGSB 51-GP-52Ma.
 - .3 Maximum "k" factor: to CAN/ULC-S702.
- .6 TIAC Code A-6: flexible unicellular tubular elastomer.
 - .1 Insulation: with vapour retarder jacket.
 - .2 Jacket: to CGSB 51-GP-52Ma.
 - .3 Maximum "k" factor: standard of acceptance: Armaflex.
 - .4 Certified by manufacturer: free of potential stress corrosion cracking corrodants.

2.3 INSULATION SECUREMENT

- .1 Tape: self-adhesive, aluminum, plain reinforced, 50 mm wide minimum.
- .2 Contact adhesive: quick setting.
- .3 Canvas adhesive: washable.
- .4 Tie wire: 1.5 mm diameter stainless steel.
- .5 Bands: stainless steel, 19 mm wide, 0.5 mm thick.

2.4 CEMENT

- .1 Thermal insulating and finishing cement:
 - .1 Hydraulic setting or air drying on mineral wool, to ASTM C449/C449M.
-

2.5 VAPOUR RETARDER LAP ADHESIVE

- .1 Water based, fire retardant type, compatible with insulation.

2.6 INDOOR VAPOUR RETARDER FINISH

- .1 Vinyl emulsion type acrylic, compatible with insulation.

2.7 OUTDOOR VAPOUR RETARDER FINISH

- .1 Vinyl emulsion type acrylic, compatible with insulation.
- .2 Reinforcing fabric: fibrous glass, untreated 305 g/m².

2.8 JACKETS

- .1 Polyvinyl Chloride (PVC):
 - .1 One-piece moulded type and sheet to CAN/CGSB-51.23 with pre-formed shapes as required.
 - .2 Colours: to match adjacent finish paint by Departmental Representative.
 - .3 Minimum service temperatures: -20 degrees C.
 - .4 Maximum service temperature: 65 degrees C.
 - .5 Moisture vapour transmission: 0.02 perm.
 - .6 Thickness: 0.5 mm.
 - .7 Fastenings:
 - .1 Use solvent weld adhesive compatible with insulation to seal laps and joints.
 - .2 Tacks.
 - .3 Pressure sensitive vinyl tape of matching colour.
 - .8 Special requirements:
 - .1 Outdoor: UV rated material at least 0.5 mm thick.
 - .2 Canvas:
 - .1 220 and 120 gm/m² cotton, plain weave, treated with dilute fire retardant lagging adhesive to ASTM C921.
 - .2 Lagging adhesive: compatible with insulation.
 - .3 Aluminum:
 - .1 To ASTM B 209.
 - .2 Thickness: 0.5 mm sheet.
 - .3 Finish: stucco.
 - .4 Joining: longitudinal and circumferential slip joints with 50 mm sheeet.
 - .5 Fittings: 0.5 mm thick die-shaped fitting covers with factory-attached protective liner.
-

- .6 Metal jacket banding and mechanical seals: stainless steel, 19 mm wide, 0.5 mm thick 300 mm spacing.
- .4 Stainless Steel:
 - .1 Type: 304 or 316.
 - .2 Thickness: 0.25 mm.
 - .3 Finish: corrugated.
 - .4 Joining: longitudinal and circumferential slip joints with 50 mm sheeet.
 - .5 Fittings: 0.5 mm thick die-shaped fitting covers with factory-attached protective liner.
 - .6 Metal jacket banding and mechanical seals: stainless steel, 19 mm wide, 0.5 mm thick at 300 mm spacing.

PART 3 - PRODUCTS

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 PRE-INSTALLATION REQUIREMENT

- .1 Pressure testing of piping systems and adjacent equipment to be complete, witnessed and certified.
- .2 Surfaces clean, dry, free from foreign material.

3.3 INSTALLATION

- .1 Install in accordance with TIAC National Standards.
 - .2 Apply materials in accordance with manufacturers instructions and this specification.
 - .3 Use two layers with staggered joints when required nominal wall thickness exceeds 75 mm.
 - .4 Maintain uninterrupted continuity and integrity of vapour retarder jacket and finishes.
 - .1 Install hangers, supports outside vapour retarder jacket.
 - .5 Supports, Hangers:
-

.1 Apply high compressive strength insulation, suitable for service, at oversized saddles and shoes where insulation saddles have not been provided.

3.4 REMOVABLE, PRE-FABRICATED, INSULATION AND ENCLOSURES

- .1 Application: at expansion joints, valves, primary flow measuring elements flanges and unions at equipment.
- .2 Design: to permit movement of expansion joint and to permit periodic removal and replacement without damage to adjacent insulation.
- .3 Insulation:
 - .1 Insulation, fastenings and finishes: same as system.
 - .2 Jacket: aluminum, SS, PVC or high temperature fabric consistent with system.

3.5 INSTALLATION OF ELASTOMERIC INSULATION

- .1 Insulation to remain dry. Overlaps to manufacturers instructions. Ensure tight joints.
- .2 Provide vapour retarder as recommended by manufacturer.

3.6 PIPING INSULATION SCHEDULES

- .1 Includes valves, valve bonnets, strainers, flanges and fittings unless otherwise specified.
 - .2 TIAC Code: A-1.
 - .1 Securements: SS wire bands, Tape at 300 mm on centre.
 - .2 Seals: lap seal adhesive, lagging adhesive. Insulation: TIAC Code 1501-H.
 - .3 TIAC Code: A-3.
 - .1 Securements: SS wire bands, Tape at 300 mm on centre.
 - .2 Seals: VR lap seal adhesive, VR lagging adhesive. Insulation: TIA Code: 1501-C.
 - .4 TIAC Code: A-6.
 - .1 Insulation securements: as recommended by manufacturer.
 - .2 Seals: lap seal adhesive, lagging adhesive.
 - .3 Installation: TIAC Code:.
 - .5 TIAC Code: C-2 with without vapour retarder jacket.
 - .1 Insulation securements: as recommended by manufacturer.
-

.2 Seals: lap seal adhesive, lagging adhesive. Insulation:
TIAC Code: 1501-C.

.6 TIAC Code: A-2.

.1 Insulation securements: as recommended by manufacturer.

.2 Seals: lap seal adhesive, lagging adhesive. Installation:
TIAC Code: 1501-H.

.7 Thickness of insulation as listed in following table.

.1 Run-outs to individual units and equipment not exceeding
4000 mm long.

.2 Do not insulate exposed runouts to plumbing fixtures,
chrome plated piping, valves, fittings.

Appli- cation	Temp degrees C	TIAC code	Pipe sizes (NPS) and insulation thickness (mm)					
			Run out	to 1	1 1/4 to 2	2 1/2 to 4	5 to 6	8 & over
Domestic hot water supply and recirc, tempered water		A-1	25	25	25	38	38	38
Domestic cold water		A-3	25	25	25	25	25	25
Chilled Glycol		A-3	25	25	38	38	38	38
Glycol Heating		A-6	25	25	25	38	38	38
Refrigerant suction and discharge		A-6	25	25	38	38	38	38

.8 Finishes:

.1 Exposed indoors: PVC jacket.

.2 Exposed in mechanical rooms: PVC jacket except aluminum or
SS on steam, condensate and diesel exhaust.

.3 Concealed, indoors: canvas on valves, fittings. No further
finish.

.4 Use vapour retarder jacket on TIAC code A-3 insulation
compatible with insulation.

.5 Finish attachments: SS screws bands, at 150 mm on centre.
Seals: wing closed.

.6 Insulation: to appropriate TIAC code CRF/1 through CPF/5.

.7 Outdoors: Water-Proof SS or PVC Jacket with UV inhibitor
(White).

3.7 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

PART 1 - GENERAL

1.1 POTABLE WATER SYSTEMS

- .1 When cleaning is completed and system filled:
 - .1 Verify performance of equipment and systems as specified elsewhere in Division 22.
 - .2 Check for proper operation of water hammer arrestors. Run one outlet for 10 seconds, then shut of water immediately. If water hammer occurs, replace water hammer arrestor or recharge air chambers. Repeat for each outlet and flush valve.
 - .3 Confirm water quality consistent with supply standards, verifying that no residuals remain resulting from flushing and/or cleaning.

1.2 WET AND DRY PIPE SPRINKLER SYSTEM, STANDPIPE AND HOSE SYSTEMS

- .1 Cleaning, testing, start-up, performance verification of equipment, systems, components, and devices is specified elsewhere in Division 21.
- .2 Verification of controls, detection devices, alarm devices is specified Division 26.
- .3 Verify operation of interlocks between HVAC systems and fire alarm systems.

1.3 SANITARY AND STORM DRAINAGE SYSTEMS

- .1 Buried systems: perform tests prior to back-filling. Perform hydraulic tests to verify grades and freedom from obstructions.
- .2 Ensure that traps are fully and permanently primed.
- .3 Ensure that fixtures are properly anchored, connected to system.
- .4 Operate each fixture to verify drainage and no leakage.
- .5 Cleanouts: refer to Section 22 42 01 - Plumbing Specialties and Accessories.

1.4 REPORTS

- .1 In accordance with Section 01 91 13 - General Commissioning (Cx) Requirements: Reports, supplemented as specified herein.
-

AAFC Research Centre

Performance

Section 23 08 01

Micro Winery

Verification

Page 2

AAFC Kentville Research Centre

Mechanical Piping

Kentville, Nova Scotia

Systems

Job No. R.083308.001

PART 2 - PRODUCTS

2.1 NOT USED

.1 Not used.

PART 3 - EXECUTION

3.1 NOT USED

.1 Not used.

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Section 42 20 00 - Process Heating and Cooling Equipment.

1.2 REFERENCES

- .1 American Society for Testing and Materials International (ASTM)
 - .1 ASTM E 202-10, Standard Test Methods for Analysis of Ethylene Glycols and Propylene Glycols.
- .2 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).

1.3 SUBMITTALS

- .1 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
- .2 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Instructions: submit manufacturer's installation instructions.

PART 2 - PRODUCTS

2.1 CLEANING SOLUTIONS

- .1 Tri-sodium phosphate: 0.40 kg per 100 L water in system.
 - .2 Sodium percarbonate: 0.40 kg per 100 L water in system.
 - .3 Low-foaming detergent: 0.01 kg per 100 L water in system.
-

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- 1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 CLEANING HYDRONIC SYSTEMS

- .1 Timing: systems operational, hydrostatically tested and with safety devices functional, before cleaning is carried out.
 - .2 Cleaning Agency:
 - .1 Retain qualified water treatment specialist to perform system cleaning.
 - .3 Install instrumentation such as flow meters, orifice plates, pitot tubes, flow metering valves only after cleaning is certified as complete by water treatment specialist.
 - .4 Cleaning procedures:
 - .1 Provide detailed report outlining proposed cleaning procedures at least 4 weeks prior to proposed starting date. Report to include:
 - .1 Cleaning procedures, flow rates, elapsed time.
 - .2 Chemicals and concentrations used.
 - .3 Inhibitors and concentrations.
 - .4 Specific requirements for completion of work.
 - .5 Special precautions for protecting piping system materials and components.
 - .6 Complete analysis of water used to ensure water will not damage systems or equipment.
 - .5 Conditions at time of cleaning of systems:
 - .1 Systems: free from construction debris, dirt and other foreign material.
 - .2 Control valves: operational, fully open to ensure that terminal units can be cleaned properly.
 - .3 Strainers: clean prior to initial fill.
 - .4 Install temporary filters on pumps not equipped with permanent filters.
 - .5 Install pressure gauges on strainers to detect plugging.
 - .6 Report on Completion of Cleaning:
 - .1 When cleaning is completed, submit report, complete with certificate of compliance with specifications of cleaning component supplier. The report is to show that the cleaner is no
-

longer in the piping system and it is acceptable to add the inhibitor.

.7 Hydronic Systems:

- .1 Fill system with water, ensure air is vented from system.
- .2 Fill expansion tanks 1/3 to 1/2 full, charge system with compressed air to at least 35 kPa (does not apply to diaphragm type expansion tanks).
- .3 Use water metre to record volume of water in system to +/- 0.5%.
- .4 Add chemicals under direct supervision of chemical treatment supplier.
- .5 Closed loop systems: circulate system cleaner at 60 degrees C for at least 36 h. Drain as quickly as possible. Refill with water and inhibitors. Test concentrations and adjust to recommended levels.
- .6 Flush velocity in system mains and branches to ensure removal of debris. System pumps may be used for circulating cleaning solution provided that velocities are adequate.
- .7 Add chemical solution to system.
- .8 Establish circulation, raise temperature slowly to maximum design 82 °C minimum. Circulate for 12 h, ensuring flow in all circuits. Remove heat, continue to circulate until temperature is below 38 degrees C. Drain as quickly as possible. Refill with clean water. Circulate for 6 h at design temperature. Drain and repeat procedures specified above. Flush through low point drains in system. Refill with clean water testing for residual cleaner. The cleaner is to be clear from the system before the inhibitor is to be added.

3.3 START-UP OF HYDRONIC SYSTEMS

- .1 After cleaning is completed and system is filled:
 - .1 Establish circulation and expansion tank level, set pressure controls.
 - .2 Ensure air is removed.
 - .3 Check pumps to be free from air, debris, possibility of cavitation when system is at design temperature.
 - .4 Dismantle system pumps used for cleaning, inspect, replace worn parts, install new gaskets and new set of seals.
 - .5 Clean out strainers repeatedly until system is clean.
 - .6 Check water level in expansion tank with cold water with circulating pumps OFF and again with pumps ON.
 - .7 Repeat with water at design temperature.
 - .8 Check pressurization to ensure proper operation and to prevent water hammer, flashing, cavitation. Eliminate water hammer and other noises.
 - .9 Bring system up to design temperature and pressure slowly over
-

a 48 hour period.

.10 Perform TAB as specified in Section 23 05 93 - Testing, Adjusting and Balancing for HVAC.

.11 Adjust pipe supports, hangers, springs as necessary.

.12 Monitor pipe movement, performance of expansion joints, loops, guides, anchors.

.13 If sliding type expansion joints bind or if bellows type expansion joints flex incorrectly, shut down system, re-align, repeat start-up procedures.

.14 Re-tighten bolts using torque wrench, to compensate for heat-caused relaxation. Repeat several times during commissioning.

.15 Check operation of drain valves.

.16 Adjust valve stem packing's as systems settle down.

.17 Fully open balancing valves (except those that are factory-set).

.18 Check operation of over-temperature protection devices on circulating pumps.

.19 Adjust alignment of piping at pumps to ensure flexibility, adequacy of pipe movement, absence of noise or vibration transmission.

3.4 CLEANING

.1 Proceed in accordance with Section 01 74 11 - Cleaning.

.2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

PART 1 - GENERAL

1.1 RELATED REQUIREMENTS

- .1 Section 23 55 01 - Duct Heaters.
- .2 Section 23 81 23 - Ductless Split-System Air Conditioners.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for electric and electronic control system for HVAC and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.

1.3 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
 - .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
 - .3 Storage and Handling Requirements:
 - .1 Store materials off ground indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect electric and electronic control systems from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.
 - .4 Packaging Waste Management: in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
-

PART 2 - PRODUCTS

2.1 THERMOSTAT (LOW VOLTAGE)

- .1 Low voltage wall thermostat:
 - .1 For use on 24 V circuit at 1.5 A capacity.
 - .2 With heat anticipator adjustable 0.1 to 1.2 A.
 - .3 Temperature setting range: 10 degrees C to 25 degrees C.
 - .4 Without sub-base.

2.2 AUXILIARY CONTROL DEVICES

- .1 Control Transformers.
 - .1 Control Transformers: 60 Hz, primary voltage to suit supply, 120 V single phase secondary, VA rating to suit load plus 20% margin.
 - .2 DC Power supplies: To controls vendor requirements, CSA approved.

2.3 GAS DETECTION SYSTEM

- .1 General: Gas detection system consisting of multi-zone central monitoring and alarm panel and multiple remote sensors for Carbon Dioxide and Oxygen
 - .2 Gas Detection Panel:
 - .1 Enclosure: steel, wall-mounted NEMA 1 enclosure 210 mm high x 210 mm wide x 102 mm deep.
 - .2 Status readouts: LED display indicating the following:
 - .1 Power (green)
 - .2 Warning (amber)
 - .3 Alarm (red)
 - .4 Sensor Status: Normal (green), Abnormal (red)
 - .3 Digital readouts: 4-digit LED display, indicating channel # and concentration.
 - .4 Inputs: minimum two CO2 sensor channels and five O2 sensor channels, compatible with sensor output signals.
 - .5 Outputs:
 - .1 4-20 mA warning signal and alarm signal to minimum eight remote alarms.
 - .6 Electrical requirements: 120/1/60.
 - .3 CO2 Gas sensors:
 - .1 Enclosure: plastic, wall or beam-mounted NEMA 4 enclosure, 216 mm high x 266 mm wide x 114 mm deep.
-

- .2 Sensors: plug in electrochemical sensing elements, minimum 15% full scale accuracy, carbon dioxide sensors, minimum carbon dioxide range 0-1000 ppm factory calibrated.
- .3 Outputs: RS-485 4-wire connection, or 4-20 mA 3-wire connection, compatible with gas sensor control panel.
- .4 Electrical Requirements: 24 VDC powered from gas detection panel.

- .4 Oxygen Gas Sensor:
 - .1 Enclosure: Plastic, wall or beam-mounted NEMA 1 enclosure, 152 mm high x 89 mm wide x 28 mm deep.
 - .2 Sensor: Electrochemical diffusion sensing elements, minimum 2.5% full scale accuracy, oxygen range 0-25%.
 - .3 Outputs: 4-20mA e-wire connection compatible with gas sensor control panel.
 - .4 Electrical requirements: 24 VDC powered from gas detection panel.

- .5 Strobe/horn:
 - .1 Electronic 90 dB at 3 m with adjustable sound.
 - .2 Voltage: to operation from the gas detection panel.
 - .3 Wall mounted c/w vandal resistant wire guard.
 - .4 Blue strobe colour.
 - .5 ULC listed.
 - .6 Separate circuit wiring for strobe and alarm.

2.4 PANELS

- .1 Free-standing wall mounted enamelled steel cabinets with hinged and key-locked front door.
- .2 Control wiring required for Chiller Control local control panel, gas detection alarm panel and Refrigeration local control panel.
- .3 Panels to be lockable with same key.

2.5 WIRING

- .1 As per requirement of Division 26 where ever more stringent.
 - .2 For wiring under 70 volts use FT6 rated wiring where wiring is not run in conduit. Other cases use FT4 wiring.
 - .3 For 70V and above copper conductor with chemically cross-linked thermosetting polyethylene insulation rated RW90 and 6 2.28 V. Colour code to CSA 22.1.
-

- .4 Wiring must be continuous without joints.
- .5 Sizes:
 - .1 Field wiring to digital device: #18AWG 20AWG stranded twisted pair.
 - .2 Analog input and output: shielded #18 minimum solid copper #20 minimum stranded twisted pair.
 - .3 120V Power supply: to match or exceed breaker, size #12 minimum.
 - .4 Wiring for safeties/interlocks for starters, motor control centres, to be stranded, #14 minimum. .
- .6 All wiring to be rigid conduit, flexible and liquid tight flexible metal conduit to the requirement of Division 26.

PART 3 - EXECUTION

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for electric and electronic control systems installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 INSTALLATION

- .1 Install control devices.
 - .2 On outside wall, mount thermostats on bracket or insulated pad 25 mm from exterior wall.
 - .3 Install remote sensing device and capillary tube in metallic conduit. Conduit enclosing capillary tube must not touch heater or heating cable.
-

3.3 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

PART 1 - GENERAL

1.1 SUMMARY

- .1 Related Sections:
 - .1 Section 01 32 16.07 - Construction Progress Schedules - Bar (GANTT) Chart.
 - .2 Section 01 33 00 - Submittal Procedures.
 - .3 Section 01 45 00 - Testing Quality Control.
 - .4 Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .5 Section 01 78 00 - Closeout Submittals.
 - .6 Section 23 05 05 - Installation of Pipework.
 - .7 Section 23 08 01 - Performance Verification of Mechanical Piping Systems.
 - .8 Section 23 08 02 - Cleaning and Start-Up of Mechanical Piping Systems.

1.2 REFERENCES

- .1 American Society of Mechanical Engineers (ASME)
 - .1 ASME B16.5-13, Pipe Flanges and Flanged Fittings.
 - .2 ASME B16.18-2012 (R2005), Cast Copper Alloy Solder Joint Pressure Fittings.
 - .3 ASME B16.22-13, Wrought Copper and Copper Alloy Solder-Joint Pressure Fittings.
 - .4 ASME B18.2.1-12, Square and Hex Bolts and Screws Inch Series.
 - .2 American Society for Testing and Materials International (ASTM)
 - .1 ASTM A 47/A 47M-99(2014), Standard Specification for Ferritic Malleable Iron Castings.
 - .2 ASTM A 53/A 53M-12, Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc Coated, Welded and Seamless.
 - .3 ASTM B 75M-11, Standard Specification for Seamless Copper Tube Metric.
 - .4 ASTM B 837-10, Standard Specification for Seamless Copper Tube for Natural Gas and Liquefied Petroleum (LP) Gas Fuel Distribution Systems.
 - .3 Canadian Standards Association (CSA International)
 - .1 CSA W47.1-09, Certification of Companies for Fusion Welding of Steel.
 - .4 Canadian Standards Association (CSA)/Canadian Gas Association (CGA)
 - .1 CAN/CSA B149.1-15, Natural Gas and Propane Installation Code Handbook.
-

- .5 Health Canada/Workplace Hazardous Materials Information System (WHMIS)

- .1 Material Safety Data Sheets (MSDS).

1.3 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet for piping, fittings and equipment.
 - .2 Indicate on manufacturers catalogue literature following: valves, regulators, meters, pressure reducing valves.
- .3 Test Reports: submit certified test reports from approved independent testing laboratories indicating compliance with specifications for specified performance characteristics and physical properties.
- .4 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .5 Instructions: submit manufacturer's installation instructions.
- .6 Closeout Submittals: submit maintenance and engineering data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

PART 2 - PRODUCTS

2.1 PIPE

- .1 Steel pipe: to ASTM A 53/A 53M, Schedule 40, seamless as follows:
 - .1 NPS 1/2 to 2, screwed.
 - .2 NPS 2 1/2 and over, plain end.
- .2 Copper tube: to ASTM B 837.

2.2 JOINTING MATERIAL

- .1 Screwed fittings: Teflon approved for natural gas.
 - .2 Welded fittings: to CSA W47.1.
-

- .3 Flange gaskets: nonmetallic flat.
- .4 Brazing: to ASTM B 837.

2.3 FITTINGS

- .1 Steel pipe fittings, screwed, flanged or welded:
 - .1 Malleable iron: screwed, banded, Class 150.
 - .2 Steel pipe flanges and flanged fittings: to ASME B16.5.
 - .3 Welding: butt-welding fittings.
 - .4 Unions: malleable iron, brass to iron, ground seat, to ASTM A 47/A 47M.
 - .5 Bolts and nuts: to ASME B18.2.1.
 - .6 Nipples: schedule 40, to ASTM A 53/A 53M.
- .2 Copper pipe fittings, screwed, flanged or soldered:
 - .1 Cast copper fittings: to ASME B16.18.
 - .2 Wrought copper fittings: to ASME B16.22.

2.4 VALVES

- .1 Provincial Code and CGA approved, lubricated plug type or ball valve.
- .2 NPS 2 and under, screwed.
- .3 NPS 2-1/2 and over, flanged.
- .4 Suitable for the temperature to which exposed.
- .5 Certified by Canadian Gas Association (CGA).

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 PIPING

- .1 Install in accordance with Section 23 05 05 - Installation of Pipework, and CAN/CSA B149.1, CAN/CSA B149.2.

- .2 Install drip points:
 - .1 At low points in piping system.
 - .2 At connections to equipment.
- .3 Ream pipe ends. Clear scale and dirt, inside and outside before and after assembly.
- .4 Slope piping down in direction of flow to low point.
- .5 Use eccentric reducers at pipe size change installed to provide positive drainage.
- .6 Use dielectric type fittings where buried service enters and connects to building piping.
- .7 Joints:
 - .1 Gas service inside building - screw or weld NPS 2 and under. Weld NPS 2-1/2 and over.
 - .2 Gas service in ceiling plenums - weld all sizes.
 - .3 Gas service outside building - weld all sizes below ground. Weld all sizes NPS 2-1/2 and over about ground.

3.3 VALVES

- .1 Install valves with stems upright or horizontal unless otherwise approved by departmental representative
- .2 Install valves at branch take-offs to isolate pieces of equipment, and as indicated.
- .3 Install valve on the main gas service entering the building. Valve to have locking lugs.

3.4 FIELD QUALITY CONTROL

- .1 Site Tests/Inspection:
 - .1 Test system in accordance with CAN/CSA B149.1 and requirements of authorities having jurisdiction.
 - .2 Manufacturer's Field Services:
 - .1 Have manufacturer of products supplied under this Section review work involved in handling, installation/application, protection and cleaning of its products, and submit written reports, in acceptable format, to verify compliance of work with Contract.
-

.2 Provide manufacturer's field services, consisting of product use recommendations and periodic site visits for inspection of product installation, in accordance with manufacturer's instructions.

.3 Schedule site visits to review work at stages listed:

.1 After delivery and storage of products, and when preparatory work on which work of this Section depends is complete, but before installation begins.

.2 Twice during progress of work at 25% and 60% complete.

.3 Upon completion of work, after cleaning is carried out.

.3 Performance Verification:

.1 Refer to Section 23 08 01 - Performance Verification of Mechanical Piping Systems.

.4 PV procedures:

.1 Test performance of components.

3.5 ADJUSTING

.1 Purging: purge after pressure test in accordance with CAN/CSA B149.1.

.2 Pre-Start-Up Inspections:

.1 Check vents from regulators, control valves, terminate outside building in approved location through roof, and protected against blockage, damage.

.2 Check gas trains, entire installation is approved by authority having jurisdiction.

3.6 CLEANING

.1 Cleaning: in accordance with Section 23 08 02- Cleaning and Start-Up of Mechanical Piping Systems and CAN/CSA B149.1,.

.2 Perform cleaning operations as specified in Section 23 08 02 and in accordance with manufacturer's recommendations.

.3 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 35 29 - Health and Safety Requirements.
- .3 Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .4 Section 01 78 00 - Closeout Submittals.
- .5 Section 23 00 00 - Common Work Results for HVAC.
- .6 Section 23 05 05 - Installation of Pipework.
- .7 Section 23 05 23.01 - Valves - Bronze.
- .8 Section 23 05 23.02 - Valves - Cast Iron.
- .9 Section 23 05 93 - Testing, Adjusting and Balancing for HVAC.
- .10 Section 23 08 02 - Cleaning and Start-up of Mechanical Piping Systems.

1.2 REFERENCES

- .1 American Society of Mechanical Engineers (ASME).
 - .1 ASME B16.1-2015, Cast Iron Pipe Flanges and Flanged Fittings.
 - .2 ASME B16.3-2011, Malleable Iron Threaded Fittings.
 - .3 ASME B16.5-2013, Pipe Flanges and Flanged Fittings.
 - .4 ASME B16.9-2012, Factory-Made Wrought Butt welding Fittings.
 - .5 ASME B18.2.1-2012, Square and Hex Bolts and Screws (Inch Series).
 - .6 ASME B18.2.2-2015, Square and Hex Nuts (Inch Series).
 - .2 American Society for Testing and Materials International, (ASTM).
 - .1 ASTM A 47/A47M-99(20014), Standard Specification for Ferritic Malleable Iron Castings.
 - .2 ASTM A 53/A53M-12, Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc Coated Welded and Seamless.
 - .3 ASTM A 536-84(2014), Standard Specification for Ductile Iron Castings.
 - .4 ASTM B 61-15, Standard Specification for Steam or Valve Bronze Castings.
-

1.5 DELIVERY, STORAGE AND HANDLING

.1 Waste Management and Disposal.

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 PIPE

- .1 Steel pipe: to ASTM A53/A53M, Grade B, as follows:
 - .1 NPS 3/4 to NPS 14: Schedule 40.
 - .2 NPS 1/2 and under: Schedule 80.

2.2 PIPE JOINTS

- .1 NPS 2 and under: screwed fittings with PTFE tape.
- .2 NPS 2 1/2 and over: Rolled Grooved.
 - .1 Couplings to CSA B242.
 - .2 Coupling to be Rigid type, housing shall be cast with offsetting angle pattern bolt pads and system support and hanging in accordance with ANSI B31.1.
- .3 Flanges: plain face, slip-on to AWWA C111, roll grooved adaptors or welded.
- .4 Orifice flanges: slip-on raised face, 2100 kPa.
- .5 Flange gaskets: to AWWA C111.
- .6 Pipe thread: taper.
- .7 Bolts and nuts: to ASME B18.2.1 and ASME B18.2.2.
- .8 Roll grooved coupling gaskets: EPDM.

2.3 FITTINGS

- .1 Screwed fittings: malleable iron, to ASTM A47/A47M, and to ASME B16.3, Class 150.
-

- .3 Inner hose: stainless steel, corrugated.
- .4 Braided wire mesh stainless steel outer jacket.
- .5 Diameter and type of end connection:
 - .1 NPS 2 and under: threaded,
 - .2 NPS 2-1/2 and above: flanged.
- .6 Operating conditions:
 - .1 Working pressure: 1034 kPa.
 - .2 Working temperature: 100 °C.
 - .3 To match system requirements.

PART 3 - EXECUTION

3.1 PIPING INSTALLATION

- .1 Install pipework in accordance with Section 23 05 05 - Installation of Pipe Work.

3.2 CIRCUIT BALANCING VALVES

- .1 Install flow measuring stations and flow balancing valves on each branch (zone) circuit off main hydronic loop and as indicated.
- .2 Remove handwheel after installation and when TAB is complete.
- .3 Install performed polyurethane insulation covers on valves after systems have been balanced.

3.3 CLEANING, FLUSHING AND START-UP

- .1 In accordance with Section 23 08 02 - Cleaning and Start-Up of Mechanical Piping Systems.

3.4 TESTING

- .1 Test system in accordance with Section 23 05 05 - Installation of Pipework. Pressure test piping to 860 kPa for minimum 4 hours without loss of pressure.
-

3.5 FILLING OF SYSTEM

- .1 Refill system with inhibited glycol solution as specified.

3.6 BALANCING

- .1 Balance water systems to within plus or minus 5 % of design output.
- .2 Refer to Section 23 05 93 - Testing, Adjusting and Balancing for HVAC for applicable procedures.

3.7 PERFORMANCE VERIFICATION

- .1 In accordance with Section 23 08 01 - Performance Verification.

3.8 FLEXIBLE CONNECTORS

- .1 Install with stainless steel bolting and hardware.

PART 1 - GENERAL

1.1 SUMMARY

- .1 Section Includes:
 - .1 The supply and installation of Hydronic Specialties Equipment.
- .2 Related Sections:
 - .1 Section 01 33 00 - Submittal Procedures.
 - .2 Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
 - .3 Section 01 35 29 - Health and Safety Requirements.
 - .4 Section 01 78 00 - Closeout Submittals.
 - .5 Section 23 08 01 - Performance Verification of Mechanical Piping Systems.

1.2 REFERENCES

- .1 American Society of Mechanical Engineers (ASME).
 - .1 ASME-04, Boiler and Pressure Vessel Code.
- .2 American Society for Testing and Materials, (ASTM).
 - .1 ASTM A 47/A 47M-99(2009), Specification for Ferritic Malleable Iron Castings.
 - .2 ASTM A 278M-01(2006), Specification for Gray Iron Castings for Pressure-Containing Parts for Temperatures up to 650 degrees F (345 degrees C).
 - .3 ASTM A 516/A 516M-10, Specification for Pressure Vessel Plates, Carbon Steel, for Moderate - and Lower - Temperature Service.
 - .4 ASTM A 536-84(2009), Specification for Ductile Iron Castings.
 - .5 ASTM B 62-09, Specification for Composition Bronze or Ounce Metal Castings.
- .3 Canadian Standards Association (CSA International).
 - .1 CSA B51-09, Boiler, Pressure Vessel, and Pressure Piping Code.

1.3 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Product Data:
 - .1 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Indicate on product data expansion tanks, air vents,
-

separators, valves and strainers.

- .3 Closeout Submittals:
 - .1 Submit maintenance data in accordance with Section 01 78 00 - Closeout Submittals.

1.4 QUALITY ASSURANCE

- .1 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section 01 35 29 - Health and Safety Requirements.

1.5 DELIVERY STORAGE AND DISPOSAL

- .1 Waste Management and Disposal:
 - .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .2 Collect and separate for disposal paper, plastic, polystyrene and corrugated cardboard packaging material for recycling in accordance with Waste Management Plan.

PART 2 - PRODUCTS

2.1 AUTOMATIC AIR VENT

- .1 Standard automatic float vent: brass body and NPS 1/8 connection and rated at up to 690 kPa working pressure.
- .2 Float: solid material suitable for 115°C working temperature.

2.2 PIPE LINE STRAINER

- .1 NPS 1/2 to 2: bronze body to ASTM B 62-02, screwed connections, Y pattern.
 - .2 Blowdown connection: NPS 1.
 - .3 Screen: stainless steel brass with 1.19 mm perforations.
 - .4 Working pressure: up to 860 kPa.
-

2.3 LOW PRESSURE RELIEF VALVE

- .1 Bronze/brass housing, full nozzle and disc, spring loaded relief valve.
- .2 Capacity: matched to pump run-out setting. Relief settings as indicted on drawings.

PART 3 - EXECUTION

3.1 GENERAL

- .1 Install as indicated and to manufacturer's recommendations. Install floor mounted equipment on housekeeping pads.
- .2 Run drain lines and blow off connections to terminate above nearest drain.
- .3 Maintain proper clearance to permit service and maintenance.
- .4 Should deviations beyond allowable clearances arise, request and follow Departmental Representative's directive.
- .5 Check shop drawings for conformance of all tappings for ancillaries and for equipment operating weights.

3.2 STRAINERS

- .1 Install in horizontal or down flow lines.
- .2 Ensure clearance for removal of basket.
- .3 Install ahead of each pump.
- .4 Install ahead of each automatic control valve larger than NPS 1 except at radiant heating zone valves and as indicated.

3.3 AUTOMATIC AIR VENTS

- .1 Install at high points of systems.
 - .2 Install ball valve on automatic air vent inlet. Run discharge to nearest funnel floor drain.
-

3.4 PERFORMANCE VERIFICATION

- .1 In accordance with Section 23 08 01 - Performance Verification of Mechanical Piping Systems, supplemented as specified herein.

PART 1 GENERAL

1.1 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
- .3 Section 01 78 00 - Closeout Submittals.
- .4 Section 01 91 13 - Commissioning - General Requirements.
- .5 Section 23 08 02 - Cleaning and Start-up of Mechanical Piping Systems.
- .6 Section 23 05 05 - Installation of Pipework.
- .7 Section 23 08 01 - Performance Verification of Mechanical Piping.

1.2 REFERENCES

- .1 American National Standards Institute (ANSI).
 - .1 ANSI/ASME B16.1-2010, Cast Iron Pipe Flanges and Flanged Fittings.
 - .2 ANSI/ASME B16.25-2012, Buttwelding Ends.
 - .3 ANSI/ASME B16.3-2006, Malleable Iron Threaded Fittings.
 - .4 ANSI/ASME B16.5-13, Pipe Flanges and Flanged Fittings.
 - .5 ANSI/ASME B16.9-2012, Factory-Made Wrought Steel Buttwelding Fittings.
 - .6 ANSI B18.2.1-12, Square and Hex Bolts and Screws (Inch Series).
 - .7 ANSI/ASME B18.2.2-87(R2005), Square and Hex Nuts (Inch Series).
 - .2 American Water Works Association (AWWA).
 - .1 AWWA C111/A21.11-07, Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings.
 - .3 American Society for Testing and Materials International, (ASTM).
 - .1 ASTM A 47/A47M-99(2009), Standard Specification for Ferritic Malleable Iron Castings.
 - .2 ASTM A 53/A53M-12, Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc Coated, Welded and Seamless.
 - .3 ASTM A 126-04(2009), Standard Specification for Gray Iron Castings for Valves, Flanges, and Pipe Fittings.
 - .4 Canadian Standards Association (CSA International).
 - .1 CSA W48-06(R2011), Filler Metals and Allied Materials for Metal Arc Welding (Developed in cooperation with the Canadian Welding Bureau).
-

- .5 Manufacturers Standardization Society of the Valve and Fittings Industry, Inc.
 - .1 MSS-SP-70-2011, Cast Iron Gate Valves, Flanged and Threaded Ends.
 - .2 MSS-SP-71-2011, Gray Iron Swing Check Valves, Flanged and Threaded Ends.
 - .3 MSS-SP-80-2013, Bronze Gate, Globe, Angle and Check Valves.
 - .4 MSS-SP-85-2011, Gray Iron Globe and Angle Valves, Flanged and Threaded Ends.

1.3 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit product data and include manufacturer's literature data sheets for following: valves.
- .3 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
- .4 Submit operation and maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.4 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal paper, plastic, polystyrene and corrugated cardboard packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4 Fold up metal banding, flatten and place in designated area for recycling.

PART 2 - PRODUCTS

2.1 PIPE

- .1 Steel pipe: to ASTM A 53/A53M-07, Grade B, seamless, as follows:
 - .1 Steam;
 - .1 To NPS 2: Schedule 80.
-

- .2 NPS 2 1/2 and over: Schedule 40.
- .2 Condensate: Schedule 80.

2.2 PIPE JOINTS

- .1 NPS 2 and under: screwed fittings with PTFE tape.
- .2 NPS 2-1/2 and over: welding fittings and flanges to CSA W48.
- .3 Flanges: raised face. Flange gaskets to AWWA C111.
- .4 Pipe thread: taper.
- .5 Bolts and nuts: carbon steel, to ANSI/ASME B18.2.1 and ANSI/ASME B18.2.2.
- .6 Buttwelding ends: to ANSI/ASME B16.25-2007.

2.3 FITTINGS

- .1 Pipe flanges: carbon steel to ASTM A105/A105M-12, and to ANSI/ASME B16.3-2011, Class 150.
- .2 Screwed fittings: forged steel to ASTM A105/A105M-12, and to ANSI/ASME B16.11-2011, Class 3000.
- .3 Steel pipe gaskets, flanges and flanged fittings: to ANSI/ASME B16.5-2009.
- .4 Buttwelding fittings: carbon steel to ASTM A234, Grade WPB, and to ANSI/ASME B16.9-2012.
- .5 Unions: forged steel, to ASTM A105/A105M-12 and ANSI/ASME B16.11-2011.
- .6 Gaskets: Manufactured gasket, spiral wound 304 or 316 stainless steel with graphite, rated for required steam temperature and pressure.

PART 3 - EXECUTION

3.1 PIPING

- .1 Install pipework in accordance with Section 23 05 05 - Installation of Pipework, supplemented as specified herein.
 - .2 Connect branch lines into top of mains.
-

- .3 Install piping in direction of flow with slopes indicated on drawings. In the absence of other guidelines, slope the lines in the direction of flow as follows:
 - .1 Steam: 1:240.
 - .2 Low pressure condensate return: 1:70.
 - .3 High pressure and pumped condensate return: slope toward low point in piping.
- .4 Make provision for thermal expansion.
- .5 Drip pocket: line size, as indicated on drawings.

3.2 TESTING

- .1 Test pressure: 1-1/2 times maximum system operating pressure for high pressure steam and condensate, 860 kPa for low pressure steam and condensate.

3.3 CLEANING, FLUSHING, START-UP

- .1 In accordance with Section 23 08 02 - Cleaning and Start-up of Mechanical Piping Systems.

3.4 PERFORMANCE VERIFICATION (PV)

- .1 General:
 - .1 In accordance with Section 23 08 01 - Performance Verification of Mechanical Piping supplemented as specified herein.
- .2 Timing, only after:
 - .1 Pressure tests successfully completed.
 - .2 Flushing as specified has been completed.
- .3 PV Procedures:
 - .1 Verify complete drainage of condensate from steam coils.
 - .2 Verify proper operation of system components, including, but not limited to:
 - .1 Steam traps - verify no blow-by.
 - .2 Thermostatic vents.
 - .3 Monitor operation of provisions for controlled pipe movement including expansion joints, loops, guides, anchors.

PART 1 - GENERAL

1.1 RELATED sections

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 23 05 05 - Installation of Pipework.

1.2 REFERENCES

- .1 American Society of Mechanical Engineers (ASME)
 - .1 ASME B16.22-2013, Wrought Copper and Copper Alloy Solder - Joint Pressure - Fittings.
 - .2 ASME B16.24-2016, Cast Copper Pipe Flanges and Flanged Fittings: Class 150, 300, 400, 600, 900, 1500 and 2500.
 - .3 ASME B16.26-2013 Cast Copper Alloy Fittings for Flared Copper Tubes.
 - .4 ASME B31.5-2016, Refrigeration Piping.
- .2 American Society for Testing and Materials (ASTM)
 - .1 ASTM A 307-14, Specification for Carbon Steel Bolts and Studs, 60,000 PSI Tensile Strength.
 - .2 ASTM B 280-16, Specification for Seamless Copper Tube for Air Conditioning and Refrigeration Field Service.
- .3 Canadian Standards Association (CSA)
 - .1 CSA B52-13, Mechanical Refrigeration Code.
- .4 Environment Canada (EC)
- .5 EPS 1/RA/1-96, Environmental Code of Practice for the Reduction of Fluorocarbon Emissions from Refrigeration and Air Conditioning Systems.

1.3 ADMINISTRATIVE REQUIREMENTS

- .1 Pre-installation meetings:
 - .1 Convene pre-installation meeting 1 week prior to beginning work of this section and on-site installation, with departmental representative to:
 - .1 Verify project requirements.
 - .2 Review installation and substrate conditions.
 - .3 Co-ordination with other building construction subtrades.
 - .4 Review manufacturer's written installation instructions and warranty requirements.
-

1.4 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for refrigerant piping, fittings and equipment and include product characteristics, performance criteria, physical size, finish and limitations.
 - .2 Submit 2 copies of WHMIS MSDS in accordance with Section 01 35 23 - Health and Safety and 01 35 26 - Environmental Procedures. Indicate VOC's for adhesive and solvents during application and curing.
 - .3 Test Reports: submit certified test reports from approved independent testing laboratories indicating compliance with specifications for specified performance characteristics and physical properties.
 - .4 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.

1.5 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 10 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for refrigerant piping for incorporation into manual.

1.6 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Product Requirements and with manufacturer's written instructions.

PART 2 - PRODUCTS

2.1 TUBING

- .1 Processed for refrigeration installations, deoxidized, dehydrated and sealed.
 - .1 Hard copper: to ASTM B 280-16, type ACR B.
 - .2 Annealed copper: to ASTM B 280-16, with minimum wall thickness as per CSA B52-13 and ASME B31.5-2016.
-

2.2 FITTINGS

- .1 Service: design pressure 2070 kPa and temperature 121° C.
 - .1 Brazed:
 - .2 Fittings: wrought copper to ASME B16.22-2013.
 - .3 Joints: silver, copper-phosphorous, 95% Cu-5%P and non-corrosive flux.
- .2 Flared:
 - .1 Bronze or brass, for refrigeration, to ASME B16.26-2013.

2.3 PIPE SLEEVES

- .1 Hard copper or steel, sized to provide 6 mm clearance around between sleeve and uninsulated pipe or between sleeve and insulation.

2.4 VALVES

- .1 22 mm and under: Class 500, 3.5 Mpa, globe or angle non-directional type, diaphragm, packless type, with forged brass body and bonnet, moistureproof seal for below freezing applications, brazed connections.
- .2 Over 22 mm: Class 375, 2.5 MPa, globe or angle type, diaphragm, packless type, back-seating, cap seal, with cast bronze body and bonnet, moistureproof seal for below freezing applications, brazed connections.

PART 3 - EXECUTION

3.1 GENERAL

- .1 In accordance with Section 23 05 05 - Installation of Pipework, supplemented as specified herein
- .2 Install in accordance with CSA B52-13, EPS1/RA/1 and ASME B31.5-2016.

3.2 BRAZING PROCEDURES

- .1 Bleed inert gas into pipe during brazing.
 - .2 Remove valve internal parts, solenoid valve coils, sight glass.
 - .3 Do not apply heat near expansion valve and bulb.
-

3.3 PIPING INSTALLATION

- .1 General:
 - .1 Soft annealed copper tubing: bend without crimping or constricting Hard drawn copper tubing: do not bend. Minimize use of fittings.
- .2 Hot gas lines:
 - .1 Pitch at least 1:240 down in direction of flow to prevent oil return to compressor during operation.
 - .2 Provide trap at base of risers greater than 2400 mm high and at each 7600 mm thereafter.
 - .3 Provide inverted deep trap at top of risers.
 - .4 Provide double risers for compressors having capacity modulation.
 - .1 Large riser: install traps as specified above.
 - .2 Small riser: size for 5.1 m/s at minimum load. Connect upstream of traps on large riser.

3.4 PRESSURE AND LEAK TESTING

- .1 Close valves on factory charged equipment and other equipment not designed for test pressures.
- .2 Leak test to CSA B52-S1-09 before evacuation to 2MPa and 1MPa on high and low sides respectively.
- .3 Test Procedure: Initially test with nitrogen and maintain for 12 hours. If loss of pressure occurs, check for leaks with soap and water. If leak cannot be found then build pressure up to 35 kPa with refrigerant gas on high and low sides. Supplement with nitrogen to required test pressure. Test for leaks with electronic or halide detector. Repair leaks and repeat tests.

3.5 DEHYDRATION AND CHARGING

- .1 Close service valves on factory charged equipment.
 - .2 Ambient temperatures to be at least 13° C for at least 12 hours before and during dehydration.
 - .3 Use copper lines of largest practical size to reduce evacuation time.
 - .4 Use two-stage vacuum pump with gas ballast on 2nd stage capable of pulling 5Pa absolute and filled with dehydrated oil.
 - .5 Measure system pressure with vacuum gauge. Take readings with valve between vacuum pump and system closed.
-

- .6 Triple evacuate system components containing gases other than correct refrigerant or having lost holding charge as follows:
 - .1 Twice to 14Pa absolute and hold for 4 h.
 - .2 Break vacuum with refrigerant to 14kPa.
 - .3 Final to 5Pa absolute and hold for at least 12 h.
 - .4 Isolate pump from system, record vacuum and time readings until stabilization of vacuum.
 - .5 Submit test results to Departmental Representative.

- .7 Charging:
 - .1 Charge system through filter-drier and charging valve on high side. Low side charging not permitted.
 - .2 With compressors off, charge only amount necessary for proper operation of system. If system pressures equalize before system is fully charged, close charging valve and start up. With unit operating, add remainder of charge to system.
 - .3 Re-purge charging line if refrigerant container is changed during charging process.

- .8 Checks:
 - .1 Make checks and measurements as per manufacturer's operation and maintenance instructions.
 - .2 Record and report measurements to Departmental Representative.

3.6 INSTRUCTIONS

- .1 Post instructions in frame with glass cover CSA B52-13.

PART 1 - GENERAL

1.1 REFERENCES

- .1 American Society of Mechanical Engineers (ASME)
 - .1 ASME Boiler and Pressure Vessel Code, Section VII-2013.
- .2 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).

1.2 SUBMITTALS

- .1 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
 - .1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Shop Drawings:
 - .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
- .3 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .4 Closeout Submittals:
 - .1 Submit operation and maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.
 - .1 Log sheets as recommended by manufacturer Engineer.

1.3 QUALITY ASSURANCE

- .1 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section 01 35 29 - Health and Safety Requirements.
-

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 Install HVAC water treatment systems in accordance with ASME Boiler Code Section VII, and requirements and standards of authorities having jurisdiction, except where specified otherwise.
- .2 Ensure adequate clearances to permit performance of servicing and maintenance of equipment.

3.3 CLEANING OF MECHANICAL SYSTEM

- .1 Provide copy of recommended cleaning procedures and chemicals for approval by Departmental Representative.
- .2 Flush mechanical systems and equipment with approved cleaning chemicals designed to remove deposition from construction such as pipe dope, oils, loose mill scale and other extraneous materials. Use chemicals to inhibit corrosion of various system materials that are safe to handle and use.
- .3 Examine and clean filters and screens, periodically during circulation of cleaning solution, and monitor changes in pressure drop across equipment.
- .4 Drain and flush systems until alkalinity of rinse water is equal to make-up water.
- .5 Disposal of cleaning solutions approved by authority having jurisdiction.

3.4 FIELD QUALITY CONTROL

- .1 Start-up:
 - .1 Start up glycol feed systems in accordance with manufacturer's instructions.
 - .2 Commissioning:
-

- .1 Timing:
 - .1 After start-up deficiencies rectified.
 - .2 After start-up and before TAB of connected systems.
- .2 Pre-commissioning Inspections: verify:
 - .1 Presence of test equipment, reagents, chemicals, details of specific tests performed, and operating instructions.
 - .2 Suitability of log book.
 - .3 Required quality of treated water.
- .3 Commissioning procedures - applicable to glycol systems:
 - .1 Establish, adjust as necessary and record automatic controls and feed rates.
 - .2 Monitor performance continuously during commissioning of connected systems and until acceptance of project.
 - .3 Establish test intervals, regeneration intervals.
 - .4 Record on approved report forms commissioning procedures, test procedures, dates, times, quantities of glycol solution added, treated water analysis, test results, instrument readings, adjustments made, results obtained.
 - .5 Establish, monitor and adjust automatic controls as necessary.
 - .6 Visit project at specified intervals after commissioning is satisfactorily completed to verify that performance remains as set during commissioning (more often as required until system stabilizes at required level of performance).
 - .7 Advise Departmental Representative in writing on matters regarding installed water treatment systems.
closed circuit
- .4 Training:
 - .1 Commission systems, perform tests in presence of, and using assistance of, assigned O&M personnel.
- .5 Certificates:
 - .1 Upon completion, furnish certificates confirming satisfactory installation and performance.
- .6 Commissioning Reports:
 - .1 To include system schematics, test results, test certificates, design criteria, other data required by Departmental Representative.
- .7 Commissioning activities during Warranty Period:
 - .1 Check out water treatment systems on regular basis and submit written report to Departmental Representative.

3.5 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
-

- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

PART 1 - GENERAL

1.1 SUMMARY

- .1 Section Includes:
 - .1 Materials and installation of low-pressure metallic ductwork, joints and accessories.
- .2 Related Sections:
 - .1 Section 01 33 00 - Submittal Procedures.
 - .2 Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .3 Section 23 05 29 - Hangers and Supports for HVAC Piping and Equipment.
 - .4 Section 23 05 94 - Pressure Testing of Ducted Air Systems.

1.2 REFERENCES

- .1 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE).
 - .2 American Society for Testing and Materials International, (ASTM).
 - .1 ASTM A 480/A 480M-16, Standard Specification for General Requirements for Flat-Rolled Stainless and Heat-Resisting Steel Plate, Sheet and Strip.
 - .2 ASTM A 635/A 635M-15, Standard Specification for Steel, Sheet and Strip, Heavy-Thickness Coils, Carbon, Hot Rolled.
 - .3 ASTM A 653/A 653M-15, Standard Specification for Steel Sheet, Zinc Coated (Galvanized) or Zinc-Iron Alloy Coated (Galvannealed) by the Hot-Dip Process.
 - .3 Department of Justice Canada (Jus).
 - .1 Canadian Environmental Protection Act (CEPA), 1999, c. 33.
 - .4 Health Canada/Workplace Hazardous Materials Information System (WHMIS).
 - .1 Material Safety Data Sheets (MSDS).
 - .5 National Fire Protection Association (NFPA).
 - .1 NFPA 90A-15, Standard for the Installation of Air-Conditioning and Ventilating Systems.
 - .2 NFPA 90B-15, Standard for the Installation of Warm Air Heating and Air-Conditioning Systems.
 - .6 Sheet Metal and Air Conditioning Contractors' National Association (SMACNA).
 - .1 SMACNA HVAC Duct Construction Standards - Metal and Flexible, 2nd Edition 1995 and Addendum No. 1, 1997.
-

thereof.

.3 Class C: transverse joints and connections made air tight with gaskets, sealant, tape or as indicated. Longitudinal seams unsealed.

2.2 SEALANT

- .1 Sealant: oil resistant, water borne, polymer type flame resistant duct sealant. Temperature range of minus 30 degrees C to plus 93 degrees C.

2.3 TAPE

- .1 Tape: polyvinyl treated, open weave fiberglass tape, 50 mm wide.

2.4 DUCT LEAKAGE

- .1 In accordance with SMACNA HVAC Air Duct Leakage Test Manual

2.5 FITTINGS

- .1 Fabrication: to SMACNA.
 - .2 Radiused elbows.
 - .1 Rectangular: Centreline radius: 1.5 times width of duct unless noted otherwise.
 - .2 Round: smooth radius or five piece if required. Centreline radius: 1.5 times diameter.
 - .3 Mitred elbows, rectangular:
 - .1 To 400 mm: with single thickness turning vanes.
 - .2 Over 400 mm: with double thickness turning vanes.
 - .4 Branches:
 - .1 Rectangular main and branch: with 45 degrees entry on branch.
 - .2 Round main and branch: enter main duct at 45 degrees with conical connection.
 - .3 Provide volume control damper in branch duct near connection to main duct.
 - .4 Main duct branches: with splitter damper.
 - .5 Transitions:
 - .1 Diverging: 20 degrees maximum included angle.
 - .2 Converging: 30 degrees maximum included angle.
-

- .1 Fresh air intakes including combustion air systems.
 - .2 Exhaust stacks from base of riser upwards.
 - .3 Elsewhere as indicated.
- .2 Form bottom of horizontal duct without longitudinal seams.
 - .1 Weld joints of bottom and side sheets.
 - .2 Seal other joints with duct sealer.

3.4 SEALING AND TAPING

- .1 Apply sealant to outside of joint to manufacturer's recommendations.
- .2 Bed tape in sealant and recoat with minimum of one coat of sealant to manufacturers recommendations.

3.5 DUCT MATERIALS

- .1 Duct shall be constructed of the following materials unless indicated otherwise:
 - .1 Interior duct systems: 304 stainless steel or galvanized steel.
 - .2 Exterior duct systems and components: stainless steel or aluminum.

3.6 LEAKAGE TESTS

- .1 Refer to Section 23 05 94 - Pressure Testing of Ducted Air Systems.
- .2 In accordance with SMACNA HVAC Duct Leakage Test Manual.
- .3 Do leakage tests in sections.
- .4 Make trial leakage tests as instructed to demonstrate workmanship.
- .5 Do not install additional ductwork until trial test has been passed.
- .6 Test section minimum of 30 m long with not less than three branch takeoffs and two 90 degrees elbows.
- .7 Complete test before performance insulation or concealment Work.

PART 1 - GENERAL

1.1 SUMMARY

- .1 Related Sections:
 - .1 Section 01 32 16.07 - Construction Progress Schedules - Bar (GANTT) Chart.
 - .2 Section 01 33 00 - Submittal Procedures.
 - .3 Section 01 45 00 - Quality Control.
 - .4 Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .5 Section 01 78 00 - Closeout Submittals.

1.2 REFERENCES

- .1 Health Canada/Workplace Hazardous Materials Information System (WHMIS).
 - .1 Material Safety Data Sheets (MSDS).
- .2 Sheet Metal and Air Conditioning Contractors' National Association (SMACNA).
 - .1 SMACNA - HVAC Duct Construction Standards - Metal and Flexible, 95.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and data sheet. Indicate the following:
 - .1 Flexible connections.
 - .2 Duct access doors.
 - .3 Turning vanes.
 - .4 Instrument test ports.
 - .3 Test Reports: submit certified test reports from approved independent testing laboratories indicating compliance with specifications for specified performance characteristics and physical properties.
 - .1 Certification of ratings: catalogue or published ratings to be those obtained from tests carried out by manufacturer or independent testing agency signifying adherence to codes and standards.
-

- .4 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .5 Instructions: submit manufacturer's installation instructions.
- .6 Manufacturer's Field Reports: manufacturer's field reports specified.
- .7 Closeout submittals: submit maintenance and engineering data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

PART 2 - PRODUCTS

2.1 GENERAL

- .1 Manufacture in accordance with SMACNA - HVAC Duct Construction Standards.

2.2 FLEXIBLE CONNECTIONS

- .1 Frame: galvanized sheet metal frame mm thick with fabric clenched by means of double locked seams.
- .2 Material:
 - .1 Fire resistant, self extinguishing, neoprene coated glass fabric, temperature rated at minus 40 degrees C to plus 90 degrees C, density of 1.3 kg/m².

2.3 ACCESS DOORS IN DUCTS

- .1 Non-Insulated Ducts: sandwich construction of same material as duct, one sheet metal thickness heavier, minimum 0.6 mm thick complete with sheet metal angle frame.
 - .2 Insulated Ducts: sandwich construction of same material as duct, one sheet metal thickness heavier, minimum 0.6 mm thick complete with sheet metal angle frame and 25 mm thick rigid glass fibre insulation.
 - .3 Gaskets: neoprene foam rubber.
 - .4 Hardware:
 - .1 Up to 300 x 300 mm: two sash locks complete with safety chain.
-

- .2 301 to 450 mm: four sash locks complete with safety chain.
- .3 451 to 1000 mm: piano hinge and minimum two sash locks.
- .4 Doors over 1000 mm: piano hinge and two handles operable from both sides.
- .5 Hold open devices.

2.4 TURNING VANES

- .1 Factory or shop fabricated single thickness double thickness or with trailing edge, to recommendations of SMACNA and as indicated.

2.5 INSTRUMENT TEST

- .1 1.6 mm thick steel zinc plated after manufacture.
- .2 Cam lock handles with neoprene expansion plug and handle chain.
- .3 28 mm minimum inside diameter. Length to suit insulation thickness.
- .4 Neoprene mounting gasket.

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and data sheet.

3.2 INSTALLATION

- .1 Flexible Connections:
 - .1 Install in following locations:
 - .1 Inlets and outlets to supply air units and fans.
 - .2 Inlets and outlets of exhaust and return air fans.
 - .3 Elsewhere, as indicted.
 - .2 Length of connection: 100 mm.
 - .3 Minimum distance between metal parts when system in operation: 75 mm.
 - .4 Install in accordance with recommendations of SMACNA.
 - .5 When fan is running:
 - .1 Ducting on sides of flexible connection to be in alignment.

- .2 Ensure slack material in flexible connection.
- .2 Access Doors and Viewing Panels:
 - .1 Size:
 - .1 900 x 900 mm for person size entry.
 - .2 750 x 450 mm for servicing entry.
 - .3 300 x 300 mm for viewing.
 - .2 Locations:
 - .1 Fire and smoke dampers.
 - .2 Control dampers.
 - .3 Devices requiring maintenance.
 - .4 Required by code.
 - .5 Reheat coils.
 - .6 Elsewhere as indicated.
- .3 Instrument Test Ports:
 - .1 General:
 - .1 Install in accordance with recommendations of SMACNA and in accordance with manufacturer's instructions.
 - .2 Locate to permit easy manipulation of instruments.
 - .3 Install insulation port extensions as required.
 - .4 Locations:
 - .1 For traverse readings.
 - .1 Ducted inlets to roof and wall exhausters.
 - .2 Inlets and outlets of other fan systems.
 - .3 Main and sub-main ducts.
 - .4 And as indicated.
 - .2 For temperature readings.
 - .1 At outside air intakes.
 - .2 In mixed air applications in locations as approved by Departmental Representative.
 - .3 At inlet and outlet of coils.
 - .4 Downstream of junctions of two converging air streams of different temperatures.
 - .5 And as indicated.
- .4 Turning vanes:
 - .1 Install in accordance with recommendations of SMACNA and as indicated.

3.3 CLEANING

- .1 Perform cleaning operations as specified in Section and in accordance with manufacturer's recommendations.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

PART 1 - GENERAL

1.1 SUMMARY

- .1 Section Includes:
 - .1 Balancing dampers for mechanical forced air ventilation and air conditioning systems.

1.2 REFERENCES

- .1 Sheet Metal and Air Conditioning National Association (SMACNA)
 - .1 SMACNA HVAC Duct Construction Standards, Metal and Flexible-1985.
- .2 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
 - .1 Indicate the following:
 - .1 Pressure drop.

PART 2 - PRODUCTS

2.1 GENERAL

- .1 Manufacture to SMACNA standards.

2.2 SINGLE BLADE DAMPERS

- .1 Fabricate from same material as duct, but one sheet metal thickness heavier. V-groove stiffened.
 - .2 Size and configuration to recommendations of SMACNA, except maximum height 100 mm.
 - .3 Locking quadrant with shaft extension to accommodate insulation thickness.
-

- .4 Inside and outside bronze end bearings.
- .5 Channel frame of same material as adjacent duct, complete with angle stop.

2.3 MULTI-BLADED DAMPERS

- .1 Factory manufactured of material compatible with duct.
- .2 Opposed blade: configuration, metal thickness and construction to recommendations of SMACNA.
- .3 Maximum blade height: 100 mm.
- .4 Bearings: self-lubricating nylon.
- .5 Linkage: shaft extension with locking quadrant.
- .6 Channel frame of same material as adjacent duct, complete with angle stop.
- .7 Maximum leakage : 4 % at 1000 Pa.

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 Install where indicated.
 - .2 Install in accordance with recommendations of SMACNA and in accordance with manufacturer's instructions.
 - .3 Locate balancing dampers in each branch duct, for supply, return and exhaust systems.
 - .4 Runouts to registers and diffusers: install single blade damper located as close as possible to main ducts.
 - .5 Dampers: vibration free.
-

- .6 Ensure damper operators are observable and accessible.
- .7 Corrections and adjustments conducted by Departmental Representative.

3.3 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

PART 1 - GENERAL1.1 REFERENCES

- .1 American Society for Testing and Materials International (ASTM)
 - .1 ASTM A 653/A 653M-13, Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by Hot-Dip Process.
- .2 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .3 American National Standards Institute (ANSI)
 - .1 ANSI/AMCA Standard 500-D-12, Laboratory Methods of Testing Dampers for Rating.

1.2 SUBMITTALS

- .1 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
 - .1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Indicate the following:
 - .1 Performance data.
 - .2 Leakage.
 - .3 Pressure drop.
 - .4 Torque required.
 - .2 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .2 Instructions: submit manufacturer's installation instructions.
 - .3 Closeout Submittals
 - .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.
-

PART 2 - PRODUCTS

2.1 MULTI-LEAF DAMPERS

- .1 Opposed for modulating service and parallel blade type for isolating.
- .2 Extruded aluminum, interlocking blades, complete with extruded vinyl seals, spring stainless steel side seals, structurally formed and welded galvanized steel frame.
- .3 Pressure fit self-lubricated bronze bearings.
- .4 Linkage: plated steel tie rods, brass pivots and plated steel brackets, complete with plated steel control rod.
- .5 Performance:
 - .1 Leakage: in closed position less than 2% of rated air flow at 1000 Pa differential across damper.
 - .2 Pressure drop: at full open position less than 25 Pa differential across damper at 5 m/s.
- .6 Insulated aluminum dampers for all fresh air and exhaust air applications:
 - .1 Frames: insulated with extruded polystyrene foam with RSI 0.88.
 - .2 Blades: constructed from aluminum extrusions with internal hollows insulated with polyurethane or polystyrene foam, RSI 0.88.

2.2 BACK DRAFT DAMPERS

- .1 Automatic gravity operated, multi or single leaf, steel construction with nylon bearings, centre pivoted.

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.
-

3.2 INSTALLATION

- .1 Install where indicated.
- .2 Install in accordance with recommendations of SMACNA and manufacturer's instructions.
- .3 Seal multiple damper modules with silicon sealant.
- .4 Install access door adjacent to each damper. See Section 23 33 00 - Air Duct Accessories.
- .5 Ensure dampers are observable and accessible.

3.3 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

PART 1 - GENERAL

1.1 SYSTEM DESCRIPTION

.1 Performance Requirements:

.1 Catalogued or published ratings for manufactured items: obtained from tests carried out by manufacturer or those ordered by manufacturer from independent testing agency signifying adherence to codes and standards.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

.1 Product Data:

.1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.

.2 Indicate following:

- .1 Capacity.
- .2 Throw and terminal velocity.
- .3 Noise criteria.
- .4 Pressure drop.
- .5 Neck velocity.

.2 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.

.1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.

.2 Instructions: submit manufacturer's installation instructions.

1.3 DELIVERY, STORAGE, AND HANDLING

.1 Packing, shipping, handling and unloading:

.1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.

.2 Deliver, store and handle materials in accordance with manufacturer's written instructions.

.2 Waste Management and Disposal:

.1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

1.4 MAINTENANCE

- .1 Extra Materials:
 - .1 Provide maintenance materials in accordance with Section 01 78 00 - Closeout Submittals.
 - .2 Include:
 - .1 Keys for volume control adjustment.
 - .2 Keys for air flow pattern adjustment.

PART 2 - PRODUCTS

2.1 GENERAL

- .1 To meet capacity, pressure drop, noise level, neck velocity as follows:
 - .1 Noise: NC 25 to 35.
 - .2 Pressure drop: 12 to 20 Pa.
 - .3 Capacity: as indicated.
- .2 Frames:
 - .1 Full perimeter gaskets.
 - .2 Plaster frames where set into plaster or gypsum board and as specified.
 - .3 Concealed fasteners.
- .3 Concealed manual volume control damper operators.
- .4 Colour: as directed by Departmental Representative or as indicated.

2.2 MANUFACTURED UNITS

- .1 Grilles, registers and diffusers of same generic type, products of one manufacturer.

2.3 DIFFUSERS, GRILLES AND REGISTERS

- .1 General: with opposed blade dampers.
 - .2 Size and construction as indicated.
-

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 Install in accordance with manufacturers instructions.
- .2 Install with flat head cadmium plated screws in countersunk holes where fastenings are visible.
- .3 Provide concealed safety chain on each grille, register and diffuser.

3.3 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

PART 1 - GENERAL

1.1 REFERENCES

- .1 American Society for Testing and Materials International (ASTM)
 - .1 ASTM E 90-09, Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements.
- .2 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .3 Sheet Metal and Air Conditioning Contractors' National Association (SMACNA).
- .4 Society of Automotive Engineers (SAE).

1.2 SYSTEM DESCRIPTION

- .1 Performance Requirements:
 - .1 Catalogued or published ratings for manufactured items: obtained from tests carried out by manufacturer or those ordered by manufacturer from independent testing agency signifying adherence to codes and standards.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
 - .1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Indicate following:
 - .1 Pressure drop.
 - .2 Face area.
 - .3 Free area.
 - .2 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
-

.2 Instructions: submit manufacturer's installation instructions.

.3 Test Reports:

.1 Submit certified data from independent laboratory substantiating acoustic and aerodynamic performance to ASTM E 90.

1.4 DELIVERY, STORAGE, AND HANDLING

.1 Packing, shipping, handling and unloading:

.1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.

.2 Deliver, store and handle materials in accordance with manufacturer's written instructions.

.2 Waste Management and Disposal:

.1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 GOOSENECK HOODS

.1 Outdoor components of hood to be constructed from aluminum. Thickness: to ASHRAE and SMACNA.

.2 Fabrication: to ASHRAE and SMACNA.

.3 Joints: to SMACNA or proprietary manufactured duct joint. Proprietary manufactured flanged duct joint considered class A seal.

.4 Supports: Tie-down points required on each corner for duct widths 914 mm and over.

.5 Complete with integral birdscreen of 2.7 mm diameter wire. Use 12 mm mesh on exhaust 19 mm mesh on intake.

.6 Provide hinged access door where dampers are located at roof line.

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 In accordance with manufacturer's and SMACNA recommendations.
- .2 Reinforce and brace.
- .3 Anchor securely into opening. Seal with caulking to ensure weather tightness.
- .4 Secure roof hood, as recommended by manufacturer.

3.3 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

PART 1 - GENERAL

1.1 REFERENCES

- .1 American National Standards Institute/National Fire Prevention Association (ANSI/NFPA)
 - .1 ANSI/NFPA 96-2014, Ventilation Control and Fire Protection of Commercial Cooking Operations.
- .2 American Society of Heating, Refrigeration and Air-Conditioning Engineers (ASHRAE)
 - .1 ASHRAE 52.2-2002, Method of Testing General Ventilation air-Cleaning Devices for Removal Efficiency by particle Size.
- .3 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-115.13-85, Filter Media, Automatic Roll.
- .4 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .5 Underwriters' Laboratories of Canada
 - .1 ULC-S111-2013, Standard Method of Fire Tests for Air Filter Units.
 - .2 ULC-S649-06, Exhaust Hoods and Related Controls for Commercial and Institutional Kitchens.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
 - .1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Shop Drawings:
 - .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Indicate following: efficiencies, pressure drop.
 - .3 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
-

- .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .2 Instructions: submit manufacturer's installation instructions.

.4 Closeout Submittals

- .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.3 DELIVERY, STORAGE, AND HANDLING

.1 Packing, shipping, handling and unloading:

- .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.

.2 Waste Management and Disposal:

- .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

1.4 MAINTENANCE

.1 Extra Materials:

- .1 Provide maintenance materials in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Furnish list of individual manufacturer's recommended spare parts for equipment such as frames and filters, addresses of suppliers, list of specialized tools necessary for adjusting, repairing or replacing for inclusion in operating manual.
- .3 Spare filters: in addition to filters installed immediately prior to acceptance by Departmental Representative, supply 1 complete set of filters for each filter unit or filter bank in accordance with section 01 78 00 - Closeout Submittals.
- .4 Commissioning filters: provide additional set of filters for commissioning process.

PART 2 - PRODUCTS

2.1 GENERAL

- .1 Media: suitable for air at 100% RH and air temperatures between minus 40 and 50 degrees C.
-

- .2 Number of units, size and thickness of panels, overall dimensions of filter bank, configuration and capacities: to equipment manufacturer's standards and to limit pressure drops.
- .3 Pressure drop when clean and dirty, maximum 62 pa clean and 200 pa dirty.

2.2 FIBROUS GLASS PANEL FILTERS (MERV 8)

- .1 Disposable fibrous glass media: to CAN/CGSB-115.10 with adhesive.
- .2 Holding frame: 1.2 mm minimum thick galvanized steel with 3 mm diameter hinged wire mesh screen.
- .3 Performance: minimum average synthetic dust weight arrestance 70% to ASHRAE 52.1. Minimum efficiency reporting value to ASHRAE 52.5: MERV 8.
- .4 Fire rated: to ULC -S111.
- .5 Nominal thickness: 50 mm.

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION GENERAL

- .1 Install in accordance with manufacturer's recommendations and with adequate space for access, maintenance and replacement.

3.3 REPLACEMENT MEDIA

- .1 Replace media with new upon acceptance.
 - .2 Filter media new and clean, as indicated by pressure gauge, at time of acceptance.
-

3.4 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

PART 1 - GENERAL

1.1 REFERENCES

- .1 Statutes of Canada 1999 Chapter 33: "Canadian Environmental Protection Act 1999".
 - .1 SOR/2003-289: "Federal Halocarbon Regulations 2003".
- .2 Environmental Code of Practice for Eliminations of Fluorocarbon Emissions from Refrigeration and Air Conditioning Systems (the Environment Canada "Refrigeration Code of Practice", and the Report EPS 1 RA/2 dated March 1996).

1.2 GENERAL

- .1 Contractors and their personnel shall be familiar with the Section and its requirements.
- .2 The Contractor will comply with all Federal, Provincial, and Municipal regulatory requirements and guidelines for environmental protection and natural resources conservation, including the references noted above.

1.3 HALOCARBONS

- .1 All work relating to halocarbons to comply with referenced standards outlined above in Paragraph 1.1 - References.
 - .2 All work related to halocarbon equipment installation, servicing, etc., to be carried out by, or under direct supervision of a technician licensed by the Province of Nova Scotia as a refrigeration mechanic.
 - .3 Technician to provide to Departmental Representative:
 - .1 Copy of Province of Nova Scotia license.
 - .2 Certificate issued by the Heating, Refrigeration, and Air Conditioning Institute of Canada.
 - .3 Ozone Depletion Prevention Substance Awareness Card.
 - .4 Only non halocarbon refrigerant are acceptable.
 - .5 All work related to halocarbon equipment installation, servicing, decommissioning, leak testing to be documented on Departmental Representative supplied "Refrigeration and Air Conditioning
-

Service Log". Copy(s) of the "Refrigeration and Air Conditioning Service Log" form will be supplied to the Contractor during pre-commencement meeting.

- .6 Immediately report all releases of halocarbons to Departmental Representative.
- .7 Factory-charged halocarbon-containing shall be leak-tested by this Contractor in accordance with the "Refrigeration Code of Practice" within one working day after delivery to the site.
 - .1 No payment for delivery of this equipment to be site will be made until it is documented to be leak-free.
- .8 Non-factory sealed halocarbon-containing equipment shall be leak-tested using "triple evacuation": evacuate the system to 400 micron.

PART 2 - PRODUCTS

2.1 NOT USED

- .1 Not used.

PART 3 - EXECUTION

3.1 NOT USED

- .1 Not used.

PART 1 - GENERAL

1.1 REFERENCE STANDARDS

- .1 CSA Group
 - .1 CSA C22.2 No.46 M1988(R2011), Electric Air-Heaters.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for duct heaters and include product characteristics, performance criteria, physical size, finish and limitations.
 - .2 Submit product data and include:
 - .1 Element support details.
 - .2 Heater: total kW rating, voltage, phase.
 - .3 Number of stages.
 - .4 Rating of stage: rating, voltage, phase.
 - .5 Heater element watt/density and maximum sheath temperature.
 - .6 Maximum discharge temperature.
 - .7 Unit support.
 - .8 Clearance from combustibile materials.
 - .9 Internal components wiring diagrams.
 - .10 Minimum operating airflow.
 - .11 Pressure drop minimum airflow.

1.3 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
 - .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
 - .3 Storage and Handling Requirements:
 - .1 Store materials in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect duct heaters from nicks, scratches, and blemishes.
-

- .3 Replace defective or damaged materials with new.
- .4 Develop Construction Waste Management Plan related to Work of this Section.

PART 2 - PRODUCTS

2.1 DUCT HEATERS

- .1 Slip-in type heater, suitable for insertion into duct through an opening on the side. Heater will come complete with flange for securing it to the duct. Mounting flange shall be independent of the terminal box so as to allow installation without opening the box or drilling into it.
 - .2 Coils: High grade nickel-chrome alloy, insulated from galvanized steel frame by floating ceramic bushings. coil terminal pins to be stainless steel, insulated by non-rotating ceramic bushings.
 - .3 Heaters to be complete with fail safe, automatic reset disc-type thermal cut-outs as required by CSA.
 - .4 Duct heater shall be complete with a built-in disconnect to switch power off at the unit.
 - .5 Duct heaters shall be complete with disconnecting back-up magnetic contactors, 24 volt transformer, airflow sensor, SCR control, load fuses, solid state relays, pilot lights and protective screens required to provide a consistent air temperature output.
 - .6 Cutpouts shall be shielded from accidental impact and shall de-energize the heater in case of insufficient airflow.
 - .7 Capacities and sizes as indicated on drawings.
 - .8 Duct heater to accept control input signal by proportional duct thermostat with wall mounted interface.
 - .9 Main isolation disconnect switch.
-

PART 3 - EXECUTION

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for duct heaters installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 INSTALLATION

- .1 Make power and control connections to CSA C22.2 No.46.

3.3 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 01 91 13 - General Commissioning (Cx) Requirements and Section 26 05 00 - Common Work Results for Electrical.
- .2 Perform tests in presence of Departmental Representative.
 - .1 Provide test report and include copy with Operations and Maintenance Manuals.
- .3 Test cut-out protection when air movement is obstructed.
- .4 Test fan delay switch to assure disipation of heat after element shut down.
- .5 Test unit cut-off when fan motor overload protection has operated.
- .6 Ensure heaters and controls operate correctly.

3.4 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
-

- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

PART 1 - GENERAL

1.1 REFERENCE STANDARDS

- .1 American Society of Heating, Refrigeration and Air-Conditioning Engineers (ASHRAE)
 - .1 ASHRAE 84-2013, Method of Testing Air-to-Air Heat/Energy Exchangers (ANSI approved).

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for energy recovery equipment and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Shop Drawings:
 - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province, Nova Scotia.
- .4 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .5 Test Reports:
 - .1 Catalogued or published ratings: obtained from tests carried out by manufacturer or those ordered from independent testing agency signifying adherence to codes and standards in force.
 - .2 Provide confirmation of testing.
- .6 Manufacturers' Instructions: submit manufacturer's installation instructions.
 - .1 Departmental Representative will make available 1 copy of systems supplier's installation instructions.

1.3 MAINTENANCE MATERIAL SUBMITTALS

- .1 Submit maintenance materials in accordance with Section [1 78 00 - Closeout Submittals.
-

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect energy recovery equipment from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.
- .4 Develop Construction Waste Management Plan related to Work of this Section and in accordance with Section.

PART 2 - PRODUCTS

2.1 GENERAL

- .1 Comply with ASHRAE 84.

2.2 AIR TO AIR FIXED PLATE EXCHANGER

- .1 Casing: 0.8 mm thick anodized aluminum.
 - .2 Heat transfer surfaces: corrugated aluminum, edge sealed and bonded to casing.
 - .3 Cross contamination: not permitted.
 - .4 Condensate drain: NPS 2.
 - .5 Removable access panels.
 - .6 Performance characteristics: refer to schedule.
 - .7 Merv 8 Filters to be provided as specified in Section 23 44 00 - HVAC Air Filtration.
 - .8 HRV to have low speed and high speed settings.
-

- .9 HRV to have low voltage control option for remote activation of high speed mode.
- .10 Provide interposing relay for activation of remote motorized dampers.

PART 3 - EXECUTION

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for energy recovery equipment installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 INSTALLATION

- .1 Install in accordance with manufacturers recommendations.
- .2 Support independently of adjacent ductwork with flexible connections.
- .3 Install access doors in accordance with Section 23 33 00 - Air Duct Accessories for access to coils, dampers.

3.3 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
 - .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
 - .3 Waste Management: separate waste materials for recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
-

.1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
- .3 Section 01 78 00 - Closeout Submittals.

1.2 REFERENCES

- .1 American Society of Heating, Refrigeration and Air-Conditioning Engineers (ASHRAE)
 - .1 ASHRAE 52.1-92, Gravimetric and Dust Spot Procedures for Testing Air-Cleaning Devices Used in General Ventilation for Removing Particulate Matter.
- .2 American Society for Testing and Materials (ASTM International)
 - .1 ASTM C 547-11, Specification for Mineral Fibre Pipe Insulation.
- .3 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-115.10-M90, Disposable Air Filters For Removal of Particulate Matter from Ventilating Systems.
 - .2 CAN/CGSB-115.15-M91, High Efficiency, Rigid Type Air Filters for Removal of Particulate Matter from Ventilating Systems.
- .4 Canadian Standards Association (CSA International)
 - .1 CSA B521-09, Mechanical Refrigeration Code.
 - .2 CAN/CSA-656-14. Performance Standards for split-system and single package central air conditioners and heat pumps.
- .5 Environment Canada, (EC)/Environmental Protection Services (EPS)
 - .1 EPS 1/RA/2-1996, Code of Practice for Elimination of Fluorocarbons Emissions from Refrigeration and Air Conditioning Systems.
 - .2 Environment Canada-1994, Ozone-Depleting Substances Alternatives and Suppliers List.

1.3 SHOP DRAWINGS AND PRODUCT DATA

- .1 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Indicate major components and accessories including sound power levels of units.
-

- .3 Type of refrigerant used.

1.4 CLOSEOUT SUBMITTALS

- .1 Provide operation and maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.5 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

1.6 WARRANTY

- .1 All units shall have a one-year warranty on all parts not including the compressor.
- .2 The compressors shall have a 6-year warranty. The 6-year warranty will be conditional upon a proper maintenance schedule as described in the commissioning and manufacturer's maintenance report.

1.7 EXTRA MATERIALS

- .1 Furnish the following spare parts:
 - .1 One set of recommended filters for indoor coil fan units.
 - .2 Other items as per manufacturer's recommendations.

PART 2 - PRODUCTS

2.1 SINGLE ZONE DUCTLESS SPLIT SYSTEM

- .1 Ductless single mini split cooling unit: to CAN/CSA-C656. Capacities: as indicated.
 - .2 System Type:
 - .1 The condensing unit shall be pre-charged with R134A refrigerant or other HFC based equivalent as specified in Section 23 54 14 - Halocarbon Management.
 - .2 The system shall consist of a wall mounted evaporator section with wired control and a horizontal discharge, and a compatible single phase condensing unit.
 - .3 Condensing Unit:
-

- .1 The condensing unit shall be compatible with the evaporator unit.
 - .2 The condensing unit shall be equipped with a control board that interfaces with the evaporator unit to perform all functions necessary for operation and it shall be completely factory assembled.
 - .3 The condensing unit shall have the ability to operate with the tubing length required between the evaporator and the condensing units without additional requirement for field supplied line segments, traps or additional oil.
 - .4 The unit shall be test run at the factory prior to being supplied.
 - .5 The casing shall be constructed from galvanized steel plate and finished with rust protector such as acrylic paint munsell 3Y7.8/1.1 or equal.
 - .6 The fan grille shall be of ABS plastic or similarly suitable material.
 - .7 The unit shall be furnished with an AC fan as per the manufacturer's recommendations to match the capacity of the evaporator unit.
 - .8 The fan blades shall be of aerodynamic design for quiet operation.
 - .9 The fan shall be mounted in front of the coil, pulling air across it from the rear and dispelling it through the front.
 - .10 The L-shaped condenser coil shall be of copper tubing with flat aluminum fins to reduce debris build-up.
 - .11 The coil shall be protected with an integral metal guard.
 - .12 Refrigerant flow from the condenser shall be controlled by means of linear expansion valve (LEV) metering orifice. The LEV shall be controlled by a microprocessor-controlled step motor.
- .4 Compressor:
- .1 The compressor shall be a rotary compressor with a Variable Compressor Speed Inverter Technology.
 - .2 The compressor shall be driven by inverter circuit to control compressor speed.
 - .3 The compressor speed shall match the room load.
 - .4 The condensing unit shall have an accumulator and high pressure safety switch.
- .5 Electrical:
- .1 Both the condensing and evaporator units shall be 208V, 1 phase, 60 Hz. Units shall be complete with disconnect switch.
 - .2 The condensing unit shall be controlled by the microprocessor located in the evaporator unit.
 - .3 The control signal between the evaporator and the condensing units shall be pulse signal 24 volts DC.
 - .4 The unit shall have pulse amplitude modulation circuit which shall enable the unit to use 98% of input power supply.
- .6 Evaporator Unit:
- .1 Cooling (and heating where indicated on the Mechanical schedule), wall mounted, ductless.
 - .1 Cooling auto swing louvers (up/down).
-

- .2 Continuous 'airsweep'.
 - .3 Auto-restart after power interruptions.
 - .4 Auto-shut flaps close when unit is off.
 - .5 Blower: direct drive, multiple speed.
 - .6 Filters: cleanable and reusable.
 - .7 Electrical: as indicated with single point power connection.
 - .8 Sound rating: as indicated.
 - .9 Built-in temperature controls.
 - .10 Auto-changeover.
- .7 Controls:
- .1 The system shall have a wired controller to perform input functions necessary to operate the system.
 - .2 The wire controller shall have multi-language large DOT liquid crystal display and a weekly timer with multiple pattern settings per day.
 - .3 The controller shall consist of the following:
 - .1 On-Off switch
 - .2 Cool/Dry fan selector
 - .3 Thermostat setting
 - .4 Timer mode
 - .5 High/Low fan speed
 - .6 Auto vane selector
 - .7 Check mode switch
 - .8 Test Run
 - .4 The controller shall have a built-in temperature sensor. It shall also consist of two microprocessors interconnected by a single non-polar two-wire cable.
 - .5 Controls field wiring shall run direct from the evaporator unit to the controller with no splices, and manufacturer shall provide 2 conductor non-polar 22 AWG stranded wire for connection to remote controller.
 - .6 The system shall have self-diagnostics with codes for evaporator and condensing unit displayed on wired remote panel.
 - .7 Controller shall display operating conditions such as pipe temperatures, compressor operating conditions, LEV opening pulses, sub-cooling and discharge super heat.
 - .8 The microprocessor within the wall mounted remote controller shall provide automatic cooling, display setpoint and the computer room temperature.
 - .9 Control system shall control the continued operation of the air sweep louvers as well as provide On/Off switching.
 - .10 The microprocessor located in the evaporator unit shall have the capability to monitor return air temperature and evaporator coil temperature, receiving and processing commands from the wired controller, providing emergency operation and controlling the condensing unit, and shall have common alarm point.
 - .11 The control voltage from the controller to the evaporator unit shall be 12 volts, DC.
-

.12 The control signal between the evaporator and condensing unit shall be pulse signal 24 volts DC. The system shall be capable of automatic restart when power is restored after power interruption.

- .8 Refrigerant Piping, Valves, Fitting and Accessories Within Unit:
 - .1 To CSA B52.
 - .2 Include for each refrigerant circuit:
 - .1 Thermal expansion valve, external equalizing type.
 - .2 Combination filter-dryer.
 - .3 Solenoid valves.
 - .4 Liquid sight glass with moisture indicator.
 - .5 Suction line insulation: flexible elastomeric unicellular to ASTM C 547, 12 mm minimum thickness and as per local Code requirements.
- .9 Refrigerant Charge:
 - .1 Holding charge of refrigerant applied at factory.

2.2 MULTI-ZONE DUCTLESS SPLIT SYSTEM

- .1 Similar to single zone units except common condensing unit serving two or more evaporator units with independent control.
- .2 Inverter driven variable volume refrigerant compressor.

PART 3 - EXECUTION

3.1 GENERAL

- .1 Air Conditioning Units and Condensing Units:
 - .1 Install evaporator units and condensing units according to manufacturer's recommendations, and in accordance with EPS 1/RA/2.
- .2 Supply and install refrigeration piping by following the manufacturer's recommendations. Refrigerant piping (Liquid line and suction line) shall be separately insulated.
- .3 Obtain final refrigerant piping and wiring diagrams from the supplier.
- .4 Provide all required control wiring and power wiring for a complete installation.
- .5 The refrigerant distribution circuit and piping shall be designed and selected according to the manufacturer's specifications.
- .6 Manufacturer to certify installation.

3.2 EQUIPMENT PREPARATION

- .1 Provide services of manufacturer's field Representative to set and adjust equipment for operation as specified.