

**Supply and Install AHU Cooling Coil  
AAFC Research and Development Centre -St. John's, NL**

**AMENDMENT # 1**

\*\*\*\*\*  
THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY.  
THE AMENDMENT SHALL FORM A PART OF THE CONTRACT DOCUMENTS.  
\*\*\*\*\*

**ADDENDUM NO. 1**

**SPECIFICATIONS**

1. In Section 23 74 00, Clause 2.4.2, add sentence to read “Given that 1 ton equals 3.52 kW, then 44kW divided by 3.52 kW equals 12.5 tons cooling capacity.”

**DRAWINGS**

- .1 On Drawing M1, Detail 3 refers to 5/M1 detail. Revise reference to read 5/M2 Detail.
- .2 On Drawing M2, Detail 5, shows only 2 of 3 inside dimensions for the AHU. Add note indicating third inside dimension is 350mm Inside Length

By submission of its tender, the Tenderer confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Tender Amount.

All other terms & conditions remain unchanged.

\*\*\*\*\*