



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Travaux publics et Services gouvernementaux
Canada
Place Bonaventure,
portail Sud-Ouest, 7e étage
800 rue de la Gauchetière Ouest,
Bureau 7300,
Voir aux présentes - See herein
Montréal
Québec
H5A 1L6

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Travaux publics et Services gouvernementaux Canada
Place Bonaventure,
800 rue de la Gauchetière Ouest
Voir aux présentes - See herein
Montréal
Québec
H5A 1L6

Title - Sujet Expansion parking at La Macaza	
Solicitation No. - N° de l'invitation 21301-188288/A	Amendment No. - N° modif. 010
Client Reference No. - N° de référence du client 21301-18-8288	Date 2018-02-15
GETS Reference No. - N° de référence de SEAG PW-\$MTC-410-14537	
File No. - N° de dossier MTC-7-40063 (410)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-03-15	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Spina, Angelina	Buyer Id - Id de l'acheteur mtc410
Telephone No. - N° de téléphone (514) 496-3785 ()	FAX No. - N° de FAX (514) 496-3822
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
21301-188288
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
010
File No. - N° du dossier
MTC-7-40063

Buyer ID - Id de l'acheteur
MTC410
CCC No./N° CCC - FMS No/ N° VME

CHANGE OF ADDRESS – BIDS DELIVERY

For bids delivered on Monday, January 15, 2018, or later:

In person or by mail:
Place Bonaventure, South-West Portal, 7th Floor
800 de la Gauchetière Street West, Suite 7300
Montreal (QC), H5A 1L6

THE INVITATION TO TENDER IS MODIFIED AS MENTIONED BELOW:

Amendment 10

The closing date for the above mentioned project has been postponed from February 21st 2018 at 2:00 pm until March 15th 2018 at 2:00 PM.

1. SI03 OPTIONAL SITE VISIT

There will be a second site visit on Thursday February 22nd 2018 at 10h00 am. Interested bidders are to meet at the La Macaza facility located at 321, Chemin de l'aéroport, La Macaza QC J0T1R0.

Contractors who wish to attend the bidders' visit must send a confirmation by email **AT LEAST ONE (1) WORK DAYS** prior to the visit to the following email address: angelina.spina@tpsgc-pwgsc.gc.ca and Brigitte.Chabot@CSC-SCC.GC.CA.

2. You must delete in its totality the **BID AND ACCEPTANCE FORM (BA)** and replace it by the adjoining document.
3. Please find enclosed herewith the addition of a plan.
4. Please cancels and replaces completely 01 00 50 with the adjoining document.
5. Please find enclosed herewith questions and answers (CLARIFICATION NO. 2).

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

Solicitation No. - N° de l'invitation
21301-188288
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
010
File No. - N° du dossier
MTC-7-40063

Buyer ID - Id de l'acheteur
MTC410
CCC No./N° CCC - FMS No/ N° VME

BID AND ACCEPTANCE FORM (BA)

BA01 IDENTIFICATION

Expansion of the parking facility at La Macaza Institution (321 Chemin de l'aéroport, La Macaza (QC), J0T 1R0).

BA02 BUSINESS NAME AND ADDRESS OF BIDDER

Name: _____

Address: _____

Telephone: _____ Fax: _____ PBN: _____

E-mail address: _____

Industrial Security Program Organisation Number (ISP ORG#) _____
(when required)

BA03 THE OFFER

The Bidder offers to Canada to perform and complete the Work for the above named project in accordance with the Bid Documents for the **TOTAL BID AMOUNT INDICATED IN APPENDIX 4.**

BA04 BID VALIDITY PERIOD

The bid must not be withdrawn for a period of sixty (60) days following the date of solicitation closing.

BA05 ACCEPTANCE AND CONTRACT

Upon acceptance of the Bidder's offer by Canada, a binding Contract will be formed between Canada and the Bidder. The documents forming the Contract will be the Contract Documents identified in "Contract Documents (CD)" section.

BA06 CONSTRUCTION TIME

The Contractor must perform and complete the Work within five (5) weeks from the date of notification of acceptance of the offer.

BA07 BID SECURITY

The Bidder must enclose bid security with its bid in accordance with GI08 - Bid Security Requirements of R2710T - General Instructions - Construction Services - Bid Security Requirements.

BA08 SIGNATURE

Name and title of person authorized to sign on behalf of Bidder (Type or print)

Signature

Date

Solicitation No. - N° de l'invitation
21301-188288
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
010
File No. - N° du dossier
MTC-7-40063

Buyer ID - Id de l'acheteur
MTC410
CCC No./N° CCC - FMS No/ N° VME

APPENDIX 4 - COMBINED PRICE FORM

- 1) The prices per unit will govern in establishing the Total Extended Amount. Any arithmetical errors in this Appendix will be corrected by Canada.
- 2) Canada may reject the bid if any of the prices submitted do not reasonably reflect the cost of performing the part of the work to which that price applies.

LUMP SUM

The Lump Sum Amount designates Work to which a Lump Sum Arrangement applies.

- (a) Work included in the Lump Sum Amount represents all work not included in the unit price table.

Project: Expansion of the La Macaza Institution parking area
Location: La Macaza
Project No.: 550-2-352-3920
Revision # 2

Correctional Service Canada

BID FORM

ARTICLE	WORK DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	PRODUCT
1.0	Demolition work				
1,2	Removal of topsoil				
1.5	Protection of works to be preserved				
1.6	Relocation of panels				
1.7	Mobile shelter to be relocated and reinstalled				
3.0	Concrete work				
3.1	Demolition of existing concrete elements				
4.0	Diverse work				
4.7	Site restoration				
4.8	Clean-up				
5.0	Electricity and lighting work				
5.1	Removal of exterior electrical outlets (Zones 3, 4 and 6), including disconnection, metal base and aboveground ducts				
5.2	Removal of exterior lamp posts (Zone 4), including removal of the arms and lamps from the posts and disconnection (Zone 7)				
5.3	Removal of the panels (C & D) and one contactor in building 017's basement (Zone 8), including ducts, interior and exterior wiring and protective measures during work				
5.4	Removal of ducts, foundation and underground wiring of the lamp posts and exterior electrical outlets (Zones 3 to 8)				
5.34	Supply of the 6 m lifting gate including all accessories (motor, BJ, harp, 2 detection loops, lighting fixture on the arm) - Zone 9				
5.35	Installation of the 6 m lifting gate including all accessories (motor, BJ, ducts, harp, 2 detection loops, lighting fixture on the arm) - Zone 9				
7.0	Traffic management				
7.1	Maintaining the traffic flow and signalling, and work phases				
7.2	Signs indicating work and temporary signage				

Project: Expansion of the La Macaza Institution parking area
Location: La Macaza
Project No.: 550-2-352-3920
Revision # 2

Correctional Service Canada

BID FORM

ARTICLE	WORK DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	PRODUCT
8.0	Temporary measures during construction				
8.1	Transfer and maintain services other than exterior electrical outlets for panels C and D (ex.: optical fibre)				
8.2	Maintain lighting in the parking area				
8.3	Provide power supply on the work site (120V and/or 600V)				
9.0	Environmental measures				
9.2	Environmental protection plan and additional measures on site and for the storage area				
	Sub-total, Lump sum	1	lump sum		\$
1.0	Demolition work				
1.1	Pulverization (crushing, transportation and storage)	6200	m ²	\$	0,00 \$
1.3	Saw cuts and levelling	160	m	\$	0,00 \$
1.4	Removal of culvert	1	unit	\$	0,00 \$
	Sub-total, 1.0 Demolition work				0,00 \$
2.0	Road work				
2.1	Class II excavation/backfilling and placing	2625	m ³	\$	0,00 \$
2.2	Preparation and shaping of infrastructure	13900	m ²	\$	0,00 \$
2.3	Granular base, 150 mm thick (recuperation of crushed material, shaping and compaction)	13900	m ²	\$	0,00 \$
2.4	Provision for the MG 112 granular base amendment	325	ton	\$	0,00 \$
2.5	Granular subbase, MG 20, 300 mm thick	13900	m ²	\$	0,00 \$
2.6	Asphalt pavement, ESG-14, 60 mm thick (heavy traffic lane)	2425	m ²	\$	0,00 \$
2.7	Asphalt pavement, ESG-10, 40 mm thick (heavy traffic lane and expansion)	13350	m ²	\$	0,00 \$
2.8	Asphalt pavement, ESG-10, 40 mm thick (Electrical work rehabilitation: Perimeter - Zone 7, Building 017 - Zone 8, and Gate - Zone 9)	160	m ²	\$	0,00 \$
	Sub-total, 2.0 Road work				0,00 \$

Project: Expansion of the La Macaza Institution parking area
Location: La Macaza
Project No.: 550-2-352-3920
Revision # 2

Correctional Service Canada

BID FORM

ARTICLE	WORK DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	PRODUCT
3.0	Concrete work				
3.2	Extension of the concrete medians with curbs, including foundation and 1.5 m connections	40	m	\$	0,00 \$
3.3	Monolithic concrete medians, 1.2 m wide including foundation	500	m ²	\$	0,00 \$
3.4	Monolithic 1.8 m concrete sidewalks including foundation	35	m ²	\$	0,00 \$
	Sub-total, 3.0 Concrete work				0,00 \$
4.0	Diverse work				
4.1	Culvert, 450 mm ø and riprap	20	m	\$	0,00 \$
4.2	Bollards	7	unit	\$	0,00 \$
4.3	Concrete tank	5	unit	\$	0,00 \$
4.4	Ditch shaping	160	m	\$	0,00 \$
4.5	Topsoil and hydro-seeding	2900	m ²	\$	0,00 \$
4.6	Adjustable frames for existing manholes	3	unit	\$	0,00 \$
	Sub-total, 4.0 Diverse Work				0,00 \$
5.0	Electricity and lighting work				
5.5	Lamp posts bases - Zones 1, 2 and 4	6	unit	\$	0,00 \$
5.6	Supply and installation of a pull pit #1 - Zone 8	6	unit	\$	0,00 \$
5.7	Duck Bank (type A) - concrete part only (Zones 5 and 8)	11	m ³	\$	0,00 \$
5.8	Duck Bank (type B) - concrete part only (Zones 4 and 5)	25	m ³	\$	0,00 \$
5.9	Duck Bank (type C) - concrete part only (Zones 1, 2, 3, 5, 6, 7 and 9)	120	m ³	\$	0,00 \$
5.10	Duck Bank (type D) - concrete part only (Zones 1, 2 and 4)	140	m ³	\$	0,00 \$

Project: Expansion of the La Macaza Institution parking area
Location: La Macaza
Project No.: 550-2-352-3920
Revision # 2

Correctional Service Canada

BID FORM

ARTICLE	WORK DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	PRODUCT
5.11	Base for lifting gate (Zone 9)	1	unit	\$	0,00 \$
5.12	Base for the pedestal island (Zone 9)	1	unit	\$	0,00 \$
5.13	Exterior double electric terminal for public vehicles - Zones 4 and 6 - concrete part only	9	unit	\$	0,00 \$
5.14	Exterior double electric terminal for institutional vehicles - Zone 3 - concrete part only	31	unit	\$	0,00 \$
5.15	Supply and installation of two electric panels C and D with disconnecting switches and breakers, including wiring to the panels - Zone 8	2	unit	\$	0,00 \$
5.16	Supply and installation of panels C and D electrical wiring (2 or 3 + ground) to each of the electrical outlets of the exterior electric terminals. Unit = wiring per outlet (circuit per panel C or D). Zone 8 to Zones 3, 4 and 6	85	unit	\$	0,00 \$
5.17	Supply and installation of lamp posts electrical wiring including termination connection. Unit = wiring per lamp (two lamps per lamp post) - Zone 7 (L-10C) to Zones 1, 2 and 4	20	unit	\$	0,00 \$
5.18	Supply and installation of the gate's electrical wiring including breaker and connection to the panel - Unit = metre from Zone 8 to Zone 9	160	m	\$	0,00 \$
5.19	Supply and installation of the traffic light's electrical and control wiring (red/green) - Unit = metre including all wires in one or two cables, from the security station in Zone 8 to the traffic light in Zone 6	85	m	\$	0,00 \$
5.20	Supply and installation of LED lam posts with arms and lamps - Unit = one two arms lamp post (L-04N à L-09N) - Zones 1, 2 and 4	6	unit	\$	0,00 \$
5.21	Addition to the existing lamp posts: supply and installation of arms and lamps - Unit = 2 arms per lamp post (L-01C à L-03C) - Zone 4	3	unit	\$	0,00 \$
5.22	Supply and installation of exterior double electric terminal for public vehicles - Zones 4 and 6	9	unit	\$	0,00 \$
5.23	Supply and installation of exterior double electric terminal for institutional vehicles - Zone 3	31	unit	\$	0,00 \$

Project: Expansion of the La Macaza Institution parking area
Location: La Macaza
Project No.: 550-2-352-3920
Revision # 2

Correctional Service Canada

BID FORM

ARTICLE	WORK DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	PRODUCT
5.24	Supply and installation of pull box - "large" model- BTG-01 to BTG -03 - Zone 4	3	unit	\$	0,00 \$
5.25	Supply and installation of pull box - "small" model- BTP-01 to BTP-18 - Zone 4	18	unit	\$	0,00 \$
5.26	Supply and installation of metal bases (steel box) screwed in the lamp posts' concrete foundation (L-04N à L-09N) - Zones 1, 2 and 4	6	unit	\$	0,00 \$
5.27	Supply and installation of pull pit # 1 - Zones 5/8	1	unit	\$	0,00 \$
5.28	Supply and installation of foundation (type A). Unit = 9 ducts per metre- Zones 5 and 8 (MC -01)	11	m	\$	0,00 \$
5.29	Supply and installation of foundation (type B). Unit = 3 ducts per metre- Zones 4 and 5 (MC -03)	21	m	\$	0,00 \$
5.30	Supply and installation of foundation (type C). Unit = 2 ducts per metre- Zones 1, 2, 3, 5, 6, 7 and 9 (MC -02, MC -04 to MC -08)	120	m	\$	0,00 \$
5.31	Supply and installation of foundation (type D). Unit = 1 duct per metre- Zones 1, 2 and 4 (MC -10 to MC -17)	140	m	\$	0,00 \$
5.32	Supply and installation of electrical ducts (53 mm) to reach the electric terminals in Zones 3, 4 and 6	1260	m	\$	0,00 \$
5.33	Supply and installation of ducts (electrical/control) in building 017 for the traffic light (red/green) and lamp post L-01C - Unit = metre including all wires in one cable and the drilling in the concrete slab or lamp post - Zones 8 and 9	21	m	\$	0,00 \$
5.36	Supply and installation of the gate's double pedestal- Zone 9	1	unit	\$	0,00 \$
5.37	Supply and installation of two card readers with wiring and ducts up to the gate's motor, including 20 cards (programming and installation)- Zone 9. Unit = 2 card readers with 20 programmed cards	1	unit	\$	0,00 \$
5.38	Supply and installation of traffic lights (red/green) with control to building 017, including wiring - Zones 4, 5 and 8	1	unit	\$	0,00 \$

Project: Expansion of the La Macaza Institution parking area
Location: La Macaza
Project No.: 550-2-352-3920
Revision # 2

Correctional Service Canada

BID FORM

ARTICLE	WORK DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	PRODUCT
5.39	Supply and installation of the gate's ducts and anchorages on, under and inside the concrete base to reach the gate's elements (island, harp, motor, lighting fixture on the arm) - Zone 9	1	unit	\$	0,00 \$
Sub-total, 5.0 Electricity and lighting work					<u>0,00 \$</u>
6.0	Marking and signalling work				
6.1	Solid line	1950	m	\$	0,00 \$
6.2	Broken line	115	m	\$	0,00 \$
6.3	Parking for people with disabilities	4	unit	\$	0,00 \$
6.4	No stopping "RED" indication line under the gate's arm - Zone 9	1	unit	\$	0,00 \$
6.5	Pedestrian crossing	245	m	\$	0,00 \$
6.6	Permanent road signs on posts	15	unit	\$	0,00 \$
6.7	Supply of 12" x 12" metal guide signs on 1" x 1" x 48" metal posts to be installed in front of the institutional parking spaces (1 to 6) - Zone 3	6	unit	\$	0,00 \$
Sub-total, 6.0 Marking and signalling work					<u>0,00 \$</u>
7.0	Traffic management				
7.3	Temporary installation of ducts including electrical wiring during work for signalling requirements	105	m	\$	0,00 \$
Sub-total, 7.0 Traffic management					<u>0,00 \$</u>
9.0	Environmental measures				
9.1	Sediment barriers	700	m	\$	0,00 \$
Sub-total, 9.0 Environmental measures					<u>0,00 \$</u>


Project: Expansion of the La Macaza Institution parking area
Location: La Macaza
Project No.: 550-2-352-3920
Revision # 2

Correctional Service Canada

BID FORM

ARTICLE	WORK DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	PRODUCT
Summary					
	Sub-total, Lump sum				0,00 \$
	Sub-total, 1.0 Demolition work				0,00 \$
	Sub-total, 2.0 Road work				0,00 \$
	Sub-total, 3.0 Concrete work				0,00 \$
	Sub-total, 4.0 Diverse Work				0,00 \$
	Sub-total, 5.0 Electricity and lighting work				0,00 \$
	Sub-total, 6.0 Marking and signalling work				0,00 \$
	Sub-total, 7.0 Traffic management				0,00 \$
	Sub-total, 9.0 Environmental measures				0,00 \$
	Sub-total				0,00 \$
	GST (5.0%)				0,00 \$
	QST (9.975%)				0,00 \$
					0,00 \$

END OF SECTION



exp
 1100 Avenue de la République
 1100 Avenue de la République
 1100 Avenue de la République
 1100 Avenue de la République

REVISIONS
 NO. DATE DESCRIPTION
 1 17-10-26 APPROVAL
 2 17-04-26 APPROVAL

LEGENDA / LEGEND
 (S) - SÉRIE DE CONDUITS
 (E) - ÉLECTRIQUE
 (M) - MÉCANIQUE
 (H) - HYDRAULIQUE
 (G) - GAZ
 (V) - VENTILATION
 (A) - AUTRES





PROJET
 ÉTABLISSEMENT DE LA MACHAZA
 LA MACHAZA INSTITUTION
 321, CHEMIN DE L'AÉROPORT
 LA MACHAZA

AGRANDISSEMENT DU STA TONNEMENT EXPANSION OF EXISTING PARKING FACILITIES

GENIE ELECTRIQUE ELECTRICAL ENGINEERING
 CONSTRUCTION - RÉSEAU PRISES POUR VEHICLES
 CONSTRUCTION - ELECTRICAL VEHICLES OUTLETS
 L.-J. FORBES, INC.

1 17-10-26 APPROVAL
 2 17-04-26 APPROVAL

N. BELLEY, L.-J. FORBES, INC.
 L.-J. FORBES, INC., P. MAQUINE, INC.
 550-2-352-3920-3920
 20-10-17
 1:500M
 87/2



1.4 SECURITY SCREENING

- .1 All workers shall undergo security screening in order to be granted a security classification as required by the Correctional Service of Canada and Public Works and Government Services Canada.
- .2 Section 01 35 13 provides a detailed description of the procedures involved in the security screening.
- .3 At the start of work, a job-site special meeting will be held with institution representatives to define the instructions governing security and site operation in a correctional environment.

1.5 CODES

- .1 The specifications will require that the work and materials comply with the National Building Code of Canada (NBC) and all other applicable provincial or local codes. The strictest requirements shall apply in case of contradiction or discrepancy.
- .2 The work shall be performed in a manner that meets or exceeds the following requirements:
 - .1 Contract documents
 - .2 Specified standards and codes as well as other documents cited as references

1.6 REQUIRED DOCUMENTS

- .1 A copy of the following documents shall be kept at the job site:
 - .1 Contract drawings
 - .2 Specifications
 - .3 Amendments
 - .4 Amended shop drawings
 - .5 Modification orders
 - .6 Other contract amendments
 - .7 On-site test reports
 - .8 Approved work schedule
 - .9 Manufacturer installation and start-up instructions

1.7 SUBSOIL STUDY

- .1 A soil test report is available for consultation and is attached to the specifications.

1.8 WORK SCHEDULE

- .1 The successful bidder shall initiate work immediately upon receiving notice that the contract has been awarded. The work covered by this document, including measures to correct construction deficiencies, must be completed within the schedule specified herein. Failure to comply with the schedule shall be dealt with as provided for in the Standard Acquisition Clauses and Conditions (SACC) Manual, Public Works and Government Services Canada (PWGSC).

- .2 Within 10 business days of contract award, submit a work schedule for the various project phases, the completion date of which will be no later than July 20, 2018. The work period is established at **10 weeks**.
- .3 Within 10 business days of contract award, submit shop drawings, technical data sheets, samples and security screening applications for approval.
- .4 The work sequence is as follows:
 - .1 Start-up meeting and schedule submission, shop drawings, technical data sheets, samples and security screening applications for approval
 - .2 Approval of documents submitted
 - .3 Construction start-up
 - .4 Phase 1: Expansion of the existing parking-lot;
 - .5 Phase 2: Improvements of the existing parking-lot;
 - .6 Submission of operating and maintenance manuals for approval;
 - .7 Provisional acceptance;
 - .8 Training of operating personnel;
 - .9 Correction of deficiencies; and
 - .10 Final approvals.
- .5 Within ten (10) business days of contract award, the Contractor shall provide, in a format acceptable to the Project Manager, a work schedule indicating:
 - .1 Dates for submitting shop drawings, lists of materials and samples;
 - .2 Delivery dates for the following pieces of equipment and materials;
 - .3 Start-up and completion dates for the work described in each section of the specifications; and
 - .4 Final completion date with respect to the completion date stipulated in the contract documents
- .6 Changes to milestones in the submitted schedule shall be at the discretion of the CSC Project Manager. The schedule shall be updated by the Contractor with the cooperation and approval of the CSC Project Manager.
- .7 If the proposed works are to be performed outside normal working hours: coordination is required with the CSC Project Manager.



January 29, 2018

**TENDER SPECIFICATION
for
La Macaza Institution: Expansion of the
parking facilities**

CLARIFICATION NO. 2

The following shall form an integral part of the following tender documents:

***“Tender Documents and Drawings for La Macaza
Institution: Expansion of the parking facilities”***

1. Q : Can you confirm that the unit of items 5.3, 5.4, 5.5 and 5.6 are in cubic metres ? They are not in linear metres ?

A : The units of items 5.3, 5.4, 5.5 and 5.6 in the bid form are in linear meter. Refer to revised bid form attached to this document.

2. Q : During the site visit, we have discussed with the consultants and the institution representatives that the work period of 5 weeks would be revised. Any changes concerning the work period?

A : A work period of 10 weeks will be permitted. Refer to revised section 01 00 50 attached to this document.

3. Q : There is 2 different unit price schedule for the following sections : 1.0, 3.0, 4.0, 5.0, 7.0 and 8.0. Please provide clarifications. Items 5.5 and 5.6 of page 1/7 is the same article?

R : Refer to revised bid form for clarification, the article numbers have been modified and are now only appearing once. Items 5.5 and 5.6 of page 1/7, which are items 5.34 and 5.35 in the revised bid form, are two different articles. Item 5.34 is the supply of the lifting gate while item 5.35 is the installation of this one.

4. Q : Regarding article 5.31 in the bid form, is the gate control system an autonomous system or is it interconnected with the facility? Is it possible to request the type and or model number of the card readers for the parking pedestal?

A : The gate control system is an autonomous system, as shown on electrical plan 11/12, the card readers model must be HID R40 or approved equal.



January 29, 2018

5. Q : Following modification #8 which includes a bid form, did the contract go from lump sum to unit price? Are the quantities presented within appendix 4 part of the tender documents and used for the payments or are they for indication only?

A : The contract is lump sum. The quantities presented in appendix 4 are part of the tender documents but are indicative only, the payments will not be based on these quantities.

6. Q : I am having difficulties understanding the answer to the question concerning the security system. Is the question related to the motorised gate and its components? If so, Paradox does not fabricate motorised gates. Who is the supplier for the motorized gate?

A : The supplier of the motorized gate and its components can either be Automatic System, Pivin Drapeau or approved equal.

7. Q : Is it the general contractor or the electrician's responsibility to do the civil work related to the electrical work? More specifically the excavation, backfill of the electrical trench for duct banks, light post foundations, motorized gate foundation and pull boxes.

A : It is the responsibility of the general contractor to carry out all the work as well as the specialized resources in order to complete the work according to the plans and specifications.

END OF CLARIFICATION