

**Part 1 ADDENDUM NO.2**

**1.1 General**

- .1 This Addendum is issued prior to tender closing and shall become an integral part of the Tender, Specifications, Drawings and Contract Documents for this project.
- .2 In the event of conflicts between the various Contract Documents, the order of precedence shall be as stipulated in the General Conditions of the Contract, except that this Addendum shall take overall precedence.

**Part 2 Questions**

**2.1 Question 1**

Section 23 05 93 Testing, Adjusting, And Balancing

**Part 1 General**

**1.3 ALLOWANCES**

- .1 Cash Allowance: Section 01 20 13 for the Cash Allowance Sum applicable to this section.
- .2 Allowance includes testing, adjusting, and balancing of mechanical systems.
- .3 Work is included in this section and is part of the Contract Sum/Price.

There is no Section 01 20 13. What is required for testing, adjusting and balancing?

**Answer:** Remove Section 1.3 Allowances from Section 23 05 93 Testing, Adjusting, and Balancing. The Contractor is to include a certified balance of the system in their quotation this will not be paid for out of the cash allowance.

**END OF SECTION**