




### COLOR SELECTION

WALLS	NO	DESCRIPTION
RETURN PANEL	11	11
TRANSOM	11	11
CAR TOP	M2625	WHITE BAKED ENAMEL
FLOORING	TILE	FLINTKOTE V.A. #3227 CLASSIC (1/2" x 1/2")
KICKPLATE	"a	STAINLESS STEEL
CAR DOOR	M2615	BAKED ENAMEL
CAR COLUMNS	"a	STAINLESS STEEL
LANDING DOORS	"a	BAKED ENAMEL
LANDING FRAMES	"a	BAKED ENAMEL

SERVICE	PASSENGER
CAPACITY	600 LBS. SPEED 100 FPM
OPERATION	SEL. COLL.
NO. LANDING	4 NO. OPENINGS 4
CAGE	302 EST. GROSS CAR WT. 3180 LBS.
MACHINE	207E BASEMENT TRACTION
SHEAVE SHAFT LOAD	7300 LBS.
COUNTERWEIGHT, EST. WT.	3420 LBS.
HOIST MOTOR	3 HP 1200 RPM
M.O. SET	H.P. - KW
POWER SUPPLY	480 VOLTS 3 PH. 60 CY.
CONTROLLER	23L-1
CAR ENCLOSURE	SACR. (W/OUT DRAP. CURTAIN)
CAR DOORS	SINGLE SPEED
HATCH DOORS	SINGLE SPEED
INTERLOCKS	YES
GUIDE RAILS	CAR 2 CAR 2
SAFETY TYPE	SAFETY GOVERNOR CONTAINING 2 1/2" STROKE
BUFFERS	CAR SPRING STROKE 3"
DECK	NOT BY ELEV. MFG.
MACH. & OH. BEAMS	SEE LAYOUT
EFFECTIVE AREA	4 SQ. FT.
CABLES	3/8" 19S 21
PISTON RAILS	TO USE DOUBLE CAST
IRON RAIL CLIPS	ENT. W/ WEATHER STRIPPING
CABLE SPRINGS	ON BOTH ENDS



NOT BY ELEV. MFG.  
A ROOM FUSED CUTOUT SWITCH IN MACHINE ROOM AND 3 1/2" FUSED CAR LIGHT CUTOUT SWITCH IN MACHINE ROOM (FOR EACH ELEVATOR AS SHOWN).  
SUITABLE ACCESS TO MACHINE ROOM BUILDING STRUCTURE TO RECEIVE NEW ELEVATOR EQUIPMENT.  
SUPPORTS FOR MACHINE OR SHEAVE BEAMS (LOADS MARKED ON PLAN ARE DOUBLE THE ACTUAL LIVE LOADS).  
SUPPORTS FOR RAIL FASTENINGS AT SHOWN INTERVALS OR LESS WHERE THIS IS EXCEEDED RAIL STIFFENERS OR ADDITIONAL SUPPORTS WILL BE PROVIDED AT OWNERS EXPENSE.  
ALL SCREEN RAILINGS, STEPS AND LADDERS (IF REQUIRED).  
SHEAR GUARDS UNLESS OTHERWISE SPECIFIED.  
PIT DOORS AND PENTHOUSE FLOOR DOORS, ETC. (IF REQUIRED).  
PROPER VENTILATION, HEATING AND LIGHT REQUIRED IN PENTHOUSE OR MACHINE ROOM.  
ALL OTHER EQUIPMENT NECESSARY AND NOT OTHERWISE CALLED FOR IN ELEVATOR CONTRACT.  
DO NOT POUR DECK SLAB UNTIL MACHINE IS IN PLACE UNLESS OTHER PROVISION HAS BEEN MADE FOR GETTING MACHINE ON DECK. DECK SLAB DETAILS TO BE FURNISHED BY ELEVATOR CO.  
ENTRANCE WALLS TO BE ERECTED AFTER ENTRANCES ARE SET BY ELEVATOR COMPANY.

- BEFORE APPROVING THIS DRAWING THE ARCHITECT OR CONTRACTOR SHOULD CHECK THE FOLLOWING ITEMS IN PARTICULAR:
1. SUPPORTS FOR MACHINES AND SHEAVE BEAMS.
  2. DISTANCE ABOVE TOP LANDING.
  3. DISTANCE BELOW PENTHOUSE FLOOR.
  4. STRENGTH.
  5. PENTHOUSE AND MACHINE ROOM.
  6. INSIDE DIMENSIONS.
  7. DISTANCE FROM INSIDE FACE OF HATCH WALLS TO INSIDE FACE OF PENTHOUSE WALLS ON ALL FOUR SIDES.
  8. HEIGHT IN CLEAR.
  9. DOOR SIZE AND LOCATION.
  10. LOCATION OF ELECTRICAL FIXTURES.
  11. PIT DEPTH.
  12. HATCH (DIMENSIONS REFER TO FINISHED SIZES).
  13. FINISHED SIZES.
  14. FLOOR HEIGHTS.
  15. HATCH DOOR SIZES AND LOCATION OF BUCKS.
  16. DOOR CLEARANCE.
  17. DISTANCE ABOVE TOP LANDING TO LOWEST OR STACLE OVER HATCHWAY.

DATE	NO.	ISSUED TO	FOR
8-11-76	7 B D D	13th FLOOR	APPROV
3-13-77	8 B D D	11 FLOOR	APPROV
6-29-77	1 MTR	11 FLOOR	REF
7-2-77	3 ELEV. LND	11 FLOOR	APPROV

HATCHWAY SIZES PLUMB WITHIN ONE INCH OF FIGURES SHOWN QUANTITIES FOR CONTRACTOR.  
BY MR. J. SURGENOR DATE 4-2-77

THIS ARRANGEMENT APPROVED FOR CONTRACTOR BY MR. J. SURGENOR DATE 4-2-77

THIS ARRANGEMENT APPROVED BY ELEVATOR INSPECTOR NAME J. A. COSTELLA DATE 6-23-77

DATE	NO.	BY	DESCRIPTION
2-9-77	1	ICC	MADE FINAL
5-29-77	2	ICC	LISTED FOR CONSTRUCTION

**MONTGOMERY ELEVATOR COMPANY LTD.**  
1201 FRANKLIN STREET  
VANCOUVER, B.C.

ELECTRIC ELEVATOR LAYOUT FOR: SELECTIVE COLLECTIVE OPERATION  
BUILDING: 12 CLASS ICE BREAKERS #222  
LOCATION: 109 E. ESPLANADE,  
CITY: NORTH VANCOUVER, B.C.  
ARCHITECT: BURRARD-YARROWS GROUP  
ENGINEER:  
CONTRACTOR: BURRARD-YARROWS GROUP  
109 E. ESPLANADE, N. VANCOUVER B.C., V7L 4J6

DWG. BY C. CHIA	CHE. BY	SCALE AS SHOWN	DATE: PRELIM 7-13-76 FINAL 2-9-77
THIS INSTALLATION WILL CONFORM TO C.S.A. CODE B-64/1975		MECO REF. NO. CT-37457	CONTRACT NO. VT-3431

