



Procurement Hub – Ottawa Office,
Station 9W085, 9th Floor,
200 Kent Street,
Ottawa, Ontario K1A 0E6

Monday March 5, 2018

ADDENDUM NO. 2

Subject: ITT Invitation to Tender No. FP802-170324

Title: Ladder and Platform Refurbishment - Strait of Canso Range Towers

Location: Mulgrave and Port Malcolm, Nova Scotia

Closing Date: Thursday, March 8, 2018 @ 2:00 PM (EST)

Dear Sir/Madam:

Further to the above-mentioned Invitation to Tender, this **Addendum no.2** is to advise potential bidders of the following changes and/ or Questions & Answers from Bidders to this tender call to date:

QUESTIONS and ANSWERS

1. Question from Bidder:

Solar panels. Are we allowed to move these (if needed) to install platform and ladder? See below



DFO Answer 01:

The removal of solar panels at the two sites will be done by others.



2. **Question from Bidder:**

Removal of ladders. Do you want the welded brackets holding the ladders removed? See below



DFO Answer 02:

Please remove the brackets along with the ladders. The aluminum leg thickness is very thin however, so do not remove the weld or any leg material as it may compromise the structural integrity of the leg.

3. **Question from Bidder:**

Acceptance inspection - would we charge for re-mob? Or incorporate in price.

DFO Answer 03:

Please incorporate all costs, including any mobilization and demobilization costs in the lump sum price.

All other terms and conditions remain unchanged.

Yours truly,

Lynda Coulombe
Procurement and Contracting Consultant
Materiel and Procurement Services
Financial and Materiel Management Operations
200 Kent Street, 9th Floor, 9W085
Ottawa, ON K1A 0E6
Tel: (613) 327-9911
E-mail: Lynda.Coulombe@dfo-mpo.gc.ca