



Procurement Hub – Ottawa Office,
Station 9W085, 9th Floor,
200 Kent Street,
Ottawa, Ontario K1A 0E6

Monday March 12, 2018

ADDENDUM NO. 5

Subject: **ITT Invitation to Tender No. FP802-170324**

Title: **Ladder and Platform Refurbishment - Straight of Canso Range Towers**

Location: **Mulgrave and Port Malcolm, Nova Scotia**

Closing Date: **Thursday, March 15, 2018 @ 2:00 PM (EDT)**


Dear Sir/Madam:

Further to the above-mentioned Invitation to Tender, this **Addendum no.5** is to advise potential bidders of the following changes and/ or Questions & Answers from Bidders to this tender call to date:

QUESTIONS and ANSWERS

1. Question from Bidder:

It can be seen that once the ladder is removed, there will be a gap in the guardrail. In addition the railing seems attached to the scale that is removed. Should we consider replacing the two iron-angles used as guardrails (barriers)?





DFO Answer 01:

Yes, please remove the two short guardrail angles with the ladder, and replace with full length angles. Please use the same size and material guardrail as removed.

All other terms and conditions remain unchanged.

Yours truly,

Lynda Coulombe
Procurement and Contracting Consultant
Matériel and Procurement Services
Financial and Matériel Management Operations
200 Kent Street, 9th Floor, 9E255
Ottawa, ON K1A 0E6
Tel: (613) 327-9911
E-mail: Lynda.Coulombe@dfo-mpo.gc.ca