

Part 1 General

1.1 REFERENCE STANDARDS

- .1 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .2 The Master Painters Institute (MPI)
 - .1 Architectural Painting Specification Manual – current edition.
- .3 National Research Council Canada (NRC)
 - .1 National Building Code of Canada 2015 (NBC).

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00- Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for paint and coating products and include product characteristics, performance criteria, physical size, finish and limitations.
 - .2 Submit copies of WHMIS MSDS in accordance with Section 01 35 29.06- Health and Safety Requirements.
- .3 Samples:
 - .1 Submit for review and acceptance of each unit.
 - .2 Submit 200 x 300 mm sample panels of each paint with specified paint or coating in colours, gloss/sheen and textures required to MPI Painting Specification Manual standards.
- .4 Certificates: submit product certificates signed by manufacturer certifying materials comply with specified performance characteristics and criteria and physical requirements.

1.3 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Provide and maintain dry, temperature controlled, secure storage.
 - .2 Store painting materials and supplies away from heat generating devices.
 - .3 Store materials and equipment in well ventilated area within temperature as recommended by manufacturer.
 - .4 Fire Safety Requirements:
 - .1 Provide one 9 kg Type ABC fire extinguisher adjacent to storage area.

- .2 Store oily rags, waste products, empty containers and materials subject to spontaneous combustion in ULC approved, sealed containers and remove from site on a daily basis.
- .3 Handle, store, use and dispose of flammable and combustible materials in accordance with the National Fire Code of Canada.
- .4 Packaging Waste Management: remove for reuse and return by manufacturer of padding, pallets, crates, packaging materials as specified in Construction Waste Management Plan in accordance with Section 01 74 21- Construction/Demolition Waste Management and Disposal.

1.4 SITE CONDITIONS

- .1 Temperature:
 - .1 Apply paint finishes when ambient air and substrate temperatures at location of installation can be satisfactorily maintained during application and drying process, within MPI and paint manufacturer's prescribed limits.
- .2 Additional application requirements:
 - .1 Apply paint finish in areas where dust is no longer being generated by related construction operations or when wind conditions are such that airborne particles will not affect quality of finished surface.

Part 2 Products

2.1 MATERIALS

- .1 Supply paint materials for paint systems from single manufacturer.
- .2 Conform to latest MPI requirements for painting work including preparation and priming.
- .3 Materials in accordance with MPI - Architectural Painting Specification Manual "Approved Product" listing.
- .4 Colours:
 - .1 As indicated on architectural drawings.
- .5 Mixing and tinting:
 - .1 Perform colour tinting operations prior to delivery of paint to site, in accordance with manufacturer's written recommendations. Obtain written approval from Departmental Representative for tinting of painting materials.
 - .2 Use and add thinner in accordance with paint manufacturer's recommendations.
 - .1 Do not use kerosene or similar organic solvents to thin water-based paints.
 - .3 Thin paint for spraying in accordance with paint manufacturer's written recommendations.
 - .4 Re-mix paint in containers prior to and during application to ensure break-up of lumps, complete dispersion of settled pigment, and colour and gloss uniformity.
- .6 Gloss/sheen ratings:

- .1 Paint gloss is defined as sheen rating of applied paint, in accordance with following values:

Gloss Level-Category	Gloss @ 60 degrees	Sheen @ 85 degrees
Gloss Level 1 - Matte Finish	Max. 5	Max. 10
Gloss Level 2 - Velvet	Max.10	10 to 35
Gloss Level 3 - Eggshell	10 to 25	10 to 35
Gloss Level 4 - Satin	20 to 35	min. 35
Gloss Level 5 - Semi-Gloss	35 to 70	
Gloss Level 6 - Gloss	70 to 85	
Gloss Level 7 - High Gloss	More than 85	

- .2 Gloss level ratings of painted surfaces as specified.

- .7 Exterior painting:

- .1 Galvanized Metal: high contact/high traffic areas (doors, frames, railings and handrails, etc.)

- .1 EXT 5.3B - Alkyd G6 finish.

Part 3 Execution

3.1 GENERAL

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and data sheets.
- .2 Perform preparation and operations for interior painting in accordance with MPI - Architectural Painting Specifications Manual except where specified otherwise.

3.2 EXAMINATION

- .1 Investigate existing substrates for problems related to proper and complete preparation of surfaces to be painted. Report to Departmental Representative damages, defects, unsatisfactory or unfavourable conditions before proceeding with work.

3.3 PREPARATION/GENERAL

- .1 Protection of in-place conditions:
- .1 Protect existing building surfaces and adjacent structures from paint spatters, markings and other damage by suitable non-staining covers or masking. If damaged, clean and restore surfaces as directed by Departmental Representative.
- .2 Protect factory finished products and equipment.
- .2 Surface Preparation:
- .1 Place "WET PAINT" signs in occupied areas as painting operations progress. Signs to approval of Departmental Representative.
- .2 Clean and prepare surfaces in accordance with MPI - Architectural Painting Specification Manual specific requirements and coating manufacturer's recommendations.

- .3 Prevent contamination of cleaned surfaces by salts, acids, alkalis, other corrosive chemicals, grease, oil and solvents before prime coat is applied and between applications of remaining coats. Apply primer, paint, or pre-treatment as soon as possible after cleaning and before deterioration occurs.
- .4 Sand and dust between coats as required to provide adequate adhesion for next coat and to remove defects visible from a distance up to 1000 mm.
- .5 Clean metal surfaces to be painted by removing rust, loose mill scale, welding slag, dirt, oil, grease and other foreign substances in accordance with MPI requirements.

3.4 PREPARATION OF GALVANIZED ITEMS FOR PAINTING

- .1 Prepare all galvanized steel items that are to be painted as indicated on the drawings and that are not covered by Section 32 31 00 – Vehicle Sallyport Gates in accordance with MPI requirements before receiving the specified exterior paint system.

3.5 APPLICATION

- .1 Paint only after prepared surfaces have been accepted by Departmental Representative.
- .2 Use method of application approved by Departmental Representative.
 - .1 Conform to manufacturer's application recommendations.
- .3 Apply coats of paint in continuous film of uniform thickness.
 - .1 Repaint thin spots or bare areas before next coat of paint is applied.
- .4 Allow surfaces to dry and properly cure after cleaning and between subsequent coats for minimum time period as recommended by manufacturer.
- .5 Sand and dust between coats to remove visible defects.
- .6 Finish surfaces both above and below sight lines as specified for surrounding surfaces, including such surfaces as tops of interior cupboards and cabinets and projecting ledges.

3.6 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11- Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11- Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21- Construction/Demolition Waste Management and Disposal.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.
- .4 Place primer and paint defined as hazardous or toxic waste, including tubes and containers, in containers or areas designated for hazardous waste.

END OF SECTION