



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada

800 Burrard Street, Room 219

800, rue Burrard, pièce 219

Vancouver

British Columbia

V6Z 0B9

Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services Canada - Pacific
Region

800 Burrard Street, Room 219

800, rue Burrard, pièce 219

Vancouver

British C

V6Z 0B9

Title - Sujet Data Centre Temporary Cooling	
Solicitation No. - N° de l'invitation EZ899-183126/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client EZ899-183126	Date 2018-03-20
GETS Reference No. - N° de référence de SEAG PW-\$PWY-028-8313	
File No. - N° de dossier PWY-7-40390 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-03-22	
Time Zone Fuseau horaire Pacific Daylight Saving Time PDT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lam (PWY), Tian	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 363-7968 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: SSC - Institute of Ocean Sciences - Sidney, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ899-183126/A

Amd. No. - N° de la modif.
002

Buyer ID - Id de l'acheteur
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°

CCC - FMS No./N° VME

Les documents en français seront disponibles sur demande.

The Solicitation Amendment 002 is raised to issue Addendum 001.

Please find Addendum 001 herein.

All other terms and conditions remain unchanged.

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

DRAWINGS

1. Refer to Drawing E-100

- .1 Revise Key Note '1' to read as follows:

“Transformers are to be provided by the vendor as part of the temporary cooling package. Breaker, cable and disconnects for each of the two transformers have been provided by others. Disconnects will be located within 4m of proposed transformer locations shown. All wiring from the disconnects to the transformer and all secondary side wiring to be provided as part of the temporary cooling package.”

- .2 Delete Key Note '2'.

- .3 Clarify Detail 2-E100 as follows:

New breakers, cabling and disconnects for each of the two transformers will be provided by others, ahead of the start of work. Cabling from the disconnects to each of the two transformers, each of the two transformers, and cabling from the transformers to the four temporary air conditioning units to be provided as part of this tender package. Cabling from the disconnects to the transformers, the two transformers and cabling from the transformers to the temporary air conditioning units are to be removed upon the completion of the temporary cooling contract.

END OF ADDENDUM No. 1
