



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: 1-866-246-6893

AMENDMENT / MODIFICATION

003

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada
Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

- **Signed copy of this amendment is to accompany each tender.**
- **Une copie signée de cet amendement accompagne chaque offre.**

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet St. Andrew's Church Rehabilitation – Chilkoot Trail National Historic Site		
Solicitation No. - No. de l'invitation 5P420-17-5533/A	Date: March 21, 2018	
GETS Reference No. – No de reference de SEAG PW-18-00818959	Amendment No. - N° de la modif. 003	
Solicitation Closes:		
at – á 02:00 PM	on – le March 28, 2018	Time Zone - Fuseau horaire MDT - HAR
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/>	Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à : Rebecca Chen		
Telephone No. - No de téléphone (403) 292-8509	Fax No. – No de FAX: 1-866-246-6893	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein – Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Title - Titre	
Telephone No. - N° de telephone:	_____
Facsimile No. - N° de télécopieur:	_____
Signature	Date

Amendment 03

This amendment is being raised to distribute information from the bidder's conference and make changes to the tender package.

A) BIDDERS CONFERENCE

	Vendor	Name
1	NGC Builders	Byron Gilday Jesse Gilday
2	Ultimate Construction Inc	Philip Hoad Michel Babineau
3	AFAB Enterprises Ltd.	Teresa Klejno
4	Seismic 2000 Construction Ltd.	Rory Dellow or Dave Lammers
5	Big Rock Construction Company	Tom Falladown
6	Repp Industries Roofing Ltd.	Paul Tousignant
7	Southpaw Construction	Aren Coates

Contact information for the attendees are available upon request and approval from the vendors.

B) TENDER PACKAGE REVISIONS

In: Section 01 11 55 GENERAL INSTRUCTIONS

1.7 TRANSPORTATION

DELETE: 4.2 500 hours on type to be used;

REPLACE WITH: 4.2 50 hours on type to be used;

C) QUESTIONS AND ANSWERS

Q4/A4 from amendment 1 is revised to add one additional mock up:

4. Flashing assemblies: crickets, step flashing and kick-out diverter, and coping

Q7 Please could you provide a ground based photo of the trail from the railway station to the site?

A7 The trail from the Bennett train station to St Andrews is approximately 350 metres in length. The first 100 metres is relatively level and open, the final 250 metres is narrower trail, sees a rise of 15 metres over its length and occasionally follows boardwalks and steps. The attached Google images depict the trail between the Bennett train station and St Andrews in dry summer conditions. Google.com/maps may be of interest as an additional useful visual resource: <https://www.google.com/maps/@59.8453595,-134.9988536,2a,75y,199.65h,104.43t/data=!3m6!1e1!3m4!1sPVx7h5y2aaMkM4ij-QmQyQ!2e0!7i13312!8i6656>

Q8 Can we use different product than underlay felt paper?

A8 The felt paper is existing. New product is specified in the specifications.

Q9 What is the quantity for the damaged boards?

A9 Refer to Section 01 11 55 - General Instructions, 1.1.2.5 and Roof Assembly Note #2 on drawing A-102 for details.

Q10 What is the thickness of the plywood sheathing?

A10 Half inch.

Q11 Are shingles removed turned over to Parks Canada?

A11 Yes. The awarded contractor will be provided with bags on site to contain the removed shingles. This will be provided by Parks Canada.

Q12 Soldering is not allowed in place. Can you provide an alternative?

A12 Soldering is not allowed in place or within 11m of the building to protect against fire. As noted in Section 07 62 00, 2.3.9.4, all joints that need to be made in place to fit on the existing building are to "use a combination of sealants and seams to provide a watertight finish." The contractor should note these locations on their shop drawings.

Q13 Is Parks Canada re-routing the visitors and providing signage?

A13 Yes. Parks Canada will re-route the visitors and provide appropriate signage. Important to note that the contractor is still responsible for a perimeter fence around the work site. Please see specifications for details on fence and barrier requirements by contractor.

Q14 What is the earliest project start date?

A14 The earliest start date is weather dependant. For further information on train operating schedule feel free to contact:

White Pass & Yukon Route

Toll Free: 1-800-343-7373

info@wpyr.com

Q15 Do the materials have to be brought in by helicopter?

A15 No. Materials do not have to be transported by helicopter. Contractor is welcome to explore alternate options, i.e.: train, plane, boat. It is important to note that the site is designated as non-motorized.

Q16 Can we use the train for cargo transportation?

A16 It is the contractors responsibility to contact White Pass & Yukon Route to obtain details on cargo transportation by train.

Q17 Is there vehicular access to the Bennett train station?

A17 No. There is no access by road to the Bennett train station. The train station is approximately 500-700m downhill from St. Andrew's Church. Additionally, the site is designated as non-motorized.

Q18 Are helicopter operators in Whitehorse able to meet requirements?

A18 Yes. You should be able to find helicopter operators in Whitehorse which can meet the outlined requirements.

Q19 Will there be refrigeration units on site?

A19 No.

Q20 Will there be power provided on site?

A20 No. Power will be provided by contractor via generator.

Q21 Where are we designated to camp?

A21 The designated camp area is in very close proximity to the hiking campground itself.

Q22 Why is there a limitation to 8 people on site?

A22 There is a limitation to 8 personnel on site to site configuration and limitations to provide permanent accommodation space at Bennett.

Q23 Are any licenses required?

A23 Yes. A Parks Canada Business License will need to be obtained through the Whitehorse Parks Canada office prior to commencing with work.

Q24 Please advise and confirm whether any mechanical access is permitted from the railway station to the site such as Telehandler/Forklift/Zoom-Boom OR an All Terrain Vehicle with Trailer.

A24 No. This is a non-motorized site.

Q25 Advise and confirm whether Seacans can be utilized on site, either flown in via Helicopter or transported in from the Railway Station to the Site.

A25 Seacans may not be used on site.

All other terms and conditions remain unchanged.