



DRAWING NOTES:

- SUPPLY AND INSTALL NEW TRIPLEX DEPTH FILTER SYSTEM. REFER TO SCHEMATIC IN 4/M3 FOR TYPICAL NEW FILTER TANK C/W VALVE NEST SHOWING PIPING CONNECTIONS TO THE EXISTING SYSTEM.
- FLUSH THE EXISTING PIPES FROM THE RIVER WATER PUMPS TO THE FILTRATION SYSTEM, AND FROM THE FILTRATION SYSTEM TO PROCESS EQUIPMENT AS PER "SPECIFICATIONS 23 08 02 CLEANING AND START-UP MECHANICAL PIPING SYSTEMS." PLEASE REFER TO 1/M3 AND 2/M3 FOR PIPING TO BE FLUSHED IN THE BASEMENT AND 2ND FLOOR, RESPECTIVELY. PLEASE REFER TO 5/M3 FOR A SCHEMATIC OF THE OVERALL PROCESS.

Canada

Public Works and Government Services Canada / Travaux publics et Services gouvernementaux Canada
Real Property Branch / Direction générale des biens immobiliers

RSG ENGINEERING INC.

80 TIPPERARY PVT., NEPEAN, ON K2J 2T3
PHONE: (613) 721-0880
E-MAIL: goubko@rsgeng.com



Contractor to verify all dimensions & conditions on site and immediately notify the departmental representative of all discrepancies.

revisions	description	date
3	ISSUED FOR TENDER	2018/01/17
2	ISSUED FOR 100% REVIEW	2017/12/05
1	SUBMITTED FOR 99% REVIEW	2017/11/24

A	A
C	B C

project / projet

CLIFF STREET CHCP REPLACE SAND FILTERS

1 FLEET ST., OTTAWA, ON

drawing / dessin

MECHANICAL: NEW WORKS GROUND FLOOR

Designed By	C.G., R.G.	Conçu par
Date	2017/11/24	(yyyy/mm/dd)
Drawn By	C.G.	Dessiné par
Date	2017/11/24	(yyyy/mm/dd)
Reviewed By	R.G.	Examiné par
Date	2017/11/24	(yyyy/mm/dd)
Approved By	R.G.	Approuvé par
Date	2017/11/24	(yyyy/mm/dd)
Tender	SEBASTIEN BLAIS	Submission
Project Manager	Administrateur de projets	
Project no.	No. du projet	
	R.084332	
Drawing no.	No. du dessin	
	M-2	