



TENDER AMENDMENT

RETURN BIDS TO:

Parks Canada Agency
Mailroom
30 Victoria street
Gatineau, Quebec, J8X 0B3

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

Issuing Office:

Parks Canada Agency
Mailroom
30 Victoria street
Gatineau, Quebec, J8X 0B3

MODIFICATION D'APPEL D'OFFRES

RETOURNER LES SOUMISSIONS À :

Agence Parcs Canada
Salleducourier
30 rue Victoria
Gatineau (Quebec) J8X 0B3

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Bureau de distribution :

Agence Parcs Canada
Salleducourier
30 rue Victoria
Gatineau (Quebec) J8X 0B3

Title: Structural Rehabilitation of Four Structures Terra Nova National Park		
Solicitation No.: / N° de l'invitation : 5P201-18-0008/A	Amendment No.: / N° de modification de l'invitation : 001	Date: April 3, 2018 Date : 3 avril 2018
GETS Reference No.: / N° de référence de SEAG : PW-18-00820494		
Solicitation Closes: / L'invitation prend fin :		
At: 02:00 PM	On: April 6, 2018	Time Zone: Eastern Daylight Time (EDT)
À : 14h00	Le : 6 avril 2018	Fuseau horaire : Heure avancée de l'est (HAE)
Address Inquiries to: / Adresser toute demande de renseignements à : Nicole Levesque-Welch		
Telephone No.: / N° de téléphone : 819-420-9868	Fax No.: / N° de télécopieur :	Email Address: / Courriel : nicole.levesque-welch@pc.gc.ca
TO BE COMPLETED BY THE BIDDER (type or print) À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)		
<hr/> Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur <hr/>		
<hr/> Address - Adresse <hr/>		
<hr/> Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur <hr/>		
<hr/> Title - Titre <hr/>		
<hr/> Signature		<hr/> Date



AMENDMENT 001

This amendment is being raised to respond to questions submitted in response to solicitation 5P201-18-0008/A:

A. QUESTIONS AND ANSWERS

Q1. In **Section 03 30 07 Concrete Repairs**, asphalt Plug Joint Systems are referenced under Materials and Execution. We cannot locate any other references in the Specification, Drawings or Tender Form to where these joints would be used. Can you confirm if there are any Asphalt Plug Joints to be replaced please?

A1. Any reference to Asphalt Plug Joint Systems in Section 03 30 07 can be removed from the specification. There are no asphalt plug joint systems required on the project.

Q2. On Drawing S11 – Detail 7, the material for the wood decking of the Wildlife Walkways is designated as “Larch (No. 1 Structural) Boards”. In the Section 06 05 73 Dimension Timber of the Specifications, there is no mention of Larch. Two materials are listed – softwood timber (eastern hemlock, western hemlock, douglas fir) and hardwood timber (birch, hard maple, red or white oak). Can you confirm which material is to be used in this area please?

A2. In Section 06 05 73 Dimensional Timber, replace 2.1.1 with the following:

2.1.1 Softwood Timber: Graded and stamped to National Lumber Grading Authority (NLGA) No. 1 Structural, Larch species only will be used unless noted otherwise.

All other terms and conditions remain the same.