DISTRIBUTION SCHEDULE

EXISTING PANEL NAME	NEW PANEL NAME	DESCRIPTION	VOLTAGE	BUS	PH.	WIRES	LOCATION	FEEDERS	FED FROM	NOTES
E-1	6DPU6-E	DISTRIBUTION PANEL	600V	600A	3Ø	3W	UNIT 6 ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
N-1	6DPU6-N	DISTRIBUTION PANEL	600V	600A	3Ø	3W	UNIT 6 ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
E-2	2DPU6-E	DISTRIBUTION PANEL	208V	600A	3Ø	3W	UNIT 6 ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
N-2	2DPU6-N	DISTRIBUTION PANEL	208V	600A	3Ø	3W	UNIT 6 ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
EA	2PPU6-E1	PANELBOARD(DOUBLE TUB)	208V	225A	3Ø	4W	UNIT 6 TOWER ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
EB	2PPU6-E2	PANELBOARD	208V	225A	3Ø	4W	UNIT 6 ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
EC	2PPU6-E3	PANELBOARD	208V	225A	3Ø	4W	UNIT 6 ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
ED	2PPU6-E4	PANELBOARD	208V	225A	3Ø	4W	UNIT 6 ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
EE	2PPU6-E5	PANELBOARD	208V	100A	1Ø	3W	UNIT 6 ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
EF	2PPU6-E6	PANELBOARD	208V	100A	3Ø	4W	UNIT 6 TOWER ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
EG	2PPU6-E7	PANELBOARD	208V	225A	3Ø	4W	UNIT 6 TOWER ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
EH	2PPU6-E8	PANELBOARD	208V	100A	3Ø	4W	UNIT 6 TOWER ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
EK	2PPU6-E9	PANELBOARD	208V	225A	3Ø	4W	UNIT 6 ABOVE MCC ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
EH	2PPU6-E10	PANELBOARD	208V	225A	3Ø	4W	UNIT 6 ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
NA	2PPU6-N1	PANELBOARD	208V	225A	3Ø	4W	UNIT 6 TOWER ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
NB	2PPU6-N2	PANELBOARD	208V	225A	3Ø	4W	UNIT 6 TOWER ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
NC	2PPU6-N3	PANELBOARD	208V	225A	3Ø	4W	UNIT 6 TOWER ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
ND	2PPU6-N4	PANELBOARD	208V	225A	3Ø	4W	UNIT 6 TOWER ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
NE	2PPU6-N5	PANELBOARD	208V	225A	3Ø	4W	UNIT 6 TOWER ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
NF	2PPU6-N6	PANELBOARD	208V	225A	3Ø	4W	UNIT 6 ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
NG	2PPU6-N7	PANELBOARD	208V	225A	3Ø	4W	UNIT 6 ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
NJ	2PPU6-N8	PANELBOARD	208V	225A	3Ø	4W	UNIT 6 ELECTRICAL ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
NK	2PPU6-N9	PANELBOARD	208V	225A	3Ø	4W	UNIT 6 ABOVE MCC ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
N1A	2PPU6-N10	PANELBOARD	600V	225A	3Ø	4W	UNIT 6 ABOVE MCC ROOM	EXISTING TO REMAIN		REPLACE ALL CIRCUIT BREAKERS IN EXISTING PANEL
CDP-1	6DPC24-E1	DISTRIBUTION PANEL	600V	225A	3Ø	4W	C24 MAIN ELECTRICAL ROOM	EXISTING TO REMAIN	C13 LOAD CENTER	NEW EQUIPMENT

ELECTRICAL EQUIPMENT SCHEDULE

NEW PANEL NAME	EXISTING PANEL NAME	DESCRIPTION	KVA	VOLTAGE	RATING	PH.	WIRES	LOCATION	FEEDERS	FED FROM	NOTES
6MCCU6-E1	MCC1	MOTOR CONTROL CENTER		600V	600A	3Ø	3W	UNIT 6 MECHANICAL ROOM	3#2, 1#6GND-40C	6DPU6-E1	NEW EQUIPMENT TO REPLACE EXISTING
6MCCU6-N1	MCC2	MOTOR CONTROL CENTER		600V	600A	3Ø	3W	UNIT 6 MECHANICAL ROOM	3#2, 1#6GND-40C	6DPU6-N1	NEW EQUIPMENT TO REPLACE EXISTING
.											
750KVA		TRANSFORMER	150	600V-120/208V		3Ø	4W	UNIT 6	EXISTING	EXISTING	NEW EQUIPMENT TO REPLACE EXISTING
750KVA		TRANSFORMER	150	600V-120/208V		3Ø	4W	UNIT 6	EXISTING	EXISTING	NEW EQUIPMENT TO REPLACE EXISTING 1

MOTOR CONTROL SCHEDULE(6MCCU6-E1)

MOTOR No	DESCRIPTION	WATTS/HP	VOLTS, PH	FLA	BREAKER	FEEDER	CIRCUIT	STARTER	DISCON.	REMARKS	MOTOR No
AH-1	AIR HANDLING UNIT	3HP	600V 3PH	3.9A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-E1	NEMA SIZE 0		NOTE 1	AHU-1
AH-2	AIR HANDLING UNIT	3HP	600V 3PH	3.9A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-E1	NEMA SIZE 0		NOTE 1	AHU-2
AH-3	AIR HANDLING UNIT	2HP	600V 3PH	2.7 A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-E1	NEMA SIZE 00		NOTE 1	AHU-3
AH-4	AIR HANDLING UNIT	1HP	600V 3PH	1.7 A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-E1	NEMA SIZE 00		NOTE 1	AHU-4
RAF-1	RETURN AIR FAN	1HP	600V 3PH	1.4A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-E1	NEMA SIZE 00		NOTE 1	RAF-1
RAF-2	RETURN AIR FAN	1HP	600V 3PH	1.4 A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-E1	NEMA SIZE 00		NOTE 1	RAF-2
RAF-3	RETURN AIR FAN	5HP	600V 3PH	6.6A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-E1	NEMA SIZE 0		NOTE 1	RAF-3
RAF-4	RETURN AIR FAN	1/2HP	600V 3PH	0.9A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-E1	NEMA SIZE 00		NOTE 1	RAF-4
C-1	AIR COMPRESSOR	2HP	600V 3PH	0.8A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-E1				C-1
C-2	AIR COMPRESSOR	2HP	600V 3PH	0.8A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-E1				C-2
P-11	PUMP	10HP	600V 3PH	11 A	25.3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-E1	NEMA SIZE 1		NOTE 1	P-11
P-12	PUMP	10HP	600V 3PH	11A	25.3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-E1	NEMA SIZE 1		NOTE 1	P-12
SPARE			600V 3PH		15A3P		6MCCU6-E1				SPARE
SPARE			600V 3PH		15A3P		6MCCU6-E1				SPARE
P3	HYDRONIC PUMP	1/2HP	600V 3PH	0.9 A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-E1	NEMA SIZE 00		NOTE 1	P3
P4	HYDRONIC PUMP	1/2HP	600V 3PH	0.9 A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-E1	NEMA SIZE 00		NOTE 1	P4
P1	HYDRONIC PUMP	1HP	600V 3PH	1.7 A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-E1	NEMA SIZE 00		NOTE 1	P1
P2	HYDRONIC PUMP	1HP	600V 3PH	1.7 A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-E1	NEMA SIZE 00		NOTE 1	P2
SPARE			600V 3PH		15A3P		6MCCU6-E1				SPARE
SPARE			600V 3PH		15A3P		6MCCU6-E1				SPARE
PR-2			600V 3PH	10 A	25A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	NEMA SIZE 1		NOTE 1	PR-2
PR-1			600V 3PH	6.6 A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	NEMA SIZE 0		NOTE 1	PR-1

MOTOR CONTROL SCHEDULE(6MCCU6-N1)

MOTOR No	DESCRIPTION	WATTS/HP	VOLTS, PH	FLA	BREAKER	FEEDER	CIRCUIT	STARTER	DISCON.	REMARKS	MOTOR No
	MAIN DISCONNECT		600V 3PH		100A3P	4#3,1#6GND-40C EXISTING TO REMAIN	6MCCU6-N1			NOTE 1	
RAF-5	RETURN AIR FAN	1/2HP	600V 3PH	1.4 A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	NEMA SIZE 00		NOTE 1	RAF-5
RAF-6	RETURN AIR FAN	1 1/2HP	600V 3PH	2.4 A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	NEMA SIZE 00		NOTE 1	RAF-6
AH-5	AIR HANDLER	10HP	600V 3PH	12 A	25A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	NEMA SIZE 1		NOTE 1	AH-5
AH-6	AIR HANDLER	3HP	600V 3PH	3.9 A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	NEMA SIZE 1		NOTE 1	AH-6
AH-7	AIR HANDLER	1 1/2HP	600V 3PH	2.1A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	NEMA SIZE 00		NOTE 1	AH-7
AH-8	AIR HANDLER	1 1/2HP	600V 3PH	2.1A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	NEMA SIZE 00		NOTE 1	AH-8
VF-1	TUNNEL VENT FAN	1/2HP	600V 3PH	0.8A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	NEMA SIZE 00		NOTE 1	VF-1
AC-1	CONDENSING UNIT	5 1/2HP	600V 3PH	8.5A	20A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	MANUFACTURER		NOTE 1	AC-1
AC-2	CONDENSING UNIT	13 1/2HP	600V 3PH	18.85A	40A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	MANUFACTURER		NOTE 1	AC-2
EF-7	EXHAUST FAN	1/2HP	600V 3PH	0.8A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	NEMA SIZE 00		NOTE 1	EF-7
EF-8	EXHAUST FAN	1/2HP	600V 3PH	0.8A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	NEMA SIZE 00		NOTE 1	EF-8
EF-9	EXHAUST FAN	1/2HP	600V 3PH	0.8A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	NEMA SIZE 00		NOTE 1	EF-9
EF-10	EXHAUST FAN	1/2HP	600V 3PH	0.8A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	NEMA SIZE 00		NOTE 1	EF-10
EF-11	EXHAUST FAN	1/2HP	600V 3PH	0.8A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	NEMA SIZE 00		NOTE 1	EF-11
RAF 7	RETURN AIR FAN	3/4HP	600V 3PH	1.4 A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	NEMA SIZE 00		NOTE 1	RAF 7
EF-26	EXHAUST FAN	3/4HP	600V 3PH	1.4 A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	NEMA SIZE 00		NOTE 1	EF-26
EF-28	EXHAUST FAN	1/2HP	600V 3PH	0.8A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	NEMA SIZE 00		NOTE 1	EF-28
	WELDER				30A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1				
SPARE					15A3P						
RAF 8	RETURN AIR FAN	1 1/2HP	600V 3PH	2.4A	15A3P	3#12,1#12GND-19C EXISTING TO REMAIN	6MCCU6-N1	NEMA SIZE 00			RAF 8
	SPACE									7 DAY TIMER CONTROL	

NOTES

1. ELECTRICAL CONTRACTOR TO COORDINATE WITH OWNER TO CONFIRM MOTOR SIZE RATING ON SITE PRIOR TO SUPPLY OF NEW MCC EQUIPMENT

Public Works and Government Services Canada
Travaux publics et Services gouvernementaux Canada

REAL PROPERTY SERVICES
Western Region
SERVICES IMMOBILIERS
Région de l'ouest

wsp
203 WELLMAN CRESCENT
SASKATOON SASKATCHEWAN CANADA S7T 0J1
TEL.: 1-306-665-6223 | FAX: 1-306-665-8589 | WWW.WSPGROUP.COM

PROFESSIONAL ENGINEER — B.K. BEROLOF — MEMBER 5769 — 18/01/25 — SASKATCHEWAN

Association of Professional Engineers & Geoscientists of Saskatchewan
CERTIFICATE OF AUTHORIZATION
WSP CANADA INC.
Valid for 12 months
Permis de 12 mois valide jusqu'au
DEC 31st 2018

Revision/ Revision	Description/Description	Date/Date
.	.	.
1	ISSUED FOR ADDENDUM 1	29/03/2018
0	ISSUED FOR TENDER	25/01/2018

Client/client

CORRECTIONAL SERVICE CANADA

Project title/Titre du projet

SASKATCHEWAN PENITENTIARY ELECTRICAL UPGRADES 2017

Approved by/Approuve par
BKB

Designed by/Concept par
WSM

Drawn by/Dessine par
WSM

PWGSC Project Manager/Administrateur de Projets TPSGC

PWGSC, Architectural and Engineering Resources Manager/ Ressources Architectural et de Directeur d'Ingénierie, TPSGC

Client/client
CORRECTIONAL SERVICE CANADA

Drawing title/Titre du dessin

PACKAGE 4 - INSIDE THE WALLS (UNIT 6 & 7)
ELECTRICAL SCHEDULES

Project No./No. du projet	Sheet/ Feuille	Revision no./ La Révision no.
R.080653.001	E6-04-01 OF XX	1

PLOTTED ON: 3/28/2018 4:14:14 PM

0 10 20 30 40 50 60 70 80 90 100mm

31015